

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Josephine
Cartridge or Bag Filtration						Month/Year:	Apr-25
System Name:	Galice Resort			ID#:	41-90808		WTP ID: TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	64.00	64.00	0	25.00	0.12	0.12	
2	64.00	64.00	0	25.00	0.14	0.14	
3	49.00	40.00	9	25.00	0.14	0.14	
4	49.00	40.00	9	25.00	0.14	0.14	
5	48.00	40.00	8	25.00	0.12	0.12	
6	46.00	36.00	10	25.00	0.12	0.12	
7	64.00	64.00	0	25.00	0.11	0.11	
8	64.00	64.00	0	25.00	0.11	0.11	
9	64.00	64.00	0	25.00	0.10	0.10	
10	49.00	40.00	9	25.00	0.10	0.10	
11	64.00	64.00	0	25.00	0.10	0.10	
12	49.00	40.00	9	25.00	0.10	0.10	
13	49.00	40.00	9	25.00	0.09	0.09	
14	64.00	64.00	0	25.00	0.09	0.09	
15	64.00	64.00	0	25.00	0.15	0.15	
16	62.00	62.00	0	25.00	0.10	0.10	
17	62.00	62.00	0	25.00	0.15	0.15	
18	62.00	62.00	0	25.00	0.16	0.16	
19	62.00	62.00	0	25.00	0.16	0.16	
20	52.00	43.00	9	25.00	0.10	0.10	
21	64.00	64.00	0	25.00	0.18	0.18	
22	63.00	63.00	0	25.00	0.12	0.12	
23	63.00	63.00	0	25.00	0.13	0.13	
24	63.00	63.00	0	25.00	0.17	0.17	
25	63.00	63.00	0	25.00	0.15	0.15	
26	63.00	63.00	0	25.00	0.13	0.13	
27	54.00	46.00	8	25.00	0.14	0.14	
28	63.00	63.00	0	25.00	0.12	0.12	
29	62.00	62.00	0	25.00	0.12	0.12	
30	63.00	63.00	0	25.00	0.17	0.17	
31				25.00			
Cartridge & Bag Filtration				Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 1 NTU?			Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?			Yes	Yes	Yes		
Notes: PSI = pounds per square inch				PRINTED NAME: Kurt Swanson			
PSID = pounds per square inch difference (before filter - after filter)				SIGNATURE:Kurt Swanson		DATE:4/30/2025	
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.				541-476-3818		CERT #:	
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.							
PAGE 1 of 2							

OHA - Drinking Water Services - Surface Water Quality Data Form							WTP- :	
System Name:	GALICE RESORT	41-90808		April,2025			Disinfection Giardia Log Inactiv:	0.5
		341 Gallons /GPM =(T)						
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]	PH	formula	Yes / No	[GPM]
1	0.6	114	68.4	18.8	7.30	11.3	YES	3
2	0.6	114	68.4	10.2	7.20	19.5	YES	3
3	0.6	114	68.4	21.0	7.30	9.7	YES	3
4	0.6	114	68.4	20.6	7.40	10.4	YES	3
5	0.6	114	68.4	21.2	7.30	9.6	YES	3
6	0.6	114	68.4	22.4	7.30	8.83	YES	3
7	0.6	114	68.4	22.0	7.40	9.4	YES	3
8	0.6	114	68.4	21.6	7.30	9.33	YES	3
9	0.6	114	68.4	21.8	7.40	9.56	YES	3
10	0.6	114	68.4	22.6	7.40	9.05	YES	3
11	0.6	114	68.4	23.5	7.40	8.51	YES	3
12	0.6	114	68.4	22.9	7.40	8.87	YES	3
13	0.6	114	68.4	23.3	7.50	8.96	YES	3
14	0.6	114	68.4	23.6	7.40	8.46	YES	3
15	0.6	114	68.4	24.1	7.50	8.49	YES	3
16	0.6	114	68.4	23.3	7.40	8.63	YES	3
17	0.6	114	68.4	24.1	7.60	8.81	YES	3
18	0.6	114	68.4	24.4	7.50	8.32	YES	3
19	0.6	114	68.4	25.6	7.40	7.38	YES	3
20	0.6	114	68.4	25.9	7.50	7.51	YES	3
21	0.6	114	68.4	26.2	7.70	7.93	YES	3
22	0.6	114	68.4	26.1	7.40	7.13	YES	3
23	0.6	114	68.4	26.5	7.50	7.20	YES	3
24	0.6	114	68.4	27.0	7.50	6.96	YES	3
25	0.6	114	68.4	26.8	7.50	7.06	YES	3
26	0.6	114	68.4	27.0	7.50	6.96	YES	3
27	0.6	114	68.4	29.5	7.50	5.85	YES	3
28	0.6	114	68.4	28.6	7.80	6.99	YES	3
29	0.6	114	68.4	29.3	7.60	6.17	YES	3
30	0.6	114	68.4	29.5	7.60	6.08	YES	3
31	0.6	114	68.4			4.35	YES	3

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised November 2022

PAGE 2 of 2