

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Josephine
Cartridge or Bag Filtration						Month/Year:	May-25
System Name:	Galice Resort			ID#:	41-90808		WTP ID: TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	63.00	63.00	0	25.00	0.12	0.12	
2	63.00	63.00	0	25.00	0.12	0.12	
3	63.00	63.00	0	25.00	0.12	0.12	
4	63.00	63.00	0	25.00	0.11	0.11	
5	63.00	63.00	0	25.00	0.11	0.11	
6	56.00	55.00	1	25.00	0.11	0.11	
7	53.00	45.00	8	25.00	0.08	0.08	
8	61.00	61.00	0	25.00	0.12	0.12	
9	61.00	61.00	0	25.00	0.12	0.12	
10	61.00	61.00	0	25.00	0.12	0.12	
11	48.00	40.00	8	25.00	0.10	0.10	
12	62.00	62.00	0	25.00	0.09	0.09	
13	48.00	38.00	10	25.00	0.09	0.09	
14	60.00	60.00	0	25.00	0.16	0.16	
15	61.00	61.00	0	25.00	0.07	0.07	
16	61.00	60.00	1	25.00	0.12	0.12	
17	61.00	61.00	0	25.00	0.13	0.13	
18	61.00	61.00	0	25.00	0.11	0.11	
19	61.00	61.00	0	25.00	0.09	0.09	
20	62.00	61.00	1	25.00	0.18	0.18	
21	61.00	61.00	0	25.00	0.06	0.06	
22	61.00	61.00	0	25.00	0.06	0.06	
23	61.00	60.00	1	25.00	0.06	0.06	
24	44.00	42.00	2	25.00	0.08	0.08	
25	46.00	45.00	1	25.00	0.07	0.07	
26	46.00	46.00	0	25.00	0.06	0.06	
27	61.00	61.00	0	25.00	0.08	0.08	
28	61.00	61.00	0	25.00	0.08	0.08	
29	61.00	60.00	1	25.00	0.07	0.07	
30	47.00	47.00	0	25.00	0.06	0.06	
31	48.00	48.00	0	25.00	0.07	0.07	
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?			Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?			Yes	Yes	Yes		
Notes: PSI = pounds per square inch				PRINTED NAME: Kurt Swanson			
PSID = pounds per square inch difference (before filter - after filter)				SIGNATURE: Kurt Swanson			
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.				541-476-3818			CERT #:
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.							
PAGE 1 of 2							

OHA - Drinking Water Services - Surface Water Quality Data Form							WTP- :	
System Name:	GALICE RESORT	41-90808					Disinfection Giardia Log Inactiv:	0.5
		341 Gallons /GPM =(T)						
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.2	114	136.8	29.1	7.40	6.2	YES	3
2	1.2	114	136.8	29.2	7.50	6.4	YES	3
3	1.2	114	136.8	29.9	7.60	6.4	YES	3
4	1.2	114	136.8	29.9	7.70	6.6	YES	3
5	1	114	114.0	30.4	7.60	6.0	YES	3
6	1	114	114	30.2	7.70	6.32	YES	3
7	1	114	114.0	29.9	7.90	7.0	YES	3
8	1	114	114	26.0	7.80	8.75	YES	3
9	1.2	114	136.8	26.1	7.70	8.57	YES	3
10	1.2	114	136.8	26.3	7.80	8.78	YES	3
11	1	114	114	27.0	7.80	8.17	YES	3
12	1	114	114	27.2	7.80	8.06	YES	3
13	1	114	114	27.5	7.70	7.61	YES	3
14	1	114	114	28.2	8.00	8.13	YES	3
15	1.2	114	136.8	28.3	7.90	7.95	YES	3
16	1	114	114	28.7	7.80	7.28	YES	3
17	1.2	114	136.8	29.3	7.90	7.43	YES	3
18	1.2	114	136.8	29.5	7.90	7.33	YES	3
19	1.2	114	136.8	29.3	7.90	7.43	YES	3
20	1.2	114	136.8	29.2	7.80	7.20	YES	3
21	1.2	114	136.8	28.7	7.90	7.74	YES	3
22	1.2	114	136.8	29.3	7.90	7.43	YES	3
23	1.2	114	136.8	29.6	7.80	7.00	YES	3
24	1.2	114	136.8	28.7	7.90	7.74	YES	3
25	1.2	114	136.8	29.0	7.80	7.30	YES	3
26	1.2	114	136.8	29.3	7.90	7.43	YES	3
27	1.2	114	136.8	29.6	7.80	7.00	YES	3
28	1.2	114	136.8	28.3	7.90	7.95	YES	3
29	1	114	114	27.8	7.80	7.74	YES	3
30	1.2	114	136.8	27.7	7.80	7.98	YES	3
31	1.2	114	136.8	25.7	7.90	9.49	YES	3

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised November 2022

PAGE 2 of 2