

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Josephine
Cartridge or Bag Filtration						Month/Year:	Jun-25
System Name:		Galice Resort		ID#: 41-90808		WTP ID:	TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	62.00	62.00	0	25.00	0.06	0.06	
2	62.00	62.00	0	25.00	0.29	0.29	
3	50.00	49.00	1	25.00	0.07	0.07	
4	43.00	43.00	0	25.00	0.07	0.07	
5	55.00	55.00	0	25.00	0.09	0.09	
6	10.00	10.00	0	25.00	0.10	0.10	
7	51.00	50.00	1	25.00	0.12	0.12	
8	51.00	50.00	1	25.00	0.07	0.07	
9	51.00	50.00	1	25.00	0.07	0.07	
10	61.00	61.00	0	25.00	0.24	0.24	
11	46.00	46.00	0	25.00	0.06	0.06	
12	61.00	61.00	0	25.00	0.18	0.18	
13	61.00	61.00	0	25.00	0.07	0.07	
14	48.00	48.00	0	25.00	0.06	0.06	
15	48.00	48.00	0	25.00	0.09	0.09	
16	31.00	31.00	0	25.00	0.10	0.10	
17	40.00	40.00	0	25.00	0.07	0.07	
18	42.00	42.00	0	25.00	0.07	0.07	
19	48.00	48.00	0	25.00	0.06	0.06	
20	48.00	48.00	0	25.00	0.07	0.07	
21	48.00	48.00	0	25.00	0.07	0.07	
22	48.00	47.00	1	25.00	0.06	0.06	
23	48.00	48.00	0	25.00	0.07	0.07	
24	48.00	47.00	1	25.00	0.07	0.07	
25	62.00	62.00	0	25.00	0.13	0.13	
26	62.00	62.00	0	25.00	0.13	0.13	
27	49.00	48.00	1	25.00	0.11	0.11	
28	49.00	48.00	B32=""', "", B32-C	25.00	0.07	0.07	
29	49.00	48.00	1	25.00	0.08	0.08	
30	49.00	48.00	1	25.00	0.07	0.07	
31				25.00			
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?			Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?			Yes	Yes	Yes		
Notes: PSI = pounds per square inch				PRINTED NAME: Kurt Swanson			
PSID = pounds per square inch difference (before filter - after filter)				SIGNATURE: Kurt Swanson			
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.				541-476-3818		CERT #:	
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.							
PAGE 1 of 2							

OHA - Drinking Water Services - Surface Water Quality Data Form							WTP- :	
System Name:	GALICE RESORT	41-90808					Disinfection Giardia Log Inactiv:	0.5
		341 Gallons /GPM =(T)						
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.2	114	136.8	25.8	7.90	9.4	YES	3
2	1	114	114.0	26.2	8.00	9.3	YES	3
3	1	114	114.0	27.1	8.00	8.8	YES	3
4	1	114	114.0	27.6	8.50	10.2	YES	3
5	1.2	114	136.8	27.9	8.20	9.2	YES	3
6	1.2	114	136.8	28.3	8.00	8.26	YES	3
7	1.2	114	136.8	28.3	8.40	9.6	YES	3
8	1.2	114	136.8	29.9	8.10	7.69	YES	3
9	1	114	114	22.5	8.00	11.95	YES	3
10	1	114	114	25.1	8.00	10.03	YES	3
11	1	114	114	23.5	8.40	12.97	YES	3
12	1	114	114	24.8	8.60	12.81	YES	3
13	1.2	114	136.8	25.7	8.60	12.34	YES	3
14	1.2	114	136.8	26.4	8.00	9.40	YES	3
15	1.2	114	136.8	25.7	8.00	9.86	YES	3
16	1.2	114	136.8	26.4	8.30	10.52	YES	3
17	1	114	114	28.2	8.70	10.58	YES	3
18	1.2	114	136.8	28.0	8.00	8.43	YES	3
19	1.2	114	136.8	29.9	8.70	9.65	YES	3
20	1.2	114	136.8	29.5	8.00	7.61	YES	3
21	1.2	114	136.8	29.9	8.20	7.99	YES	3
22	1.2	114	136.8	30.1	8.10	7.59	YES	3
23	1.2	114	136.8	30.6	8.10	7.33	YES	3
24	1	114	114	31.3	8.10	6.82	YES	3
25	1	114	114	32.2	8.50	7.47	YES	3
26	1	114	114	32.3	8.50	7.42	YES	3
27	1.2	114	136.8	32.4	8.00	6.23	YES	3
28	1.2	114	136.8	33.1	8.10	6.17	YES	3
29	1	114	114	33.7	8.10	5.78	YES	3
30	1	114	114	34.0	8.10	5.66	YES	3
31		114						3

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised November 2022