

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Josephine
Cartridge or Bag Filtration						Month/Year:	Jul-25
System Name:	Galice Resort			ID#: 41-90808		WTP ID: TP-	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	42.00	42.00	0	25.00	0.07	0.07	
2	59.00	59.00	0	25.00	0.20	0.20	
3	49.00	49.00	0	25.00	0.14	0.14	
4	48.00	48.00	0	25.00	0.07	0.07	
5	49.00	49.00	0	25.00	0.07	0.07	
6	49.00	49.00	0	25.00	0.07	0.07	
7	50.00	50.00	0	25.00	0.15	0.15	
8	61.00	61.00	0	25.00	0.18	0.18	
9	61.00	61.00	0	25.00	0.18	0.18	
10	47.00	47.00	0	25.00	0.08	0.08	
11	49.00	49.00	0	25.00	0.07	0.07	
12	48.00	48.00	0	25.00	0.08	0.08	
13	49.00	49.00	0	25.00	0.08	0.08	
14	49.00	49.00	0	25.00	0.08	0.08	
15	51.00	51.00	0	25.00	0.10	0.10	
16	51.00	51.00	0	25.00	0.08	0.08	
17	42.00	42.00	0	25.00	0.09	0.09	
18	48.00	48.00	0	25.00	0.07	0.07	
19	48.00	48.00	0	25.00	0.07	0.07	
20	48.00	48.00	0	25.00	0.10	0.10	
21	48.00	48.00	0	25.00	0.10	0.10	
22	48.00	48.00	0	25.00	0.10	0.10	
23	48.00	48.00	0	25.00	0.07	0.07	
24	48.00	48.00	0	25.00	0.07	0.07	
25	48.00	48.00	0	25.00	0.06	0.06	
26	48.00	48.00	0	25.00	0.06	0.06	
27	50.00	49.00	1	25.00	0.06	0.06	
28	33.00	33.00	0	25.00	0.08	0.08	
29	41.00	41.00	0	25.00	0.07	0.07	
30	48.00	48.00	0	25.00	0.09	0.09	
31	49.00	49.00	0	25.00	0.06	0.06	
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?			Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?			Yes	Yes	Yes		
Notes: PSI = pounds per square inch				PRINTED NAME: Kurt Swanson			
PSID = pounds per square inch difference (before filter - after filter)				SIGNATURE:Kurt Swanson			
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.				541-476-3818		CERT #:	
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.							
PAGE 1 of 2							

OHA - Drinking Water Services - Surface Water Quality Data Form							WTP: :	
System Name:	GALICE RESORT	41-90808					Disinfection Giardia Log Inactiv:	0.5
		341 Gallons /GPM =(T)						
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	114	114.0	33.1	8.50	7.0	YES	3
2	0.8	114	91.2	33.6	8.40	6.4	YES	3
3	0.8	114	91.2	33.6	8.20	5.9	YES	3
4	1	114	114.0	33.3	8.10	5.9	YES	3
5	0.8	114	91.2	32.1	8.20	6.6	YES	3
6	0.8	114	91.2	32.6	8.10	6.09	YES	3
7	0.8	114	91.2	33.4	8.20	6.0	YES	3
8	1	114	114	33.9	8.60	6.91	YES	3
9	1	114	114	35.0	8.40	5.93	YES	3
10	1	114	114	34.8	8.60	6.49	YES	3
11	1	114	114	35.1	8.00	5.04	YES	3
12	1	114	114	34.7	8.10	5.39	YES	3
13	1	114	114	35.8	8.20	5.19	YES	3
14	1	114	114	36.1	8.10	4.89	YES	3
15	1	114	114	34.3	8.70	6.98	YES	3
16	0.8	114	91.2	34.5	8.30	5.77	YES	3
17	0.8	114	91.2	34.2	8.20	5.67	YES	3
18	1	114	114	34.8	8.30	5.78	YES	3
19	1	114	114	33.7	8.20	6.01	YES	3
20	0.8	114	91.2	34.6	8.20	5.51	YES	3
21	1	114	114	34.7	8.10	5.39	YES	3
22	1	114	114	34.0	8.20	5.88	YES	3
23	1	114	114	34.2	8.10	5.58	YES	3
24	0.8	114	91.2	34.5	8.10	5.34	YES	3
25	0.8	114	91.2	33.8	8.20	5.83	YES	3
26	0.8	114	91.2	34.1	8.20	5.71	YES	3
27	0.6	114	68.4	33.5	8.60	6.77	YES	3
28	0.8	114	91.2	34.3	8.50	6.32	YES	3
29	0.6	114	68.4	35.4	8.20	5.09	YES	3
30	0.8	114	91.2	36.1	8.10	4.77	YES	3
31	0.8	114	91.2	36.4	8.20	4.86	YES	3

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
dlw.dmcce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised November 2022