

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Josephine
Cartridge or Bag Filtration						Month/Year:	Oct-25
System Name:	Galice Resort			ID#: 41-90808		WTP ID: TP-	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	41.00	41.00	0	25.00	0.11	0.11	
2	31.00	31.00	0	25.00	0.08	0.08	
3	45.00	45.00	0	25.00	0.08	0.08	
4	42.00	42.00	0	25.00	0.08	0.08	
5	62.00	62.00	0	25.00	0.13	0.13	
6	63.00	63.00	0	25.00	0.09	0.09	
7	61.00	61.00	0	25.00	0.10	0.10	
8	62.00	62.00	0	25.00	0.10	0.10	
9	64.00	64.00	0	25.00	0.10	0.10	
10	62.00	62.00	0	25.00	0.10	0.10	
11	62.00	62.00	0	25.00	0.12	0.12	
12	63.00	63.00	0	25.00	0.10	0.10	
13	63.00	63.00	0	25.00	0.10	0.10	
14	42.00	42.00	0	25.00	0.08	0.08	
15	63.00	63.00	0	25.00	0.09	0.09	
16	40.00	40.00	0	25.00	0.08	0.08	
17	44.00	44.00	0	25.00	0.10	0.10	
18	40.00	40.00	0	25.00	0.07	0.07	
19	42.00	42.00	0	25.00	0.08	0.08	
20	61.00	61.00	0	25.00	0.09	0.09	
21	64.00	64.00	0	25.00	0.08	0.08	
22	62.00	62.00	0	25.00	0.10	0.10	
23	63.00	63.00	0	25.00	0.08	0.08	
24	64.00	64.00	0	25.00	0.09	0.09	
25	42.00	42.00	0	25.00	0.12	0.12	
26	30.00	30.00	0	25.00	0.14	0.14	
27	44.00	44.00	0	25.00	0.12	0.12	
28	62.00	62.00	0	25.00	0.11	0.11	
29	62.00	62.00	0	25.00	0.11	0.11	
30	66.00	66.00	0	25.00	0.08	0.08	
31	66.00	66.00	0	25.00	0.09	0.09	
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?			Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?			Yes	Yes	Yes		
Notes: PSI = pounds per square inch					PRINTED NAME: Kurt Swanson		
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE:Kurt Swanson		
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					541-476-3818		CERT #:
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.							
PAGE 1 of 2							

OHA - Drinking Water Services - Surface Water Quality Data Form							WTP- :	
System Name:	GALICE RESORT	41-90808					Disinfection Giardia Log Inactiv:	0.5
		341 Gallons /GPM =(T)						
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.6	114	68.4	36.2	8.30	5.0	YES	3
2	0.6	114	68.4	35.9	8.70	6.0	YES	3
3	0.6	114	68.4	35.9	8.70	6.0	YES	3
4	0.6	114	68.4	35.9	8.60	5.7	YES	3
5	0.6	114	68.4	36.0	8.70	5.9	YES	3
6	0.6	114	68.4	36.2	8.70	5.84	YES	3
7	0.6	114	68.4	36.2	8.70	5.8	YES	3
8	0.6	114	68.4	35.9	8.60	5.74	YES	3
9	0.6	114	68.4	36.1	8.40	5.24	YES	3
10	0.6	114	68.4	36.2	8.70	5.84	YES	3
11	0.6	114	68.4	36.0	8.60	5.70	YES	3
12	0.6	114	68.4	36.7	8.70	5.64	YES	3
13	0.6	114	68.4	36.4	8.60	5.54	YES	3
14	0.6	114	68.4	36.6	8.60	5.46	YES	3
15	0.4	114	45.6	36.4	8.60	5.41	YES	3
16	0.6	114	68.4	36.6	8.60	5.46	YES	3
17	0.6	114	68.4	37.1	8.40	4.88	YES	3
18	0.6	114	68.4	37.2	8.60	5.24	YES	3
19	0.6	114	68.4	37.8	8.50	4.83	YES	3
20	0.6	114	68.4	37.5	8.70	5.33	YES	3
21	0.6	114	68.4	37.4	8.70	5.37	YES	3
22	0.6	114	68.4	38.2	8.60	4.88	YES	3
23	0.6	114	68.4	38.1	8.60	4.92	YES	3
24	0.6	114	68.4	38.1	8.70	5.11	YES	3
25	0.6	114	68.4	38.6	8.50	4.57	YES	3
26	0.4	114	45.6	38.3	8.60	4.73	YES	3
27	0.4	114	45.6	38.3	8.60	4.73	YES	3
28	0.6	114	68.4	38.7	8.70	4.90	YES	3
29	0.8	114	91.2	38.9	8.70	4.95	YES	3
30	0.6	114	68.4	39.0	8.50	4.44	YES	3
31	0.6	114	68.4	39.6	8.60	4.42	YES	3

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised November 2022

PAGE 2 of 2