

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Josephine
Cartridge or Bag Filtration						Month/Year:	Nov-25
System Name:	Galice Resort			ID#: 41-90808		WTP ID: TP-	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	55.00	55.00	0	25.00	0.10	0.10	
2	56.00	56.00	0	25.00	0.11	0.11	
3	64.00	64.00	0	25.00	0.09	0.09	
4	64.00	64.00	0	25.00	0.08	0.08	
5	64.00	63.00	1	25.00	0.09	0.09	
6	45.00	45.00	0	25.00	0.09	0.09	
7	45.00	45.00	0	25.00	0.10	0.10	
8	62.00	62.00	0	25.00	0.20	0.20	
9	62.00	62.00	0	25.00	0.10	0.10	
10	62.00	62.00	0	25.00	0.10	0.10	
11	45.00	45.00	0	25.00	0.09	0.09	
12	64.00	64.00	0	25.00	0.10	0.10	
13	60.00	60.00	0	25.00	0.10	0.10	
14	62.00	62.00	0	25.00	0.10	0.10	
15	62.00	62.00	0	25.00	0.10	0.10	
16	60.00	60.00	0	25.00	0.11	0.11	
17	60.00	60.00	0	25.00	0.14	0.14	
18	59.00	59.00	0	25.00	0.08	0.08	
19	60.00	60.00	0	25.00	0.10	0.10	
20	42.00	42.00	0	25.00	0.09	0.09	
21	62.00	62.00	0	25.00	0.10	0.10	
22	42.00	42.00	0	25.00	0.11	0.11	
23	62.00	62.00	0	25.00	0.10	0.10	
24	62.00	62.00	0	25.00	0.10	0.10	
25	62.00	62.00	0	25.00	0.08	0.08	
26	62.00	62.00	0	25.00	0.11	0.11	
27	44.00	44.00	0	25.00	0.11	0.11	
28	40.00	40.00	0	25.00	0.11	0.11	
29	40.00	40.00	0	25.00	0.07	0.07	
30	55.00	55.00	0	25.00	0.15	0.15	
31				25.00			
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?			Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?			Yes	Yes	Yes		
Notes: PSI = pounds per square inch				PRINTED NAME: Kurt Swanson			
PSID = pounds per square inch difference (before filter - after filter)				SIGNATURE:Kurt Swanson			
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.				541-476-3818		CERT #:	
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.							
PAGE 1 of 2 1							

OHA - Drinking Water Services - Surface Water Quality Data Form							WTP- :	
System Name:	GALICE RESORT	41-90808					Disinfection Giardia Log Inactiv:	0.5
		341 Gallons /GPM =(T)						
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	114	91.2	39.0	8.60	4.7	YES	3
2	0.8	114	91.2	39.9	8.60	4.4	YES	3
3	0.8	114	91.2	39.9	8.50	4.3	YES	3
4	0.8	114	91.2	40.8	8.30	3.7	YES	3
5	0.8	114	91.2	40.8	8.50	4.0	YES	3
6	0.8	114	91.2	41.0	8.50	3.94	YES	3
7	0.4	114	45.6	41.5	8.50	3.6	YES	3
8	0.6	114	68.4	41.8	8.60	3.78	YES	3
9	0.6	114	68.4	41.8	8.80	4.09	YES	3
10	0.6	114	68.4	42.0	8.50	3.58	YES	3
11	0.8	114	91.2	42.6	8.30	3.24	YES	3
12	0.8	114	91.2	42.6	8.50	3.51	YES	3
13	0.6	114	68.4	42.7	8.50	3.40	YES	3
14	0.6	114	68.4	42.6	8.50	3.43	YES	3
15	0.6	114	68.4	42.7	8.60	3.54	YES	3
16	0.8	114	91.2	43.0	8.40	3.28	YES	3
17	0.8	114	91.2	43.2	8.40	3.23	YES	3
18	0.6	114	68.4	43.5	8.40	3.08	YES	3
19	0.6	114	68.4	43.1	8.40	3.17	YES	3
20	0.8	114	91.2	43.4	8.50	3.31	YES	3
21	0.8	114	91.2	43.2	8.40	3.23	YES	3
22	0.8	114	91.2	43.3	8.50	3.34	YES	3
23	0.8	114	91.2	43.4	8.40	3.18	YES	3
24	0.8	114	91.2	43.5	8.40	3.16	YES	3
25	0.8	114	91.2	43.8	8.40	3.09	YES	3
26	0.8	114	91.2	43.9	8.40	3.07	YES	3
27	0.8	114	91.2	43.8	8.50	3.22	YES	3
28	0.8	114	91.2	43.9	8.30	2.94	YES	3
29	0.8	114	91.2	43.8	8.30	2.97	YES	3
30	0.8	114	91.2	43.9	8.40	3.07	YES	3
31		114						3

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised November 2022