

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	COOS		
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems						Month/Year:	8/21		
System Name:	Camp Myrtlewood			ID#: 41	90861	WTP : TP -	SSF/Chlorination		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]		
OFF									
OFF									
OFF									
OFF									
5			0.22				0.22		
OFF									
OFF									
OFF									
OFF									
10			0.25				0.25		
OFF									
OFF									
OFF									
OFF									
15			0.24				0.24		
OFF									
OFF									
OFF									
OFF									
20			0.23				0.23		
OFF									
OFF									
OFF									
OFF									
25			0.23				0.23		
OFF									
OFF									
OFF									
OFF									
30			0.25				0.25		
OFF									
Slow Sand/Membrane/DE Filtration/Unfiltered				Monthly Summary (Answer Yes or No)					
95% of daily turbidity readings ≤ 1 NTU? ²			Yes	CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?			
All daily turbidity readings ≤ 5 NTU?			Yes	Yes		Yes			
Notes:				PRINTED NAME: Morgan Woods					
				SIGNATURE: Morgan Woods			DATE: 09/10/2021		
				PHONE #: (541)572.5307			CERT #: N/A		
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.									
PAGE 1 of 2									
OHA - Drinking Water Services - Surface Water Quality Data Form						WTP- :	SSF/Chlorination		
System Name:	Camp Myrtlewood	ID#: 41	90861	Month/Year:		Disinfection <i>Giardia</i> Log Inactiv:	1.0		

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
OFF								
OFF								
OFF								
OFF								
5	0.6	197	118.2	12.0	7.00	32.5	YES	0.5
OFF								
OFF								
OFF								
OFF								
10	0.4	197	78.8	12.0	7.20	34.0	YES	0.5
OFF								
OFF								
OFF								
OFF								
15	0.24	197	47.3	11.0	7.20	35.6	YES	0.5
OFF								
OFF								
OFF								
OFF								
20	0.6	197	118.2	12.0	7.30	36.0	YES	0.5
OFF								
OFF								
OFF								
OFF								
25	0.4	197	78.8	11.0	7.00	33.9	YES	0.5
OFF								
OFF								
OFF								
OFF								
30	0.6	197	118.2	12.0	7.20	34.8	YES	0.5
OFF								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350