

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	COOS
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems						Month/Year:	12/21
System Name:	Camp Myrtlewood			ID#: 41	90861	WTP : TP -	SSF/Chlorination
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
OFF							
OFF							
3			0.23				0.23
OFF							
OFF							
OFF							
OFF							
8			0.25				0.25
OFF							
OFF							
OFF							
OFF							
13			0.21				0.21
OFF							
OFF							
OFF							
OFF							
18			0.22				0.22
OFF							
OFF							
OFF							
OFF							
23			0.25				0.25
OFF							
OFF							
OFF							
OFF							
28			0.21				0.21
OFF							
OFF							
OFF							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes:

PRINTED NAME: Morgan Woods

SIGNATURE: Morgan Woods DATE: 01/10/2022

PHONE #: (541)572.5307 CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

PAGE 1 of 2

OHA - Drinking Water Services - Surface Water Quality Data Form					WTP- :	SSF/Chlorination
System Name:	Camp Myrtlewood	ID#: 41	90861	Month/Year:	Disinfection <i>Giardia</i> Log Inactiv:	1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
OFF								
OFF								
3	0.4	197	78.8	7.8	7.90	57.4	YES	0.11
OFF								
OFF								
OFF								
8	0.6	197	118.2	7.6	7.90	59.5	YES	0.11
OFF								
OFF								
OFF								
13	0.4	197	78.8	7.9	8.00	59.1	YES	0.11
OFF								
OFF								
OFF								
18	0.6	197	118.2	8.0	7.80	55.9	YES	0.11
OFF								
OFF								
OFF								
23	0.4	197	78.8	7.8	8.00	59.5	YES	0.11
OFF								
OFF								
OFF								
28	0.6	197	118.2	7.5	7.90	59.9	YES	0.11
OFF								
OFF								
OFF								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350