

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **COOS**
 Month/Year: **May-23**

System Name: **Camp Myrtlewood** ID#: **41 90861** WTP : **TP - SSF/Chlorination**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.20				
2			0.20				
3			0.20				
4			0.20				
5			0.20				
6			0.20				
7			0.20				
8			0.20				
9			0.20				
10			0.20				
11			0.20				
12			0.20				
13			0.20				
14			0.10				
15			0.10				
16			0.10				
17			0.10				
18			0.30				
19			0.20				
20			0.20				
21			0.10				
22			0.10				
23			0.10				
24			0.10				
25			0.10				
26			0.10				
27			0.10				
28			0.10				
29			0.10				
30			0.10				
31			0.10				

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? Yes	No	Yes

Notes:	PRINTED NAME: Reid Hirt	
	SIGNATURE: Reid Hirt	DATE: 6/4/23
	PHONE #: (541)572.5307	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : SSF/Chlorination
 Disinfection *Giardia* Log Inactiv: 1.0

System Name: Camp Myrtlewood ID#: 41 90861 Month/Year:

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.4	43	17.2	15.0	7.70	33.0	NO	0.11
2	0.4	43	17.2	14.8	7.76	34.2	NO	0.006
3	0.4	43	17.2	16.7	7.77	30.2	NO	0.02
4	0.4	43	17.2	14.1	7.80	36.3	NO	0.02
5	0.4	43	17.2	14.0	7.70	35.2	NO	0.02
6	0.4	43	17.2	13.8	7.68	35.5	NO	0.02
7	0.6	43	25.8	13.3	7.83	39.6	NO	0.18
8	0.8	43	34.4	15.8	7.69	32.6	YES	0.069
9	1	43	43.0	15.3	8.03	39.1	YES	0.3
10	1	43	43.0	18.0	7.77	29.7	YES	0.32
11	1	43	43.0	17.3	7.69	30.2	YES	0.3
12	1	43	43.0	16.4	8.01	36.1	YES	0.27
13	0.8	43	34.4	17.1	7.80	31.1	YES	1.43
14	1	43	43.0	17.4	7.80	31.2	YES	0.048
15	1	43	43.0	17.7	7.80	30.6	YES	0.26
16	1	43	43.0	17.2	7.88	32.6	YES	0.31
17	1	43	43.0	17.7	7.82	30.8	YES	0.3
18	1	43	43.0	17.2	7.88	32.6	YES	0.37
19	1	43	43.0	16.7	7.88	33.7	YES	0.2
20	1	43	43.0	16.6	7.80	32.9	YES	0.29
21	1	43	43.0	16.4	7.77	33.0	YES	0.15
22	1	43	43.0	15.0	7.95	38.7	YES	0.21
23	0.4	43	17.2	16.8	7.68	29.0	NO	0.06
24	0.4	43	17.2	18.5	7.80	27.1	NO	0.07
25	0.8	43	34.4	15.3	7.81	35.2	NO	0.09
26	1	43	43.0	16.4	7.88	34.4	YES	0.25
27	1	43	43.0	16.7	7.82	33.0	YES	0.06
28	1	43	43.0	15.5	7.81	35.6	YES	0.11
29	1	43	43.0	16.0	7.72	33.3	YES	0.12
30	1	43	43.0	18.2	7.74	28.9	YES	0.09
31	1	43	43.0	17.9	7.74	29.5	YES	0.66

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350