

| OHA - Drinking Water Services - Surface Water Quality Data Form   |                 |            |            |   |                               | County:                                  | COOS  |  |
|---|-----------------|------------|------------|---|-------------------------------|--|---|--|
| Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems   |                 |            |            |   |                               | Month/Year:                              | 4/24  |  |
| System Name:  | Camp Myrtlewood |            |            | ID#: 41                                   | 90861                         | WTP : TP -                               | SSF/Chlorination  |  |
| Day   | 12 AM [NTU]     | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU]                                | 4 PM [NTU]                    | 8 PM [NTU]                               | Highest Reading of the day <sup>1</sup> [NTU]           |  |
| 1   |                 |            | 0.30       |   |                               |  | 0.30  |  |
| 2   |                 |            | 0.70       |   |                               |  | 0.70  |  |
| 3   |                 |            | 0.50       |   |                               |  | 0.50  |  |
| 4   |                 |            | 0.40       |   |                               |  | 0.40  |  |
| OFF   |                 |            |            |   |                               |  |   |  |
| OFF   |                 |            |            |   |                               |  |   |  |
| OFF   |                 |            |            |   |                               |  |   |  |
| OFF   |                 |            |            |   |                               |  |   |  |
| 9   |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 10  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 11  |                 |            | 0.30       |   |                               |  | 0.30  |  |
| 12  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 13  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| OFF   |                 |            |            |   |                               |  |   |  |
| OFF   |                 |            |            |   |                               |  |   |  |
| OFF   |                 |            |            |   |                               |  |   |  |
| OFF   |                 |            |            |   |                               |  |   |  |
| OFF   |                 |            |            |   |                               |  |   |  |
| 20  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 21  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 22  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 23  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 24  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 25  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 26  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 27  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 28  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 29  |                 |            | 0.20       |   |                               |  | 0.20  |  |
| 30  |                 |            | 0.40       |   |                               |  | 0.40  |  |
| 31  |                 |            | 0.40       |   |                               |  | 0.40  |  |
| <b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>  |                 |            |            | <b>Monthly Summary (Answer Yes or No)</b> |                               |  |   |  |
| 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>   |                 |            |            | Yes                                       | CT's met everyday? (see back) |  | All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? |  |
| All daily turbidity readings ≤ 5 NTU?   |                 |            |            | Yes                                       | Yes                           |  | Yes   |  |
| <b>Notes:</b>   |                 |            |            | PRINTED NAME: Shauna Danielson            |                               |  |   |  |
|   |                 |            |            | SIGNATURE: Shauna Danielson               |                               |  | 5/7/24  |  |
|   |                 |            |            | PHONE #: (541)572.5307                    |                               |  | CERT #: N/A   |  |
| <sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only. |                 |            |            |   |                               |  |   |  |
| PAGE 1 of 2   |                 |            |            |   |                               |  |   |  |
| <b>OHA - Drinking Water Services - Surface Water Quality Data Form</b>  |                 |            |            |   |                               | WTP- :                                   | SSF/Chlorination  |  |
| System Name:  | Camp Myrtlewood | ID#: 41    | 90861      | Month/Year:                               | 4/24                          | Disinfection <i>Giardia</i> Log Inactiv: | 1.0   |  |

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> | Contact Time (T) | Actual CT    | Temp  | pH   | Required CT | CT Met? <sup>3</sup> | Peak Hourly Demand Flow |
|-------------|---|------------------|--------------|-------|------|-------------|----------------------|-------------------------|
|             | [ppm or mg/L]   | [minutes]        | <b>C X T</b> | [° C] |      | formula     | Yes / No             | [GPM]                   |
| 1           | 1.9   | 43               | 81.7         | 14.8  | 8.12 | 46.2        | YES                  | 0.04                    |
| 2           | 2.1   | 43               | 90.3         | 13.8  | 8.20 | 52.0        | YES                  | 0.14                    |
| 3           | 2   | 13.9             | 27.8         | 13.9  | 8.16 | 50.4        | YES                  | 0.14                    |
| 4           | 1.6   | 43               | 68.8         | 12.5  | 8.20 | 53.6        | YES                  | 0.15                    |
| OFF         |   |                  |              |       |      |             |                      |                         |
| OFF         |   |                  |              |       |      |             |                      |                         |
| OFF         |   |                  |              |       |      |             |                      |                         |
| OFF         |   |                  |              |       |      |             |                      |                         |
| 9           | 1.5   | 43               | 64.5         | 11.6  | 8.35 | 59.3        | YES                  | 0.1                     |
| 10          | 1.6   | 43               | 68.8         | 13.2  | 8.12 | 49.7        | YES                  | 0.08                    |
| 11          | 1.4   | 43               | 60.2         | 12.5  | 8.16 | 51.6        | YES                  | 0.04                    |
| 12          | 1.8   | 43               | 77.4         | 13.9  | 8.19 | 49.8        | YES                  | 0.08                    |
| 13          | 1.7   | 43               | 73.1         | 12.7  | 8.13 | 52.1        | YES                  | 0.09                    |
| OFF         |   |                  |              |       |      |             |                      |                         |
| OFF         |   |                  |              |       |      |             |                      |                         |
| OFF         |   |                  |              |       |      |             |                      |                         |
| OFF         |   |                  |              |       |      |             |                      |                         |
| OFF         |   |                  |              |       |      |             |                      |                         |
| OFF         |   |                  |              |       |      |             |                      |                         |
| 20          | 1.9   | 43               | 81.7         | 10.7  | 8.87 | 79.8        | YES                  | 0.11                    |
| 21          | 1.4   | 43               | 60.2         | 10.7  | 8.62 | 41.3        | YES                  | 0.14                    |
| 22          | 1.1   | 43               | 47.3         | 13.9  | 8.19 | 41.3        | YES                  | 0.08                    |
| 23          | 1.5   | 43               | 64.5         | 12.2  | 8.20 | 53.9        | YES                  | 0.14                    |
| 24          | 1.4   | 43               | 60.2         | 14.6  | 8.09 | 43.8        | YES                  | 0.2                     |
| 25          | 1.4   | 43               | 60.2         | 14.3  | 8.19 | 46.3        | YES                  | 0.14                    |
| 26          | 1.4   | 43               | 60.2         | 14.4  | 8.19 | 46.0        | YES                  | 0.2                     |
| 27          | 1.4   | 43               | 60.2         | 13.8  | 8.22 | 48.4        | YES                  | 0.09                    |
| 28          | 1.3   | 43               | 55.9         | 13.6  | 8.14 | 47.1        | YES                  | 0.1                     |
| 29          | 1.2   | 43               | 51.6         | 13.6  | 8.18 | 47.3        | YES                  | 0.1                     |
| 30          | 1.2   | 43               | 51.6         | 12.9  | 8.20 | 49.9        | YES                  | 0.1                     |
| 31          | 1.2   | 43               | 51.6         | 14.4  | 8.23 | 45.7        | YES                  | 0.1                     |

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350