

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	COOS		
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems						Month/Year:	10/24		
System Name:	Camp Myrtlewood			ID#: 41	90861	WTP : TP -	SSF/Chlorination		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]		
1			0.09				0.09		
2			0.10				0.10		
3			0.10				0.10		
4			0.11				0.11		
5			0.11				0.11		
6			0.11				0.11		
7			0.11				0.11		
8			0.11				0.11		
9			0.10				0.10		
10			0.11				0.11		
11			0.11				0.11		
12			0.11				0.11		
13			0.10				0.10		
14			0.10				0.10		
15			0.10				0.10		
16			0.16				0.16		
17			0.13				0.13		
18			0.11				0.11		
19			0.12				0.12		
20			0.26				0.26		
21			0.11				0.11		
22			0.17				0.17		
23			0.12				0.12		
24			0.12				0.12		
25			0.14				0.14		
26			0.14				0.14		
27			0.14				0.14		
28			0.10				0.10		
29			0.11				0.11		
30			0.10				0.10		
31			0.11				0.11		
<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>				<b>Monthly Summary (Answer Yes or No)</b>					
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>				Yes	CT's met everyday? (see back)		All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?				Yes	Yes		Yes		
<b>Notes:</b>				<b>PRINTED NAME: Shauna Danielson</b>					
				<b>SIGNATURE: Shauna Danielson</b>			<b>11/8/24</b>		
				<b>PHONE #: (541)572.5307</b>			<b>CERT #: N/A</b>		
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.									
PAGE 1 of 2									
<b>OHA - Drinking Water Services - Surface Water Quality Data Form</b>						WTP- :	SSF/Chlorination		
<b>System Name:</b>	Camp Myrtlewood	<b>ID#: 41</b>	90861	<b>Month/Year:</b>	10/24	<b>Disinfection <i>Giardia</i> Log Inactiv:</b>	1.0		

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	1.06	43	45.6	14.6	8.30	45.5	YES	0.04
2	0.96	43	41.3	13.7	8.56	8.4	YES	0.07
3	1.1	43	47.3	13.3	8.08	46.0	YES	0.17
4	1.11	43	47.7	15.5	8.20	41.6	YES	0.08
5	1.09	43	46.9	14.9	8.39	46.3	YES	0.08
6	1.03	43	44.3	16.2	8.41	42.5	YES	0.14
7	1.1	43	47.3	16.8	8.43	41.5	YES	0.14
8	1.2	43	51.6	15.9	8.39	43.9	YES	0.31
9	1.3	43	55.9	17.8	8.33	38.3	YES	0.17
10	1.1	43	47.3	15.8	8.38	43.5	YES	0.17
11	1.2	43	51.6	14.6	8.49	47.3	YES	0.09
12	0.94	43	40.4	17.9	8.25	35.6	YES	0.22
13	1	43	43.0	19.4	8.36	32.6	YES	0.17
14	1	43	43.0	18.7	8.26	34.8	YES	0.2
15	1.3	43	55.9	15.6	8.28	43.5	YES	0.1
16	1.13	43	48.6	15.2	8.33	44.6	YES	0.35
17	0.99	43	42.6	16.8	8.41	40.7	YES	0.19
18	1.1	43	47.3	15.1	8.32	44.6	YES	0.16
19	1.12	43	48.2	14.9	8.34	45.6	YES	0.23
20	1.2	43	51.6	14.2	8.24	46.5	YES	0.07
21	1.4	43	60.2	14.0	8.32	49.6	YES	0.14
22	1.34	43	57.6	14.2	8.31	48.4	YES	0.17
23	1.21	43	52.0	14.6	8.40	48.0	YES	0.08
24	1.2	43	51.6	14.0	8.44	50.7	YES	0.12
25	1.1	43	47.3	15.1	8.33	44.7	YES	0.33
26	1.1	43	47.3	14.6	8.39	47.3	YES	0.19
27	1.1	43	47.3	14.6	8.21	44.2	YES	0.09
28	1.1	43	47.3	13.9	8.25	47.0	YES	0.09
29	1.2	43	51.6	13.8	8.44	51.3	YES	0.11
30	1.1	43	47.3	14.2	8.31	47.1	YES	0.19
31	1.2	43	51.6	14.0	8.39	45.8	YES	0.12

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350