

OHA - Drinking Water Services - Surface Water Quality Data Form							County:	COOS
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems							Month/Year:	2/25
System Name:	Camp Myrtlewood			ID#: 41	90861		WTP : TP -	SSF/Chlorination
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1			0.37				0.37	
2			0.45				0.45	
3			0.33				0.33	
4			0.30				0.30	
5			0.33				0.33	
6			0.95				0.95	
7			0.97				0.97	
8			0.92				0.92	
9			0.59				0.59	
10			0.65				0.65	
11			0.39				0.39	
12			0.56				0.56	
13			0.53				0.53	
14			0.79				0.79	
15			0.71				0.71	
16			0.62				0.62	
17			0.67				0.67	
18			0.64				0.64	
19			0.64				0.64	
20			0.69				0.69	
21			0.68				0.68	
22			0.77				0.77	
23			0.95				0.95	
24			0.96				0.96	
25			0.92				0.92	
26			0.99				0.99	
27			0.63				0.63	
28			0.51				0.51	
29								
30								
31								
Slow Sand/Membrane/DE Filtration/Unfiltered				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings ≤ 1 NTU? ²				Yes	CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU?				Yes	Yes		Yes	
Notes:				PRINTED NAME: Shauna Danielson SIGNATURE: Shauna Danielson 2/28/2025 PHONE #: (541)572.5307 CERT #: N/A				
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.								
PAGE 1 of 2								
OHA - Drinking Water Services - Surface Water Quality Data Form							WTP- :	SSF/Chlorination
System Name:	Camp Myrtlewood	ID#: 41	90861	Month/Year:	2/25	Disinfection <i>Giardia</i> Log Inactiv:	1.0	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.67	43	71.8	14.6	8.29	48.6	YES	0.347
2	1.62	43	69.7	10.8	8.46	66.0	YES	0.194
3	1.72	43	74.0	10.0	8.46	70.6	YES	0.257
4	1.58	43	67.9	11.0	8.45	64.6	YES	0.291
5	1.59	43	68.4	11.3	8.44	63.1	YES	0.257
6	1.36	43	58.5	12.5	8.35	55.1	YES	0.340
7	1.29	43	55.5	12.3	8.33	54.8	YES	0.292
8	1.27	43	54.6	12.0	8.24	54.0	YES	0.069
9	1.35	43	58.1	12.3	8.46	57.8	YES	0.085
10	1.79	43	77.0	13.2	8.45	57.3	YES	0.055
11	1.28	43	55.0	13.8	8.43	48.0	YES	0.069
12	1.47	43	63.2	12.3	8.26	53.0	YES	0.021
13	1.37	43	58.9	11.9	8.23	56.2	YES	0.042
14	1.67	43	71.8	12.0	8.18	62.1	YES	0.076
15	1.63	43	70.1	11.7	8.30	58.7	YES	0.028
16	1.51	43	64.9	11.3	8.50	63.9	YES	0.028
17	1.4	43	60.2	13.1	8.44	55.0	YES	0.035
18	1.31	43	56.3	13.0	8.43	54.6	YES	0.094
19	1.31	43	56.3	13.6	8.38	51.5	YES	0.049
20	1.29	43	55.5	13.6	8.39	51.6	YES	0.118
21	1.48	43	63.6	13.9	8.35	50.9	YES	0.021
22	1.58	43	67.9	14.5	8.19	46.7	YES	0.021
23	1.48	43	63.6	14.7	8.24	46.4	YES	0.021
24	1.36	43	58.5	16.7	8.39	42.4	YES	0.17
25	1.29	43	55.5	14.6	8.37	47.9	YES	0.028
26	1.25	43	53.8	13.1	8.32	51.7	YES	0.118
27	1.25	43	53.8	13.2	8.17	48.6	YES	0.035
28	1.36	43	58.5	13.9	8.23	48.1	YES	0.094
29								
30								
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350