

OHA - Drinking Water Services - Surface Water Quality Data Form							County:	COOS	
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems							Month/Year:	5/25	
System Name:	Camp Myrtlewood			ID#: 41	90861		WTP : TP -	SSF/Chlorination	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]		
1			0.32				0.32		
2			0.29				0.29		
3			0.28				0.28		
4			0.26				0.26		
5			0.28				0.28		
6			0.32				0.32		
7			0.28				0.28		
8			0.28				0.28		
9			0.43				0.43		
10			0.43				0.43		
11			0.36				0.36		
12			0.37				0.37		
13			0.31				0.31		
14			0.27				0.27		
15			0.29				0.29		
16			0.26				0.26		
17			0.26				0.26		
18			0.22				0.22		
19			0.23				0.23		
20			0.25				0.25		
21			0.21				0.21		
22			0.21				0.21		
23			0.21				0.21		
24			0.23				0.23		
25			0.20				0.20		
26			0.19				0.19		
27			0.19				0.19		
28			OFF				OFF		
29			OFF				OFF		
30			OFF				OFF		
31			OFF				OFF		
Slow Sand/Membrane/DE Filtration/Unfiltered					Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings ≤ 1 NTU? ²				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?				Yes	Yes		Yes		
Notes:					PRINTED NAME: Shauna Danielson				
					SIGNATURE: Shauna Danielson			6/8/2025	
					PHONE #: (541)572.5307			CERT #: N/A	
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.									
PAGE 1 of 2									
OHA - Drinking Water Services - Surface Water Quality Data Form					WTP- :		SSF/Chlorination		
System Name:	Camp Myrtlewood	ID#: 41	90861	Month/Year:	5/25	Disinfection <i>Giardia</i> Log Inactiv:		1.0	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.51	43	64.9	17.6	8.38	40.4	YES	0.159
2	1.5	43	64.5	15.8	8.46	46.9	YES	0.146
3	1.41	43	60.6	14.6	8.42	49.5	YES	0.097
4	1.33	43	57.2	1.3	8.27	45.1	YES	0.139
5	1.21	43	52.0	19.4	8.30	33.7	YES	0.056
6	1.22	43	52.5	17.7	8.28	37.5	YES	0.104
7	1.33	43	57.2	17.3	8.37	40.3	YES	0.076
8	1.16	43	49.9	18.7	8.32	35.3	YES	0.076
9	1.36	43	58.5	16.1	8.42	44.6	YES	0.076
10	1.44	43	61.9	17.2	8.39	41.4	YES	0.076
11	1.41	43	60.6	16.4	8.31	42.8	YES	0
12	1.4	43	60.2	14.3	8.24	48.4	YES	0.013
13	1.39	43	59.8	15.2	8.35	47.3	YES	0.069
14	1.25	43	53.8	15.6	8.31	44.2	YES	0.125
15	1.29	43	55.5	16.0	8.41	44.3	YES	0.139
16	1.34	43	57.6	18.2	8.34	37.6	YES	0.083
17	1.22	43	52.5	15.5	8.35	44.5	YES	0.076
18	1.3	43	55.9	16.1	8.38	43.6	YES	0.056
19	1.22	43	52.5	15.6	8.43	45.5	YES	0.083
20	1.11	43	47.7	15.8	8.42	44.2	YES	0.083
21	1.19	43	51.2	17.8	8.27	37.0	YES	0.076
22	1.22	43	52.5	16.4	8.42	43.0	YES	0.076
23	1.33	43	57.2	17.0	8.27	39.6	YES	0.076
24	1.3	43	55.9	17.2	8.33	39.8	YES	0.056
25	1.31	43	56.3	18.2	8.32	37.2	YES	0.076
26	1.24	43	53.3	18.0	8.44	39.1	YES	0.056
27	1.22	43	52.5	18.1	8.36	37.6	YES	0.091
OFF								
OFF								
OFF								
OFF								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.
 Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2