

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Tillamook

Cartridge or Bag Filtration

Month/Year: June 2021

System Name: Kelly's Brighton Marina ID# 41 90922

WTP ID: B

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	18	6	12	15		.61
2	18	6	12			.59
3	18	6	12			.59
4	12	8	4			.58
5	12	8	4			.60
6	12	8	4			.61
7	12	6	6			.59
8	12	6	6			.62
9	12	8	4			.60
10	12	8	4			.60
11	14	8	6			.59
12	14	6	8			.58
13	14	6	8			.56
14	14	8	6			.56
15	14	8	6			.57
16	14	8	6			.58
17	14	6	8			.59
18	16	8	8			.61
19	16	8	8			.61
20	16	10	6			.60
21	16	10	6			.64
22	16	8	8			.64
23	16	8	8			.63
24	16	10	6			.65
25	16	10	6			.62
26	16	12	4			.63
27	16	8	8			.64
28	16	6	10			.64
29	16	6	10			.60
30	16	6	10			.58
31						

<b>Cartridge Filtration Monthly Summary</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. <u>9716730694</u>		PRINTED NAME: <u>KELLY LAVIDETTE</u> SIGNATURE: <u>[Signature]</u> DATE: <u>7/9/21</u> PHONE #: <u>(503) 368-5745</u> CERT #:	

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.



OHA - Drinking Water Services - Surface Water Quality Data Form

Tillamook Month/Year: June 2021

System Name: Kelly's Brighton marina

ID# 41 90922

WTP - B

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>2</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1/	2.4						Yes	1420
2/	2.4							1160
3/	2.4							980
4/	2.0							1140
5/	2.0							1360
6/	2.0							1270
7/	1.8							1240
8/	1.8							1310
9/	1.4							1090
10/	1.4							970
11/	1.4							1240
12/	1.4							1370
13/	2.0							1410
14/	2.0							870
15/	1.6							770
16/	1.4							830
17/	1.4							890
18/	1.4							880
19/	2.8							1680
20/	2.4							1270
21/	2.4							1190
22/	2.0							1040
23/	1.8							1350
24/	1.8							1340
25/	1.8							1510
26/	1.6							1620
27/	1.6							1700
28/	1.4							1290
29/	1.4							1110
30/	1.8							1270
31/								

per Kari Sallis

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised August 2016  
 Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf)

Return by 10<sup>th</sup> of following month by email, fax or mail to:  
 dwp.dmce@state.or.us; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350