

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Cartridge or Bag Filtration

County: Tillamook

Month/Year: 3/22

System Name: Kelly's Brighton Marina ID# 41 90922 WTP ID: B

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	20	12	8			.62
2	20	12	8	15		.61
3	20	12	8			.62
4	20	12	8			.61
5	20	12	8			.62
6	20	12	8			.61
7	20	12	8			.64
8	20	12	8			.62
9	20	12	8			.61
10	20	12	8			.60
11	20	12	8			.60
12	20	12	8			.59
13	20	12	8			.63
14	20	12	8			.64
15	20	12	8			.61
16	20	12	8			.63
17	20	12	8			.62
18	20	12	8			.61
19	20	12	8			.63
20	20	12	8			.61
21	20	12	8			.61
22	20	12	8			.63
23	20	12	8			.62
24	20	12	8			.62
25	20	12	8			.63
26	20	12	8			.62
27	20	12	8			.61
28	20	12	8			.60
29	20	12	8			.59
30	20	12	8			.61
31	20	12	8			.61

Cartridge Filtration Monthly Summary

95% of daily turbidity readings ≤ 1 NTU? Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. 9716730694

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

PRINTED NAME: Colin Davis

SIGNATURE: Colin Davis DATE: 3/31/22

PHONE #: (503) 368-5745 CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

Tillamook Month/Year: 3/22

System Name: Kelly's Brighton marina

ID# 41 90922

WTP - B

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1/	1.2						YES	180
2/	1.2							260
3/	1.2							300
4/	1.2							340
5/	1.4							740
6/	1.4							540
7/	1.4							300
8/	1.4							300
9/	1.4							300
10/	1.4							150
11/	1.4							410
12/	1.4							450
13/	1.4							320
14/	1.4							320
15/	1.4							320
16/	1.4							320
17/	1.4							660
18/	1.4							390
19/	1.4							500
20/	1.4							930
21/	1.4							490
22/	1.4							980
23/	1.4							570
24/	2.0							630
25/	2.0							840
26/	2.0							380
27/	2.0							420
28/	2.0							220
29/	2.0							180
30/	2.0							240
31/	2.0							220

For Kelly's Brighton marina

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours.

Revised August 2016

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Return by 10th of following month by email, fax or mail to:
dwp.dmce@state.or.us; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350