


OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Cartridge or Bag Filtration

County: Tillamook

Month/Year: 11/22

System Name: Kelly's Brighton Marina ID# 41 90922 WTP ID: B

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	12	10	2			
2	12	10	2	15		.62
3	12	10	2			.62
4	12	10	2			.62
5	12	10	2			.63
6	12	10	2			.63
7	12	10	2			.61
8	12	10	2			.61
9	12	10	2			.62
10	12	10	2			.61
11	12	10	2			.62
12	12	10	2			.62
13	12	10	2			.61
14	12	10	2			.60
15	12	10	2			.61
16	12	10	2			.61
17	12	10	2			.60
18	12	10	2			.61
19	12	10	2			.62
20	12	10	2			.61
21	12	10	2			.62
22	12	10	2			.62
23	12	10	2			.63
24	12	10	2			.63
25	12	10	2			.62
26	12	10	2			.61
27	12	10	2			.60
28	12	10	2			.60
29	12	10	2			.61
30	12	10	2			.63
31						.63

Cartridge Filtration Monthly Summary		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. <u>9716730694</u>		PRINTED NAME: <u>Bryan Yelle</u>	DATE: <u>12/3/22</u>
		SIGNATURE: 	CERT #:
		PHONE #: <u>(503) 368-5745</u>	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: Kelly's Brighton marina ID# 41 90922 Tilla W Month/Year: 11/22 WTP - B

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH	Required CT Use tables	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1/	1.4							
2/	2.2							280
3/	1.8							340
4/	1.2							1010
5/	1.2							980
6/	2.4							750
7/	2.4							1100
8/	2.2							740
9/	2.2							1330
10/	1.4							350
11/	2.4							430
12/	2.4							2180
13/	2.8							2820
14/	2.6							1790
15/	2.6							1240
16/	2.6							200
17/	2.2							340
18/	2.8							440
19/	2.6							240
20/	2.2							1230
21/	2.6							1320
22/	2.6							260
23/	2.6							210
24/	1.8							1640
25/	1.6							370
26/	1.4							1540
27/	2.0							1570
28/	2.0							1280
29/	1.6							250
30/	1.3							400
31/								280

Handwritten note:
New
Low
Sales

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised August 2016
Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Return by 10th of following month by email, fax or mail to:
dwp.dnce@state.or.us; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350