

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Cartridge or Bag Filtration

County: Tillamook
 Month/Year: Feb 23

System Name: Kelly's Brighton Marina ID# 41 90922 WTP ID: B

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	12	10	2			.81
2	12	10	2	15		.82
3	12	10	2			.81
4	12	10	2			.80
5	12	10	2			.82
6	12	10	2			.81
7	12	10	2			.82
8	12	10	2			.81
9	12	10	2			.82
10	12	10	2			.80
11	12	10	2			.80
12	12	10	2			.80
13	12	10	2			.81
14	12	10	2			.82
15	12	10	2			.81
16	12	10	2			.82
17	12	10	2			.82
18	12	10	2			.81
19	12	10	2			.80
20	12	10	2			.80
21	12	10	2			.81
22	12	10	2			.80
23	12	10	2			.80
24	12	10	2			.81
25	12	10	2			.82
26	12	10	2			.82
27	12	10	2			.82
28	12	10	2			.82
29						.82
30						
31						

Cartridge Filtration Monthly Summary		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	Yes/No Yes/No	CT's met everyday? (see back) Yes/No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes/No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. <u>9716730694</u>		PRINTED NAME: <u>Brian Yelle</u>	DATE: <u>3-3-23</u>
		SIGNATURE: <u>[Signature]</u>	CERT #:
		PHONE #: <u>(503) 368-5745</u>	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.
 PAGE 1 of 2

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: Kelly's Brighton marina ID# 41 90922 Tillamook Month/Year: Feb 23 WTP - B

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [° C]	pH	Required CT Use tables	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1/	1.8							
2/	2.0							80
3/	2.6							440
4/	2.6							730
5/	2.6							940
6/	2.2							340
7/	1.8							220
8/	1.6							180
9/	1.6							280
10/	1.6							320
11/	2.2							1050
12/	2.2							1490
13/	2.4							680
14/	2.6							350
15/	2.6							280
16/	2.8							210
17/	2.4							310
18/	2.0							1000
19/	1.8							930
20/	1.6							1330
21/	2.0							1190
22/	1.8							1080
23/	2.0							1260
24/	2.2							1180
25/	2.2							1230
26/	2.0							2600
27/	2.0							390
28/	1.8							410
29/								290
30/								
31/								

few rain glasses

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised August 2016
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Return by 10th of following month by email, fax or mail to:
dwp.dmce@state.or.us; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350