

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Cartridge or Bag Filtration

County: Tillamook

Month/Year: MAY '23

System Name: Kelly's Brighton Marina ID# 41 90922

WTP ID: B

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	12	10	2			
2	12	10	2	15		.80
3	12	10	2			.81
4	12	10	2			.80
5	12	10	2			.80
6	12	10	2			.80
7	12	10	2			.81
8	12	10	2			.81
9	12	10	2			.82
10	12	10	2			.81
11	12	10	2			.82
12	12	10	2			.82
13	12	10	2			.81
14	12	10	2			.81
15	12	10	2			.81
16	12	10	2			.81
17	12	10	2			.80
18	12	10	2			.80
19	12	10	2			.80
20	12	10	2			.80
21	12	10	2			.80
22	12	10	2			.80
23	12	10	2			.81
24	12	10	2			.80
25	12	10	2			.80
26	12	10	2			.80
27	12	10	2			.81
28	12	10	2			.81
29	12	10	2			.81
30	12	10	2			.80
31	12	10	2			.80

Cartridge Filtration Monthly Summary

95% of daily turbidity readings ≤ 1 NTU? Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. 9716730694

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

PRINTED NAME: BRIAN YELLE
 SIGNATURE: [Signature] DATE: 6-7-23
 PHONE #: (503) 368-5745 CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

Tillamook Month/Year: MAY '23

System Name: Kelly's Brighton marina

ID# 41 90922

WTP - B

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1/	1.6							
2/	1.8							480
3/	1.6							520
4/	1.4							560
5/	1.4							680
6/	1.4							840
7/	1.4							880
8/	1.4							950
9/	1.4							960
10/	1.6							940
11/	1.6							960
12/	1.6							860
13/	1.6							820
14/	1.6							2120
15/	1.6							1830
16/	1.4							1080
17/	1.4							1160
18/	1.4							930
19/	1.4							1120
20/	1.6							1210
21/	1.6							1590
22/	1.6							2260
23/	1.6							2170
24/	1.6							1200
25/	1.6							920
26/	1.6							1260
27/	1.8							3410
28/	1.6							3520
29/	1.6							2940
30/	1.6							1000
31/	1.6							980
								1100

REV
Karin
Solias

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours.

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Revised August 2016

Return by 10th of following month by email, fax or mail to:

dwp.dmce@state.or.us; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350