

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Cartridge or Bag Filtration

County: Tillamook
 Month/Year: FEB/24

System Name: Kelly's Brighton Marina ID# 41 90922 WTP ID: B

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	12	10	2			
2	12	10	2	15		
3	12	10	2			.80
4	12	10	2			.80
5	12	10	2			.81
6	12	10	2			.81
7	12	10	2			.82
8	12	10	2			.81
9	12	10	2			.81
10	22	12	10			.80
11	22	12	10			.96
12	22	12	10			.96
13	22	12	10			.99
14	22	12	10			.98
15	22	12	10			.96
16	22	12	10			.97
17	22	12	10			.98
18	22	12	10			.99
19	22	12	10			.96
20	22	12	10			.96
21	22	12	10			.96
22	22	12	10			.97
23	22	12	10			.97
24	22	12	10			.98
25	22	12	10			.98
26	22	12	10			.98
27	22	12	10			.99
28	22	12	10			.99
29	22	12	10			.98
30						.99
31						

Cartridge Filtration Monthly Summary

95% of daily turbidity readings ≤ 1 NTU? Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. 9716730694

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

PRINTED NAME: BRIAN VELLE
 SIGNATURE: [Signature] DATE: 3/2/24
 PHONE #: (503) 368-5745 CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: Kelly's Brighton Marina ID# 41 90922 Month/Year: Tillamook FEB/24 WTP - B

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? ² (Yes / No)	Peak Hourly Demand Flow [GPM]
1/	2.4							220
2/	2.4							760
3/	2.2							570
4/	2.2							580
5/	2.2							420
6/	2.2							420
7/	2.2							330
8/	2.4							380
9/	2.4							280
10/	2.2							730
11/	2.2							420
12/	2.2							320
13/	2.4							290
14/	2.4							220
15/	2.5							280
16/	2.5							240
17/	2.6							820
18/	2.6							570
19/	2.6							560
20/	2.5							370
21/	2.5							570
22/	2.6							420
23/	2.6							420
24/	2.6							240
25/	2.6							160
26/	2.6							220
27/	3.1							240
28/	3.1							180
29/	3.0							220
30/								
31/								

Per Kim Sells

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised August 2016
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Return by 10th of following month by email, fax or mail to:
dwp.dmce@state.or.us; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350