

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Cartridge or Bag Filtration

County: Tillamook
 Month/Year: MARCH/24

System Name: Kelly's Brighton Marina ID# 41 90922 WTP ID: B

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	22	10	12			
2	22	10	12	15		.98
3	16	12	4			.97
4	16	12	4			.94
5	16	12	4			.94
6	16	12	4			.92
7	16	12	4			.90
8	16	12	4			.91
9	16	12	4			.91
10	16	12	4			.94
11	16	12	4			.92
12	16	12	4			.92
13	16	12	4			.91
14	16	12	4			.91
15	16	14	2			.90
16	16	14	2			.90
17	16	14	2			.94
18	16	14	2			.96
19	16	14	2			.96
20	16	14	2			.97
21	16	14	2			.98
22	16	14	2			.98
23	16	14	2			.97
24	16	14	2			.96
25	16	14	2			.98
26	16	14	2			.97
27	16	14	2			.97
28	16	14	2			.96
29	16	14	2			.95
30	16	14	2			.94
31	16	14	2			.94

Cartridge Filtration Monthly Summary

95% of daily turbidity readings ≤ 1 NTU? Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch, difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. 9716730694

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

PRINTED NAME: Brian Yelle
 SIGNATURE: [Signature] DATE: 4/6/24
 PHONE #: (503) 368-5745 CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

Tillamook Month/Year: MARCH/24

System Name: Kelly's Brighton Marina		ID# 41 90922		WTP - B				
Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes/No	[GPM]
1/	2.6							360
2/	2.6							560
3/	2.4							320
4/	2.4							740
5/	2.4							470
6/	2.4							280
7/	2.4							130
8/	2.6							720
9/	2.5							220
10/	2.4							220
11/	2.4							410
12/	2.5							460
13/	2.4							180
14/	2.4							260
15/	2.4							430
16/	2.4							580
17/	2.5							380
18/	2.5							330
19/	2.5							660
20/	2.5							280
21/	2.5							210
22/	2.5							1050
23/	2.5							760
24/	2.5							650
25/	2.5							660
26/	2.3							550
27/	2.4							540
28/	2.4							1570
29/	2.4							2240
30/	2.4							1800
31/	2.6							1350

few
hard
to
do

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised August 2016
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Return by 10th of following month by email, fax or mail to:
dwp.dmce@state.or.us; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350