


OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Cartridge or Bag Filtration

County: Tillamook
 Month/Year: 06/24

System Name: Kelly's Brighton Marina ID# 41 90922 WTP ID: B

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	12	10	2			
2	12	10	2	15		.97
3	12	10	2			.97
4	12	10	2			.97
5	12	10	2			.99
6	12	10	2			.98
7	12	10	2			.98
8	12	10	2			.97
9	12	10	2			.96
10	12	10	2			.97
11	12	10	2			.98
12	12	10	2			.99
13	12	10	2			.97
14	12	10	2			.97
15	12	10	2			.96
16	12	10	2			.98
17	12	10	2			.97
18	12	10	2			.97
19	12	10	2			.97
20	12	10	2			.98
21	12	10	2			.98
22	12	10	2			.98
23	12	10	2			.97
24	12	10	2			.96
25	12	10	2			.96
26	12	10	2			.97
27	12	10	2			.97
28	12	10	2			.98
29	12	10	2			.98
30	12	10	2			.97
31						.97

Cartridge Filtration Monthly Summary		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No
All daily turbidity readings ≤ 5 NTU?	Yes / No		
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. <u>9716730694</u>		PRINTED NAME: <u>BRIAN YELLE</u>	DATE: <u>7/7/24</u>
		SIGNATURE: 	CERT #:
		PHONE #: <u>(503) 368-5745</u>	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

Tillamook Month/Year: 06/24

System Name: Kelly's Brighton Marina ID# 41 90922 WTP - B								
Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/	1.4							3260
2/	1.4							690
3/	1.4							1960
4/	1.6							2120
5/	1.6							3500
6/	1.6							1940
7/	1.4							2200
8/	1.4							2140
9/	1.4							820
10/	1.4							730
11/	1.4							750
12/	1.4							640
13/	1.2							1260
14/	1.2							790
15/	1.2							1920
16/	1.4							1870
17/	1.4							1190
18/	1.7							550
19/	2.0							830
20/	2.0							940
21/	2.2							1200
22/	2.2							2930
23/	2.2							2400
24/	2.4							2680
25/	2.6							1110
26/	2.8							800
27/	2.6							390
28/	2.6							2010
29/	2.4							2460
30/	2.2							1220
31/								

Ren
Koro
Sales

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised August 2016
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Return by 10th of following month by email, fax or mail to:
dwp.dmce@state.or.us; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350