

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Cartridge or Bag Filtration

County: Tillamook
 Month/Year: DEC 24

System Name: Kelly's Brighton Marina ID# 41 90922 WTP ID: B

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	10	8	2			
2	10	8	2			
3	10	8	2	15		.98
4	10	8	2			.98
5	10	8	2			.98
6	10	8	2			.98
7	10	8	2			.97
8	10	8	2			.97
9	10	8	2			.96
10	10	8	2			.96
11	10	8	2			.97
12	10	8	2			.97
13	10	8	2			.97
14	10	8	2			.97
15	10	8	2			.98
16	10	8	2			.98
17	10	8	2			.98
18	10	8	2			.98
19	10	8	2			.98
20	10	8	2			.98
21	10	8	2			.98
22	10	8	2			.97
23	10	8	2			.98
24	10	8	2			.98
25	10	8	2			.97
26	10	8	2			.97
27	10	8	2			.98
28	10	8	2			.98
29	10	8	2			.98
30	10	8	2			.98
31	10	8	2			.98

Cartridge Filtration Monthly Summary

95% of daily turbidity readings ≤ 1 NTU? Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. 9716730694

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

PRINTED NAME: Bryan Yelle
 SIGNATURE: [Signature] DATE: 1/2/25
 PHONE #: (503) 368-5745 CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services -- Surface Water Quality Data Form

System Name: Kelly's Brighton Marina ID# 41 90922 Tillamook Month/Year: DEC 20
 WTP - B

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH	Required CT Use tables	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1/	3.2							
2/	3.2							
3/	3.2							1020
4/	3.2							900
5/	2.8							480
6/	2.8							530
7/	2.8							340
8/	2.8							340
9/	2.7							350
10/	2.5							540
11/	2.5							300
12/	2.2							150
13/	1.8							290
14/	1.4							170
15/	1.2							290
16/	1.2							280
17/	1.1							690
18/	1.1							350
19/	1.2							240
20/	1.2							220
21/	1.2							210
22/	1.2							410
23/	1.2							400
24/	1.2							430
25/	1.2							930
26/	1.2							100
27/	1.2							440
28/	1.2							280
29/	1.2							150
30/	1.2							400
31/	1.2							430
								460
								390

Poor water quality

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours.
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf Revised August 2016

Return by 10th of following month by email, fax or mail to:
 dwp.dmce@state.or.us; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350