

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Cartridge or Bag Filtration

County: Tillamook
 Month/Year: JAN 25

System Name: Kelly's Brighton Marina ID# 41 90922 WTP ID: B

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	10	8	2			
2	10	8	2	15		.97
3	10	8	2			.97
4	10	8	2			.96
5	10	8	2			.98
6	10	8	2			.94
7	10	8	2			.98
8	10	8	2			.98
9	10	8	2			.98
10	10	8	2			.97
11	10	8	2			.97
12	10	8	2			.96
13	10	8	2			.96
14	10	8	2			.97
15	10	8	2			.97
16	10	8	2			.96
17	10	8	2			.96
18	10	8	2			.96
19	10	8	2			.96
20	10	8	2			.96
21	10	8	2			.96
22	10	8	2			.97
23	10	8	2			.96
24	10	8	2			.96
25	10	8	2			.96
26	10	8	2			.96
27	10	8	2			.96
28	10	8	2			.96
29	10	8	2			.97
30	10	8	2			.96
31	10	8	2			.96

Cartridge Filtration Monthly Summary

95% of daily turbidity readings ≤ 1 NTU? Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. 9716730694

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

PRINTED NAME: BRIAN YELLE
 SIGNATURE: [Signature] DATE: 2/2/25
 PHONE #: (503) 368-5745 CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: Kelly's Brighton Marina ID# 41 90922 Tillamook Month/Year: JAN 20
 WTP - B

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH	Required CT Use tables	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1/	1.2							
2/	1.3							390
3/	1.4							350
4/	1.3							190
5/	1.5							390
6/	1.5							400
7/	1.4							360
8/	1.5							130
9/	2.1							300
10/	2.0							690
11/	2.0							690
12/	2.1							670
13/	2.0							510
14/	1.9							250
15/	2.0							240
16/	2.3							260
17/	2.7							280
18/	2.7							390
19/	2.8							1020
20/	2.9							560
21/	2.9							1610
22/	2.6							360
23/	2.7							160
24/	2.7							230
25/	2.8							700
26/	2.6							650
27/	2.5							590
28/	2.4							440
29/	2.3							420
30/	2.3							430
31/	2.3							430
								520

Handwritten note: New Meter Sales

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised August 2016
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Return by 10th of following month by email, fax or mail to:
dwp.dmce@state.or.us; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350