

OHA - Drinking Water Services - Turbidity Monitoring Report Form

Cartridge or Bag Filtration

County: Tillamook
 Month/Year: JUNE 25

System Name: Kelly's Brighton Marina ID# 41 90922 WTP ID: B

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	10	8	2			
2	10	8	2	15		.96
3	10	8	2			.97
4	10	8	2			.97
5	10	8	2			.97
6	10	8	2			.96
7	10	8	2			.96
8	10	8	2			.96
9	10	8	2			.96
10	10	8	2			.96
11	10	8	2			.97
12	10	8	2			.96
13	10	8	2			.97
14	10	8	2			.96
15	10	8	2			.96
16	10	8	2			.97
17	10	8	2			.97
18	10	8	2			.97
19	10	8	2			.98
20	10	8	2			.98
21	10	8	2			.98
22	10	8	2			.98
23	10	8	2			.98
24	10	8	2			.98
25	10	8	2			.97
26	10	8	2			.98
27	10	8	2			.97
28	10	8	2			.97
29	10	8	2			.96
30	10	8	2			.97
31						.98

Cartridge Filtration Monthly Summary

95% of daily turbidity readings ≤ 1 NTU? Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. 9716730694

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

PRINTED NAME: BRIAN VELLE

SIGNATURE: [Signature] DATE: 7/7/25

PHONE #: (503) 368-5745 CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: Kelly's Brighton Marina ID# 41 90922 Month/Year: Tillamook JUNE 20
WTP - B

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? ² <u>Yes</u> / No	Peak Hourly Demand Flow [GPM]
1/	1.9							
2/	1.8							720
3/	1.6							450
4/	1.8							730
5/	1.7							640
6/	1.8							1200
7/	1.9							2360
8/	2.0							3020
9/	2.0							1300
10/	2.0							1560
11/	2.0							850
12/	2.1							430
13/	2.1							2000
14/	2.2							1030
15/	2.3							1400
16/	2.3							2220
17/	2.4							1540
18/	2.3							910
19/	1.7							530
20/	1.6							900
21/	1.6							2060
22/	1.6							1130
23/	1.7							2330
24/	2.4							830
25/	2.4							1240
26/	2.5							1000
27/	2.5							860
28/	2.5							1170
29/	2.6							1160
30/	2.7							2610
31/								1340

Handwritten note: New Kew Salas

² If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWS within 24 hours.

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf Revised August 2016

Return by 10th of following month by email, fax or mail to:
dwp.dmce@state.or.us; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.