OHA - Drinking Water Services – Turbidity Monitoring Report Form
Cartridge or Bag Filtration

System Name: Kelly's Brighton Marina ID# 41 90922 County: Tillamook

Month/Year: MAR 26 WTP ID: B

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day [1] [NTU]
1	13	10	3	15		.96
2	13	10	3			.96
3	13	10	3			.97
4	13	10	3			.98
5	13	10	3			.98
6	13	10	3			.98
7	13	10	3			.98
8	13	10	3			.98
9	13	10	3			.97
10	13	10	3			.97
11	13	10	3			.97
12	13	10	3			.97
13	13	10	3			.98
14	13	10	3			.98
15	13	10	3			.98
16	13	10	3			.96
17	13	10	3			.96
18	13	10	3			.96
19	13	10	3			.96
20	13	10	3			.97
21	13	10	3			.97
22	13	10	3			.97
23	13	10	3			.96
24	13	10	3			.96
25	13	10	3			.96
26	13	10	3			.97
27	13	10	3			.97
28	13	10	3			.97
29	13	10	3			.96
30	13	10	3			.96
31	13	10	3			.97

Cartridge Filtration Monthly Summary

95% of daily turbidity readings ≤ 1 NTU? Yes / No
All daily turbidity readings ≤ 5 NTU? Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No

All Cl_2 residual at entry point ≥ 0.2 mg/l? Yes / No

Notes: PSI = pounds per square inch
PSID = pounds per square inch, difference (before filter – after filter)
PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. 9716730694

PRINTED NAME: Brian Kelly

SIGNATURE: [signature]

DATE: 4/1/26

PHONE #: (503) 368-5745

CERT #:

[1] Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' max

OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: Kelly's Brighton marina Tillamook ID# 41 90922 Month/Year: MAR 24 WTP - B

Date / Time	Minimum Cl_2 Residual at 1st User (C)[2]	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?[2]	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/	2.6							650
2/	2.6							420
3/	2.6							250
4/	2.6							350
5/	2.6							670
6/	2.6							580
7/	2.6							710
8/	2.6							550
9/	2.7							380
10/	2.7							390
11/	2.7							250
12/	2.7							440
13/	2.7							1040
14/	2.7							720
15/	2.7							820
16/	2.6							220
17/	2.6							520
18/	2.6							360
19/	2.6							870
20/	2.6							700
21/	2.6							960
22/	2.6							1560
23/	2.5							970
24/	2.5							1050
25/	2.5							1090
26/	2.5							380
27/	2.4							1220
28/	2.4							1770
29/	2.4							710
30/	2.3							980
31/	2.3							620

Don Hard Sales

[2] If Cl_2 at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours.

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Revised August 2016

Return by 10th of following month by email, fax or mail to:
dwp.dmce@state.or.us; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350