


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook
 Month/Year: Jun-21

| System Name: OPRD Oswald West SP | | ID#: 41 91009 | | WTP : TP - A | | | |
|----------------------------------|-------------|---------------|------------|--------------|------------|------------|---|
| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the day ¹ [NTU] |
| 1 | | | 0.17 | | | | |
| 2 | | | 0.24 | | | | |
| 3 | | | 0.19 | | | | |
| 4 | | | 0.33 | | | | |
| 5 | | | 0.29 | | | | |
| 6 | | | 0.43 | | | | |
| 7 | | | | 0.32 | | | |
| 8 | | | | 0.40 | | | |
| 9 | | | 0.22 | | | | |
| 10 | | | 0.27 | | | | |
| 11 | | | 0.32 | | | | |
| 12 | | | | | 0.28 | | |
| 13 | | | | 0.27 | | | |
| 14 | | | | 0.20 | | | |
| 15 | | | 0.20 | | | | |
| 16 | | | 0.26 | | | | |
| 17 | | | 0.19 | | | | |
| 18 | | | 0.17 | | | | |
| 19 | | | 0.20 | | | | |
| 20 | | | 0.19 | | | | |
| 21 | | | | | 0.23 | | |
| 22 | | | | 0.21 | | | |
| 23 | | | 0.24 | | | | |
| 24 | | | 0.21 | | | | |
| 25 | | | 0.20 | | | | |
| 26 | | | | 0.17 | | | |
| 27 | | | | 0.26 | | | |
| 28 | | | 0.26 | | | | |
| 29 | | | 0.29 | | | | |
| 30 | | | 0.24 | | | | |
| 31 | | | | | | | |

| Slow Sand/Membrane/DE Filtration/Unfiltered | Monthly Summary (Answer Yes or No) | |
|---|------------------------------------|---|
| 95% of daily turbidity readings ≤ 1 NTU? ² | Yes | CT's met everyday? (see back) |
| All daily turbidity readings ≤ 5 NTU? | Yes | All Cl ₂ residual at entry point ≥ 0.2 mg/l? |
| | | Yes |

| | | |
|--------|---|-------------|
| Notes: | PRINTED NAME: Brian Dodge | |
| | SIGNATURE:  | 7/2/2021 |
| | PHONE #: (503) 801 4652 | CERT #: N/A |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A
 Disinfection *Giardia* Log Inactiv: 1.0

System Name: OPRD Oswald West SP ID#: 41 91009 Month/Year: 6/2021

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
|-------------|---|------------------|-----------|-------|------|-------------|----------------------|-------------------------|
| | [ppm or mg/L] | [minutes] | C X T | [° C] | 6.8 | formula | Yes / No | [GPM] |
| 1 | 2.7 | 24 | 64.9 | 11.4 | 6.80 | 39.7 | YES | 20 |
| 2 | 2.5 | 24 | 60.1 | 11.6 | 6.80 | 38.3 | YES | 20 |
| 3 | 2.6 | 24 | 62.5 | 11.4 | 6.80 | 39.3 | YES | 20 |
| 4 | 2.7 | 24 | 64.9 | 11.6 | 6.90 | 40.6 | YES | 20 |
| 5 | 2.6 | 24 | 62.5 | 11.6 | 6.90 | 40.1 | YES | 20 |
| 6 | 2.5 | 24 | 60.1 | 12.0 | 6.90 | 38.7 | YES | 20 |
| 7 | 3 | 24 | 72.1 | 12.1 | 6.80 | 39.2 | YES | 20 |
| 8 | 2.5 | 24 | 60.1 | 12.5 | 6.80 | 35.5 | YES | 20 |
| 9 | 2.5 | 24 | 60.1 | 12.2 | 6.80 | 36.9 | YES | 20 |
| 10 | 2.7 | 24 | 64.9 | 12.2 | 6.80 | 37.7 | YES | 20 |
| 11 | 2.9 | 24 | 69.7 | 12.6 | 6.80 | 36.9 | YES | 20 |
| 12 | 2.7 | 24 | 64.9 | 12.4 | 6.80 | 37.2 | YES | 20 |
| 13 | 2.5 | 24 | 60.1 | 13.0 | 6.80 | 34.3 | YES | 20 |
| 14 | 2.5 | 24 | 60.1 | 13.8 | 6.80 | 32.5 | YES | 20 |
| 15 | 2.8 | 24 | 67.3 | 12.4 | 6.80 | 37.6 | YES | 20 |
| 16 | 2.6 | 24 | 62.5 | 12.4 | 6.80 | 36.8 | YES | 20 |
| 17 | 2.8 | 24 | 67.3 | 13.0 | 6.80 | 35.5 | YES | 20 |
| 18 | 2.7 | 24 | 64.9 | 12.6 | 6.80 | 36.0 | YES | 20 |
| 19 | 3 | 24 | 72.1 | 12.4 | 6.80 | 38.5 | YES | 20 |
| 20 | 3.2 | 24 | 76.9 | 12.5 | 6.80 | 38.4 | YES | 20 |
| 21 | 2.8 | 24 | 67.3 | 14.0 | 6.80 | 33.2 | YES | 20 |
| 22 | 2.5 | 24 | 60.1 | 15.1 | 6.80 | 29.8 | YES | 20 |
| 23 | 2.6 | 24 | 62.5 | 15.4 | 6.80 | 29.6 | YES | 20 |
| 24 | 2.5 | 24 | 60.1 | 16.0 | 6.80 | 28.1 | YES | 20 |
| 25 | 2.7 | 24 | 64.9 | 14.8 | 6.80 | 31.1 | YES | 20 |
| 26 | 3 | 24 | 72.1 | 15.6 | 6.80 | 30.5 | YES | 20 |
| 27 | 2.8 | 24 | 67.3 | 15.4 | 6.80 | 30.2 | YES | 20 |
| 28 | 2.5 | 24 | 60.1 | 15.8 | 6.80 | 28.4 | YES | 20 |
| 29 | 2 | 24 | 48.1 | 17.0 | 6.80 | 24.8 | YES | 20 |
| 30 | 2.6 | 24 | 62.5 | 16.8 | 6.80 | 26.9 | YES | 20 |
| 31 | | | | | | | | 20 |

³ If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350