

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook
 Month/Year: Sep-21

System Name: OPRD Oswald West SP		ID#: 41 91009		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.24				
2			0.19				
3			0.22				
4					0.25		
5					0.23		
6			0.20				
7			0.25				
8			0.27				
9				0.22			
10				0.26			
11			0.33				
12			0.28				
13					0.26		
14					0.28		
15			0.17				
16				0.22			
17			0.27				
18				0.33			
19				0.34			
20					0.26		
21					0.24		
22				0.32			
23				0.26			
24			0.26				
25			0.22				
26				0.26			
27					0.39		
28					0.25		
29				0.29			
30			0.33				
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		
Notes:	PRINTED NAME: Brian Dodge	
	SIGNATURE: <i>Brian Dodge</i>	9.30.2021
	PHONE #: (503) 801 4652	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A
 Disinfection *Giardia* Log Inactiv: 1.0

System Name: OPRD Oswald West SP ID#: 41 91009 Month/Year: 9/2021

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.2	24	52.9	15.6	7.00	30.0	YES	20
2	2.4	24	57.7	15.6	6.90	29.6	YES	20
3	2.4	24	57.7	15.8	6.90	29.2	YES	20
4	2.3	24	55.3	16.2	6.90	28.1	YES	20
5	2	24	48.1	16.7	6.80	25.3	YES	20
6	2.2	24	52.9	16.5	6.90	27.2	YES	20
7	2.3	24	55.3	16.7	7.00	28.2	YES	20
8	2.4	24	57.7	16.6	6.90	27.7	YES	20
9	2.3	24	55.3	16.4	6.90	27.7	YES	20
10	2.1	24	50.5	16.4	6.90	27.1	YES	20
11	2	24	48.1	16.2	6.80	26.2	YES	20
12	2	24	48.1	16.2	6.80	26.2	YES	20
13	2	24	48.1	16.0	6.80	26.5	YES	20
14	2.2	24	52.9	15.6	6.80	27.9	YES	20
15	2.2	24	52.9	16.2	6.80	26.8	YES	20
16	2.1	24	50.5	16.4	6.90	27.1	YES	20
17	2	24	48.1	16.1	7.00	28.4	YES	20
18	2.2	24	52.9	15.8	6.90	28.5	YES	20
19	2	24	48.1	15.6	6.90	28.3	YES	20
20	2	24	48.1	15.0	6.80	28.3	YES	20
21	2	24	48.1	15.0	6.90	29.4	YES	20
22	2	24	48.1	15.1	6.80	28.2	YES	20
23	1.9	24	45.7	15.0	6.80	28.0	YES	20
24	2	24	48.1	15.2	6.80	28.0	YES	20
25	2.1	24	50.5	15.1	6.90	29.6	YES	20
26	2	24	48.1	14.8	6.80	28.7	YES	20
27	1.5	24	36.0	14.4	6.80	27.9	YES	20
28	1.5	24	36.0	13.6	6.80	29.4	YES	20
29	2	24	48.1	13.8	6.80	30.7	YES	20
30	1.5	24	36.0	13.6	6.80	29.4	YES	20
31								20

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350