

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook
 Month/Year: Nov-23

System Name: OPRD Oswald West SP ID#: 41 91009 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.75				
2					1.30		
3			0.18				
4				0.20			
5				0.52			
6					0.22		
7			0.21				
8			0.63				
9				0.45			
10				0.20			
11				0.22			
12			0.17				
13					0.40		
14			0.34				
15				0.16			
16			0.58				
17				0.30			
18			0.17				
19					0.19		
20					0.16		
21				0.35			
22			0.25				
23			0.22				
24					0.17		
25				0.19			
26			0.15				
27					0.13		
28				0.20			
29			0.14				
30			0.14				
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	Yes	Yes	Yes
		PRINTED NAME: Nathan Emmett	
		SIGNATURE: <i>Nathan Emmett</i>	12/9/2023
		PHONE #: (503) 910-3912	CERT #: N/A

