

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook
 Month/Year: Feb-24

System Name: OPRD Oswald West SP		ID#: 41	91009	WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.32				
2			0.14				
3				0.11			
4				0.17			
5			0.16				
6			0.16				
7				0.59			
8				0.19			
9				0.22			
10				0.08			
11				0.13			
12				0.25			
13				0.27			
14				0.48			
15				0.36			
16				0.50			
17			0.21				
18			0.25				
19			0.37				
20			0.30				
21				0.83			
22				0.54			
23				0.27			
24				0.22			
25				0.13			
26				0.14			
27				0.21			
28				0.19			
29				0.60			
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings \leq 1 NTU? ² Yes All daily turbidity readings \leq 5 NTU? Yes		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) Yes All Cl2 residual at entry point \geq 0.2 mg/l? Yes	
		PRINTED NAME: Nathan Emmett SIGNATURE: <i>Nathan Emmett</i> PHONE #: (503) 910-3912 CERT #: N/A	

