

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook
 Month/Year: Apr-24

System Name: OPRD Oswald West SP ID#: 41 91009 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1				0.13			
2				0.22			
3				0.20			
4				0.18			
5				0.16			
6				0.15			
7				0.16			
8				0.18			
9				0.14			
10				0.14			
11				0.22			
12				0.18			
13				0.14			
14				0.23			
15				0.18			
16				0.27			
17				0.19			
18				0.17			
19				0.09			
20				0.22			
21				0.14			
22				0.18			
23				0.18			
24				0.18			
25				0.14			
26				0.21			
27				0.12			
28				0.22			
29				0.18			
30				0.20			
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	Yes	Yes	Yes
		PRINTED NAME: Nathan Emmett	
		SIGNATURE: <i>Nathan Emmett</i>	
		PHONE #: (503) 910-3912	CERT #: N/A

