

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook  
 Month/Year: Jun-24

System Name: OPRD Oswald West SP ID#: 41 91009 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1				0.16			
2				0.17			
3				0.15			
4				0.21			
5				0.33			
6				0.29			
7				0.17			
8				0.13			
9				0.13			
10				0.20			
11				0.14			
12				0.15			
13				0.17			
14				0.13			
15				0.12			
16				0.13			
17				0.14			
18				0.16			
19				0.16			
20				0.17			
21				0.14			
22				0.11			
23				0.16			
24				0.16			
25				0.17			
26				0.19			
27				0.19			
28				0.17			
29				0.13			
30				0.18			
31							

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes
		PRINTED NAME: Nathan Emmett	
		SIGNATURE: <i>Nathan Emmett</i>	
		PHONE #: (503) 910-3912	CERT #: N/A

