

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**
 Month/Year: **Sep-24**

System Name: **OPRD Oswald West SP** ID#: **41 91009** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1				0.22			
2				0.20			
3				0.15			
4				0.18			
5				0.19			
6				0.16			
7				0.18			
8				0.15			
9				0.14			
10				0.08			
11				0.09			
12				0.17			
13				0.18			
14				0.20			
15				0.28			
16				0.22			
17				0.18			
18				0.17			
19				0.21			
20				0.15			
21				0.15			
22				0.15			
23				0.23			
24				0.22			
25				0.27			
26				0.34			
27				0.18			
28				0.11			
29				0.15			
30				0.17			
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	Yes	Yes	Yes
		PRINTED NAME: Nathan Emmett	
		SIGNATURE: <i>Nathan Emmett</i>	
		PHONE #: (503) 910-3912	CERT #: N/A

