

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook
 Month/Year: Dec-25

System Name: OPRD Oswald West SP ID#: 41 91009 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1				0.19			
2				0.15			
3				0.12			
4				0.08			
5				0.12			
6				0.19			
7				0.17			
8				0.19			
9				0.12			
10				0.11			
11				0.13			
12				0.12			
13				0.18			
14				0.19			
15				0.30			
16				0.25			
17				0.19			
18				0.19			
19				0.49			
20				Off			
21				0.21			
22				0.17			
23				0.19			
24				0.18			
25				Off			
26				0.21			
27				0.19			
28				Off			
29				Off			
30				0.18			
31				0.19			

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² Yes All daily turbidity readings ≤ 5 NTU? Yes		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) Yes All Cl2 residual at entry point ≥ 0.2 mg/l? Yes	
Waterline break due to fallen tree, restrooms were shutdown for repairs beginning on 12/19 and occasionally as needed for the rest of the month.		PRINTED NAME: Nathan Emmett SIGNATURE: <i>Nathan Emmett</i> PHONE #: (503) 910-3912 CERT #: N/A	

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

A

Disinfection *Giardia* Log

System Name: OPRD Oswald West SP

ID#: 41 91009

Month/Year: Dec-24

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.6	24	62.5	6.3	7.00	59.2	YES	20
2	2.9	24	69.7	6.7	7.00	59.7	YES	20
3	3	24	72.1	6.5	7.20	65.8	YES	20
4	3	24	72.1	6.1	7.30	70.1	YES	20
5	3	24	72.1	6.2	7.30	69.7	YES	20
6	2.9	24	69.7	6.5	7.20	65.0	YES	20
7	3.7	24	88.9	9.0	7.20	60.2	YES	20
8	3.8	24	91.3	8.2	7.20	64.3	YES	20
9	3.8	24	91.3	8.0	6.90	58.5	YES	20
10	4.3	24	103.3	5.9	7.40	86.0	YES	20
11	3.9	24	93.7	6.8	7.30	74.3	YES	20
12	4.2	24	100.9	7.5	7.50	79.0	YES	20
13	6.3	24	151.4	8.2	7.50	96.5	YES	20
14	6.8	24	163.4	8.6	7.50	99.7	YES	20
15	3	24	72.1	8.0	7.50	66.2	YES	20
16	3	24	72.1	8.4	6.90	51.9	YES	20
17	4	24	96.1	8.4	6.90	58.3	YES	20
18	4.5	24	108.1	9.5	7.40	68.7	YES	20
19	5	24	120.1	9.5	6.90	60.7	YES	20
20								20
21	6.9	24	165.8	10.8	6.70	64.5	YES	20
22	7.3	24	175.4	10.2	6.90	75.8	YES	20
23	7.2	24	173.0	10.6	6.80	70.3	YES	20
24	3.9	24	93.7	10.3	6.90	50.7	YES	20
25								20
26	3.4	24	81.7	9.6	6.80	48.4	YES	20
27	3.5	24	84.1	9.9	6.80	48.0	YES	20
28								20
29								20
30	2.3	24	55.3	9.4	6.80	43.3	YES	20
31	2.6	24	62.5	9.3	7.20	52.0	YES	20