

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration

Month/Year: Feb/2021

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 91044 WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.1	—	—	.08	—	—	.08
2	—	.08	—	.08	.08	—	.08
3	.08	.08	—	.08	.08	—	.08
4	—	—	—	.07	.14	.22	.22
5	—	—	.31	.09	—	—	.31
6	.10	—	—	.09	.14	—	.14
7	—	.14	—	.09	—	—	.14
8	—	0.08	—	0.08	—	—	0.08
9	0.08	—	0.10	.09	—	—	0.10
10	.10	—	.12	.15	—	.17	.17
11	—	—	.23	.09	—	—	.23
12	.09	—	0.10	0.12	—	—	.12
13	.08	—	—	.09	—	—	.09
14	.10	—	—	.10	—	—	.10
15	.10	—	—	.09	—	—	.10
16	—	.09	—	.08	.08	—	.09
17	—	.08	—	.08	.08	—	.08
18	—	.08	—	—	.08	.08	.08
19	—	—	.09	.08	—	—	.09
20	.08	—	—	.08	—	—	.08
21	.08	—	—	.08	.08	—	.08
22	—	.08	—	0.10	—	—	0.10
23	—	0.10	—	0.10	—	—	0.10
24	0.10	—	—	.10	.12	—	.12
25	.09	.08	—	.08	—	—	.09
26	.08	—	—	.08	—	—	.08
27	0.09	—	—	0.12	—	0.08	0.12
28	—	—	0.08	—	0.08	—	0.08
29							
30							
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: <u>L. Andy Colsey</u>	
	SIGNATURE: <u>[Signature]</u>	DATE: <u>1/28/2021</u>
	PHONE #: <u>(541) 997-3851</u>	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year: Feb/2021

Disinfection *Giardia*
Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
KP 1 0941	.55	480	264	9.4	8.20	81	yes	98
BG 2 1002	.59	}	283.2	10.6	8.36	61	yes	}
KB 3 1030	.66		316.8	9.4	8.12	84	yes	
KB 4 0934	.63		302.4	9.4	8.45	84	yes	
ALC 5 1030	.67		321.6	9.4	8.32	84	yes	
KP 6 0950	.69		331.2	9.4	8.46	84	yes	
KP 7 0950	.67		321.6	10.0	8.17	63	yes	
BG 8 0952	.75		360.0	9.4	8.42	84	yes	
BG 9 0942	.68		326.4	8.9	8.27	84	yes	
VB 10 1040	.66		316.8	8.3	8.26	84	yes	
KB 11 1015	.60		288	8.9	8.39	81	yes	
KB 12 1250	.58		278.4	8.9	8.18	81	yes	
KP 13 0920	.51		244.8	9.4	8.16	81	yes	
KP 14 1003	.53		254.4	8.9	8.35	81	yes	
KP 15 1010	.55		264	8.9	8.17	81	yes	
BG 16 0937	.63		302.4	9.4	8.24	84	yes	
KB 17 1100	.68		326.4	9.4	8.46	84	yes	
KB 18 1003	.66		316.8	11.1	8.11	63	yes	
ALC 19 1020	.65		312	9.4	8.25	84	yes	
VB 20 1206	.67		321.6	9.4	8.21	84	yes	
KB 21 1115	.65		312	8.9	8.30	84	yes	
KP 22 0944	.65		312	10.0	8.31	63	yes	
BG 23 0951	.65		312	10.0	8.05	63	yes	
KB 24 0944	.60		288	9.4	8.32	81	yes	
KB 25 0758	.59		283.2	9.4	8.12	81	yes	
ALC 26 0950	.58		278.4	9.4	8.48	81	yes	
KB 27 1250	.61		292.8	8.9	8.37	84	yes	
KB 28 1205	.60		288	10.0	8.35	61	yes	
30								
30								
30								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A
SYSTEM NAME: Heceta Head State Park
SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N
Florence, OR 97439 MONTH/YEAR
PHONE: 541-547-3416

Feb 2021
30437

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
1				
830 2	Bc	0.5		30501
800 3	Bc	.4		30508
4				
810 5	Mc	.1		30510
745 6	Bc	.1		30512
7				
8				
8 9	Bc	.1		30540
815 10	Bc	.1		30555
95 11	Bc	.1 CXT	0.5 pump	30562
12				
13	Bc	.1		30568
930 14	Deb	1.0	EXT Pump t:	30569
930 15	Deb	.7		30590
830 16	Bc	0.1 CXT	1.0 pump mix 30 oz. cl ₂ + 1/2 H ₂ O	30672
10am 17	JT	.3 CXT	CXT	
10am 18	JT	.5 CXT	2.9 gallons cl ₂	30720
930 19	Deb	.5		30730
930 20	Deb	.4		30732
21				
930 22	Deb	.2	CXT	30734
10am 23	JT	.3	CXT	
10am 24	JT	.5	CXT	
10am 25	JT	.3	CXT 2.5 gals cl ₂	30765
10 26	Deb	1.5	CXT	
10 27	Deb	1.5	CXT	
10 28	Deb	1.5	CXT	30800
29				
30				
31				

Total: _____
Write off when not producing water.

Total -- # days=monthly average

_____ = _____