


OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Lane
Month/Year: March 2021

System Name:	OPRD JM Honeyman Memorial State Park		ID#: 41	91044		WTP: TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	0.08	—	—	0.08	—	0.08
2	—	0.08	—	0.08	0.08	—	0.08
3	—	0.08	—	0.08	0.08	—	0.08
4	—	0.08	—	0.08	—	—	0.08
5	—	0.08	—	0.08	—	—	0.08
6	—	0.08	—	0.08	—	—	0.08
7	—	0.08	—	0.08	—	—	0.08
8	—	0.08	—	0.08	—	—	0.08
9	—	0.08	—	—	0.09	—	0.09
10	—	0.11	0.08	—	—	0.08	0.11
11	—	—	0.08	—	—	0.11	0.11
12	—	—	0.11	0.09	—	—	0.11
13	0.09	—	—	0.10	—	—	0.10
14	0.10	—	—	0.09	—	0.09	0.10
15	—	—	—	0.08	—	—	0.08
16	0.09	0.08	—	0.08	—	—	0.09
17	—	0.08	—	0.08	—	—	0.08
18	—	0.08	—	0.10	0.10	—	0.10
19	—	0.10	—	0.08	0.08	—	0.10
20	—	0.08	—	0.11	—	—	0.11
21	0.11	0.10	—	0.08	0.08	—	0.11
22	—	0.08	—	0.10	—	—	0.10
23	0.10	—	—	0.08	—	—	0.10
24	0.10	—	—	0.08	—	—	0.10
25	0.09	—	—	0.11	—	—	0.11
26	0.13	0.08	—	0.11	0.10	—	0.13
27	—	0.11	—	0.14	—	—	0.14
28	0.14	—	—	0.10	—	—	0.14
29	0.09	0.10	—	0.09	—	—	0.10
30	—	0.09	—	0.09	—	—	0.09
31	0.08	0.09	—	0.08	—	—	0.09

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes / No		
Notes:	PRINTED NAME: Kati Baker SIGNATURE:  PHONE #: (541) 997-3051 DATE: 4/1/2021 CERT #: n/a		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 91044 Month/Year: March/2021 Disinfection Giardia Log Inactive: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [°C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
BG 1 1045	0.57	480	273.6	10.0	8.35	61	yes	98
BG 2 1018	0.64		307.2	10.6	8.47	63	yes	
KB 3 1035	0.68		326.4	10.0	8.23	63	yes	
BG 4 1018	0.67		321.6	10.6	8.36	63	yes	
MP 5 1107	0.64		307.2	10.0	8.27	63	yes	
KP 6 0930	.64		307.2	10.0	8.34	63	yes	
KP 7 1017	.58		278.4	10.0	8.50	61	yes	
MC 8 1010	.69		331.2	11.1	8.46	63	yes	
KB 9 0916	.66		316.8	9.4	8.41	84	yes	
KB 10 0845	.64		307.2	8.9	8.35	84	yes	
KB 11 1020	.64		307.2	9.4	8.27	84	yes	
KB 12 0850	.61		292.8	8.9	8.10	84	yes	
KP 13 1000	.60		288	10.0	8.24	61	yes	
KP 14 0930	.61		292.8	11.7	8.26	63	yes	
KB 15 0909	.63		302.4	9.4	8.42	84	yes	
KB 16 0903	.66		316.8	8.9	8.32	84	yes	
KB 17 1020	.70		336	11.1	8.29	63	yes	
MP 18 1116	.69		331.2	9.4	8.41	84	yes	
KB 19 0936	.70		336	9.4	8.16	84	yes	
KB 20 0824	.73		350.4	10.0	8.56	75	yes	
JH 21 1010	.72		345.6	10.0	8.21	63	yes	
KB 22 0935	.69		331.2	11.1	8.20	63	yes	
KB 23 0908	.67		321.6	10.0	8.35	63	yes	
KB 24 0917	.64		307.2	10.0	8.33	63	yes	
MC 25 0935	.60		288	10.6	8.42	61	yes	
MP 26 1143	.49		235.2	9.4	8.24	81	yes	
JH 27 1015	.63		302.4	10.6	8.41	61	yes	
JH 28 1035	.62		297.6	10	8.14	61	yes	
KB 29 0925	.53		254.4	11.7	8.39	61	yes	
KB 30 0923	.59		283.2	9.4	8.20	81	yes	
KB 31 0942	.60		288	10.0	8.21	61	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A

SYSTEM NAME: Heceta Head State Park

SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N

Florence, OR 97439 MONTH/YEAR

PHONE: 541-547-3416

March
2021

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
1				
9:00 2	Be	0.9 pump	0.5 cxt	30826
8:00 3	Be	1.0 cxt		30842
8:30 4	ZB	.	.4 cxt mix 3002 Cl ₂ 1g Hr ^o	30853
8:30 5	Be	0.1 cxt		30857
Z 6		.2		
Z 7		.2		
8:30 8	Dele	1.0	Pump	30869
9				
10				
11 hrs.	JT	.5	CXT 3gals Cl ₂	30891
12	Be	1.1		30895
13				
14	ZB	1.0	cxt	30913
15				
8:00 16	Be	.5		30920
8:30 17	Be	.4		30925
10:00 18	ZB	.8	cxt	30940
8:40 19	Be	.5	CXT	30954
20				
8:40 21	ZB	.5	cxt	30962
9:00 22	ZB	.6	cxt	30968
23				
24	Be	.5		30971
25	ZB	.3	cxt	30977
26				
27				
28	ZB	.5	cxt	30984 30987
29	ZB	.3	cxt	30991
30	JT	.5	Cxt 2.5 gals/Cl ₂	31025
31	Be	.4		31030

Total: _____
Write off when not producing water: _____

Total -- # days=monthly average

--- = _____