

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Lane
Month/Year: April 2021

System Name:	OPRD JM Honeyman Memorial State Park		ID#: 41	91044		WTP: TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.08	0.08	—	0.08	—	—	0.08 0.08
2	—	0.08	—	0.09	0.08	—	0.09
3	—	0.08	—	0.09	—	0.08	0.09
4	—	0.08	—	0.10	0.09	—	0.10
5	—	0.09	—	—	0.10	—	0.10
6	—	0.15	—	—	—	0.20	0.20
7	—	—	0.20	—	0.20	—	0.20
8	—	—	0.21	—	0.13	—	0.21
9	—	0.12	—	0.1	—	—	0.12
10	0.1	—	—	0.11	—	—	0.11
11	0.11	—	—	0.10	—	—	0.11
12	0.10	—	—	0.10	0.10	—	0.10
13	—	0.10	—	0.09	0.09	—	0.10
14	—	0.09	—	0.08	0.09	—	0.09
15	—	0.09	—	0.08	0.09	—	0.09
16	—	0.09	—	0.09	0.09	—	0.09
17	0.08	0.09	—	0.08	0.09	—	0.09
18	—	0.08	0.08	0.10	0.10	—	0.10
19	0.09	0.10	—	0.09	—	—	0.10
20	0.08	—	—	0.09	—	—	0.09
21	0.09	—	—	0.10	—	—	0.10
22	0.09	—	—	0.10	—	—	0.10
23	0.10	—	—	0.09	—	—	0.10
24	0.08	—	—	0.10	0.10	—	0.10
25	0.09	0.1	—	0.13	—	—	0.13
26	—	0.12	—	0.08	—	—	0.12
27	—	0.08	—	—	0.09	—	0.09
28	—	—	0.09	0.08	—	—	0.09
29	0.09	—	—	0.10	—	—	0.10
30	—	0.10	—	0.09	0.10	—	0.10

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: Kati Baker	
	SIGNATURE: <i>[Signature]</i>	DATE: 5/1/2021
	PHONE #: (541) 997-3857	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park	ID#: 41	91044	Month/Year: April/2021	Disinfection Giardia Log Inactive:	0.5
---	---------	-------	------------------------	------------------------------------	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
VB 11028	.62	480	297.6	10.6	8.09	63	yes	98
VB 20956	.65		312	10.0	8.21	63	yes	
JH 3 1045	.62		297.6	11.1	8.29	61	yes	
JH 4 1027	.73		350.4	11.1	8.27	63	yes	
ALL 5 0740	.70		336	10.0	8.21	63	yes	
KP 6 1357	.67		321.6	11.1	8.18	63	yes	
VB 7 1410	0.65		312.0	11.1	8.17	63	yes	
JH 8 1200	.64		307.2	11.1	7.99	51	yes	
ALL 9 0930	.65		312	10.6	8.36	63	yes	
JH 10 1040	.80		384	11.1	8.34	63	yes	
JH 11 1005	.62		297.6	10.6	8.23	61	yes	
KP 12 1042	.57		273.6	10.6	8.19	61	yes	
KP 13 1055	.60		288.0	12.2	8.15	61	yes	
KP 14 1053	.67		321.6	12.8	8.11	63	yes	
VB 15 0940	.69		331.2	11.7	8.34	63	yes	
VB 16 0915	.72		345.6	11.7	8.18	63	yes	
JH 17 1100	.75		360	12.2	8.03	63	yes	
JH 18 1005	.82		393.6	12.8	8.10	65	yes	
VB 19 0938	.77		369.6	12.8	8.04	63	yes	
VB 20 0909	.69		331.2	12.8	8.19	63	yes	
VB 21 0930	.62		297.6	12.2	8.25	63	yes	
VB 22 0830	.57		273.6	12.2	8.04	61	yes	
VB 23 0935	.53		254.4	11.7	8.07	61	yes	
JH 24 1055	.50		240	12.2	8.21	61	yes	
JH 25 0950	.83		398.4	11.7	8.26	63	yes	
VB 26 0857	.49		235.2	11.7	8.18	61	yes	
VB 27 0833	.57		273.6	12.2	8.51	73	yes	
KP 28 0925	.59		283.2	12.8	7.97	51	yes	
VB 29 0835	.59		283.2	12.2	8.02	61	yes	
VB 30 0925	.61		292.8	12.8	8.18	63	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A
SYSTEM NAME: Heceta Head State Park
SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N
Florence, OR 97439 MONTH/YEAR
PHONE: 541-547-3416 *April* 2021

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
8:30	Be	.12		31034
8:30	Be	.12		
8:30	Be	.12	mix 30% ch2 with H2O - 9.3g in bucket	1041
4				
5				
6	Be	.1		
8:30	Be	.14		31076
8				
9	Be	.14		31080
11	Be	.13		31085
4:30	23	.4		31088
10am	JT	.3	No pressure after CXT flush	31102
11:30am	JT	.3	CXT, 3 gals. Cl2	31108
8:00	Be	.13		31114
9:30	DW	.3		
9:30	DW	.3		
9:30	DW	.3		31126
9:00	DW	.3		31131
10am	JT	.3 cxt	2.8 Cl2, gallons	31142
10am	JT	.3 cxt		31149
21				
9:08	DW	.2		31160
9:00	DW	.2		31165
9:00	DW	.2		31172
25	Be	.1		31180
26	ZD	.14		31190
NOON	JT	.3	CXT 2.5 gal cl2	31200
28	Be	.2	CXT mix 1/2 H2O 300% cl2	31209
8:30	Be	.12		31236
9	Be	.2	CXT	31230
31				

Total: _____
Write off when not producing water.

Total -- # days=monthly average

----- = -----