

Green

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Lane
Month/Year: May 2021

System Name:	OPRD JM Honeyman Memorial State Park		ID#: 41	91044		WTP: TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	—	.10	.10	—	.08	—	.10
2	—	—	.08	—	.08	.09	.09
3	—	—	.09	.09	—	—	.09
4	—	—	.09	—	.09	—	.09
5	—	—	.09	—	.09	—	.09
6	—	—	.09	—	—	—	.09
7	.11	—	—	.09	—	—	.11
8	—	.09	.10	.10	—	—	.10
9	.11	—	—	.11	—	—	.11
10	—	.11	—	—	.10	.10	.11
11	—	—	—	0.08	—	—	0.08
12	—	—	0.08	—	.09	.09	.09
13	—	—	—	.08	—	—	.08
14	—	.07	.08	—	.07	.08	.08
15	—	—	—	0.08	—	—	0.08
16	0.08	0.08	—	0.08	.08	—	.08
17	—	—	.08	.08	—	—	.08
18	—	.08	—	.10	—	—	.10
19	—	.09	—	—	.08	—	.09
20	—	—	0.08	0.08	0.08	0.08	0.09
21	—	—	0.08	.08	—	—	.08
22	.08	—	—	.09	—	—	.09
23	.09	—	—	.10	—	—	.10
24	—	.09	—	.07	.07	—	.09
25	—	—	.07	.07	—	—	.07
26	.07	—	—	—	.08	0.08	.08
27	—	—	.08	.08	—	—	.08
28	—	.08	.07	—	.08	.08	.08
29	—	—	.09	.08	.08	.08	.09
30	—	—	.08	.08	.09	.09	.09
31	.09	—	—	.07	.08	—	.08

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:	PRINTED NAME: <i>Kati A Baker</i>		DATE: <i>6-1-2021</i>
	SIGNATURE: <i>[Signature]</i>		CERT #:
	PHONE #: <i>(541) 997 8657</i>		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year: May 2021

Disinfection Giardia Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No ³	[GPM]
KB 10907	.62	480	297.6	13.3	7.97	53	yes	98
JH 2 1125	.62		297.6	13.3	8.29	61	yes	
KB 30914	.60		288	13.3	8.13	61	yes	
KB 40925	.59		283.2	13.9	8.00	51	yes	
JH 5 1015	.60		288	13.9	8.31	61	yes	
KB 60920	.55		264	13.9	8.10	61	yes	
KB 70939	.52		249.6	12.8	8.21	61	yes	
JH 80945	.52		249.6	12.8	8.12	61	yes	
JH 9 1005	.52		249.6	13.3	8.16	61	yes	
KB 10640	.49		235.2	13.3	8.35	61	yes	
KB 110910	.55		264	12.8	8.32	61	yes	
B6 121405	0.61		292.8	13.3	8.04	63	yes	
KB 130915	.64		307.2	13.9	8.14	63	yes	
KB 140948	.70		336	13.9	8.23	63	yes	
KP 151111	.65		312	14.4	8.22	63	yes	
B6 161304	.74		355.2	14.4	8.46	63	yes	
KP 171110	.76		364.8	14.4	8.21	63	yes	
KB 181020	.72		345.6	13.3	8.28	63	yes	
KB 190955	.69		331.2	13.3	8.15	63	yes	
KB 200950	.67		321.6	14.4	8.38	63	yes	
KB 210923	.62		297.6	14.4	8.13	63	yes	
JH 220930	.59		283.2	13.3	8.18	61	yes	
JH 230930	.73		350.4	13.3	7.98	53	yes	
KB 240855	.56		268.8	13.9	8.16	61	yes	
KB 250905	.60		288	14.4	8.06	61	yes	
KB 261157	.59		283.2	13.3	8.02	61	yes	
KB 271020	.63		302.4	15	8.06	42	yes	
JH 28 1105	.75		360	15	8.04	42	yes	
JH 29	.69		331.2	15	8.18	41	yes	
KP 300958	.69		331.2	15.6	8.05	42	yes	
KP 31 1030	.81		388.8	15.6	8.01	43	yes	

³ If Cl₂ at entry point < 0.2 mg/L or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A
SYSTEM NAME: Heceta Head State Park
SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N
Florence, OR 97439 MONTH/YEAR
PHONE: 541-547-3416

May 2021

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
1	De	0.3	3.5 g Cl ₂	31243 31246
2	DW	.3		31246
3	ZB	0.3		31256
4	JT	.3 cxt	3.3 gal. Cl ₂	31266
5	Be	.3		31266
6				
7	DW	.2		31287
8	DW	.1	3.0 gal	31312
9 11:00A	DW	.5	3 PH	31341
10 10am	JT	.4	cxt 3 gals Cl ₂	31355
11 9:00A	ZW	1.1		31388
12 4:00	DW	.6	2.5 gal	31421
13 9:00	DW	.4	2.5	31447
14 9:00	DW	.5	2.25	31478
15 9:00	DW	.5	2.2	31491
16 9:15	DW	.6	2.1	31514
17 10:00	ZW	.4		31522
18 8	Be	.4	2.1	31522
19 8	De	.4	2.1	31530
20 9:00	DW	.1	Added 2.5 gal / 4.5 gal	31550
21 9:20	gc	.2		31554
22 10:45	ZW	.8		31578
23 12:00	ZW	.5		31594
24 11am	JT	.5	cxt 4.4 Gals/Cl ₂	31606
25 2pm	JT	.5	cxt 4.2 Gals/Cl ₂	31633
26 9:00	DW	.5	cxt 4.2	31657
27 9:00	DW	.5	cxt 4.0	31678
28 9:00	DW	.4	cxt 4.0	31697
29 9:00	DW	.4	cxt 3.9	31720
30 9:00				
31 9:00	KE	.4	3.6	31774

2pm
rad
water
+
changed
etc
wash
31629

Total: _____ Total -- # days=monthly average
Write off when not producing water. _____ = _____