

Green

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Lane
 Month/Year: June 2021

System Name:	OPRD JM Honeyman Memorial State Park		ID#: 41	91044		WTP: TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	—	.07	.09	—	—	.09
2	.09	—	—	.09	.09	—	.09
3	—	—	.09	—	—	.08	.09
4	—	—	.07	.09	—	—	.09
5	.09	—	—	.10	—	.10	.10
6	.09	—	.10	—	.10	—	.10
7	—	—	.09	.09	.09	—	.09
8	—	—	.09	.09	—	—	.09
9	—	.09	.09	.09	—	.09	.09
10	.09	—	—	.07	.10	—	.10
11	—	.11	.11	—	—	.10	.11
12	—	—	—	.11	.09	.10	.11
13	—	—	—	.13	.11	.11	.13
14	—	—	.12	.13	.12	—	.13
15	—	—	.13	.13	.09	.08	.13
16	—	—	.10	.11	.10	—	.11
17	—	—	.10	.12	.11	—	.12
18	—	.11	—	.11	100 .11	.12	.12
19	—	—	.13	.13	.11	.11	.13
20	.12	—	—	.16	.12	.13	.16
21	—	—	—	.12	.12	.12	.12
22	—	—	.11	.11	.11	—	.11
23	.11	.11	.11	—	.13	.12	.13
24	.12	—	—	.10	.11	.11	.12
25	—	—	—	.12	.13	.13	.13
26	—	—	—	.13	.15	.14	.15
27	.14	—	—	.15	.15	.13	.15
28	.13	—	—	.13	.12	.12	.13
29	—	—	—	.12	.12	.13	.13
30	.12	—	—	.15	.15	.15	.15

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:		PRINTED NAME: Kati Baker	DATE: 7/1/2021
		SIGNATURE: <i>[Signature]</i>	CERT #:
		PHONE #: (541) 997 3851	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 91044 Month/Year: June 2021 Disinfection Giardia Log Inactive: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]	
KB 1 1040	.76	480	364.8	16.1	8.09	42	yes	98	
KB 2 1128	.68	}	326.4	16.7	8.09	42	yes	}	
KB 3 1022	.63		302.4	16.7	8.17	42	yes		
JH 4	.61		292.8	16.7	8.11	41	yes		
KB 5 1010	.56		268.8	16.7	8.17	41	yes		
JH 6 1110	.58		278.4	16.7	8.24	41	yes		
ML 7 0945	.58		278.4	16.7	8.28	41	yes		
KB 8 0950	.62		297.6	16.7	7.95	35	yes		
KB 9 1430	.64		307.2	16.7	8.09	42	yes		
KB 10 1105	.63		302.4	17.2	8.27	42	yes		
KB 11 1320	.63		302.4	16.1	8.26	42	yes		
KP 12 1622	.70		336.0	17.2	8.00	35	yes		
JH 13 1010	.71		340.8	17.2	8.01	42	yes		
KB 14									
KB 15 1300	.74		355.2	17.2	7.98	35	yes		
KB 16 1140	.66	316.8	17.8	7.97	35	yes			
KB 17 1100	.59	283.2	17.8	7.90	34	yes			
KB 18 1404	.53	254.4	17.8	7.99	34	yes			
KB 19 1300	.50	240	17.8	7.96	34	yes			
KP 20 1750	.49	235.2	17.8	8.07	41	yes			
ML 21 1000	.49	235.2	17.8	8.10	41	yes			
KB 22 1000	.55	264	17.8	7.97	34	yes			
KB 23 1404	.61	292.8	17.2	7.83	35	yes			
KB 24 1058	.63	302.4	17.8	8.11	42	yes			
ML 25 1155	.62	297.6	17.8	8.18	42	yes			
KB 26 1420	.64	307.2	18.3	8.00	35	yes			
KP 27 1803	.65	312	20	8.13	32	yes			
ML 28 1055	.61	292.8	19.4	8.06	42	yes			
KB 29 1050	.54	259.2	19.4	7.81	34	yes			
ML 30 1050	.48	230.4	18.9	7.83	34	yes			

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A
SYSTEM NAME: Heceta Head State Park
SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N
Florence, OR 97439 MONTH/YEAR
PHONE: 541-547-3416

June 2021

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
1 1030	DC	0.8		31787
2 8:15	DC	0.4	2.5g	31794
3 9:00	KE	1.0	3.2g	31857
4 9:00	KE	1.0	2.9g	31918
5 9:00	KE	0.8	2.7g	31976
6 8:45	KE	0.5	2.5g	32008
7 8:45	KE	0.4	2.3g	32040
8				
9 10:00	LW	.7	2 g pH	32130
10 1030	BP	.6	mix 1g Cl ₂ 3g break	32133
11 9:05	KT	1.3	3.0g	
12 10:30	KE	0.5	2.8g	32186
13 9:05	KT	1.3	2.8g	
14 10:30	KE	0.5	2.7g	32206
15 840	BC	.2	2.7g	32212
16 11	BC	.2 cxt	0.7 pump house 2.7g	32227
17 845	BC	.3 cxt		32241
18				
19 11:45	LW	.1	1.2 pump	32317
20 10:50	KT	.2 cxt	1.1 pump	32352
21 9am	JT	1 P.House	1.0 pump 2 gal/Cl ₂	32366
22 9am	JT	1	pump House, 1.9 gal/Cl ₂	32377
23 10am	JT	.5	cxt 1.9 gal/Cl ₂	
24 10:00	DC	.5	cxt 1.9 gal	32387
25 6:15	KT	.1	1.7	32433
26 9am	ERBC	.1	1.7	32471
27 9am	ERBC	.4	1.5	32488
28 10am	JT	.4	CXT 1.4 gal Cl ₂	32520
29 9am	ERBC	.5	CXT 1.5 gal Cl ₂ 1.4 gal Cl ₂	32536
30 10am	JT	.3	CXT 1.7 gal Cl ₂	32540
7/1 10am	JT	.3	CXT " "	32546

Added 1/2 gallon Cl₂ Mix. JT

Total: _____ Total -- # days=monthly average _____
Write off when not producing water. _____