

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration

Month/Year: July 2021

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 91044 WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.14	.15	.15	.15	—	.14	.15
2	.14	.15	—	.14	.14	.13	.15
3	.13	.13	—	.12	.12	.12	.13
4	.12	.11	.10	.13	.12	.15	.15
5	.15	—	—	.09	.09	.08	.15
6	—	—	—	.08	.08	.08	.08
7	—	—	—	.08	.11	.10	.11
8	—	—	—	.10	.10	.10	.10
9	—	—	—	.11	.10	.10	.11
10	—	—	—	.11	.12	.11	.12
11	—	—	.11	.12	.12	—	.12
12	—	—	.12	.12	—	—	.12
13	.13	—	—	.10	.11	—	.13
14	.11	—	—	.11	.12	—	.12
15	.12	—	.14	.14	—	.10	.14
16	—	—	—	.12	—	—	.12
17	.13	—	—	.11	.13	—	.13
18	.13	—	—	.11	—	—	.13
19	.15	—	—	.18	—	—	.18
20	.13	—	—	.08	.08	—	.13
21	—	.08	.07	.08	.08	—	.08
22	.08	—	—	.08	.10	.10	.10
23	—	—	.08	.08	.08	.08	.08
24	—	—	.08	.09	.09	—	.09
25	—	.09	—	.08	.09	.08	.09
26	—	—	.08	.12	.16	—	.16
27	.22	—	—	.09	.10 ²	—	.22
28	.11	—	—	.12	.12	—	.12
29	.12	—	—	—	—	—	.12
30	—	—	—	—	.13	.14	.14
31	.17	.23	.26	—	—	—	.26

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Randy Copsey

SIGNATURE: [Signature] DATE: 1 Jul 2021

PHONE #: (541) 997-3851 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 91044 Month/Year: July 2021 Disinfection Giardia Log Inactive: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
VB 11120	.48	480	230.4	18.9	8.08	41	yes	98
VB 21445	.47	}	225.6	18.9	8.10	41	yes	}
VB 30910	.47		225.6	17.8	7.99	34	yes	
KP 41805	.44		211.2	18.9	8.09	41	yes	
AL 51110	.48		230.4	18.9	8.00	34	yes	
VB 61020	.65		312	18.9	8.08	42	yes	
VB 71437	.80		384	18.9	8.09	42	yes	
VB 81505	.90		432	19.4	7.99	36	yes	
VB 91002	.89		427.2	18.9	8.14	43	yes	
VB 100939	.91		436.8	18.9	7.99	36	yes	
AL 110950	.92		441.6	18.9	7.85	36	yes	
AL 121120	.91		436.8	18.9	8.09	43	yes	
VB 130932	.85		408	18.3	8.05	43	yes	
VB 140940	.68		326.4	18.3	7.95	35	yes	
VB 151350	.61		292.8	18.9	8.06	42	yes	
VB 160940	.54		259.2	18.3	8.19	41	yes	
AL 170920	.50		240	18.3	7.97	34	yes	
AL 181000	.58		278.4	18.3	7.99	34	yes	
AL 191345	.62		297.6	18.9	8.04	42	yes	
VB 200908	.62		297.6	18.3	8.24	42	yes	
VB 210910	.74		355.2	18.9	8.00	35	yes	
VB 221335	.78		374.4	19.4	8.11	42	yes	
VB 231221	.80		384	18.9	7.92	35	yes	
VB 240855	.84		403.2	18.9	8.08	43	yes	
KP 251627	.88		422.4	19.4	7.78	36	yes	
AL 261040	.89		427.2	18.9	8.13	43	yes	
VB 270905	.83		398.4	18.3	8.03	43	yes	
AL 280955	.72		345.6	18.9	8.10	42	yes	
RW 29	.60		288	18.9	8.30	41	yes	
VB 300947	.56		268.8	18.3	8.17	41	yes	
VB 310846	.62		297.6	18.9	7.93	35	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us, 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A

SYSTEM NAME: Heceta Head State Park

SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N

Florence, OR 97439

MONTH/YEAR

PHONE: 541-547-3416

July 2021

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
1 7/1	JT	.3	1.7 gal c/2	32546
2 7/2	KT	.7	1.7 gal c/2	32570
3 7/3	KT	.5	1.5 gal c/2	32577
4 7/4	KT	.3	1.5 gal c/2	32583
5 7/5	ERG	.4	1.4 gal c/2	32588
6 7/6	KT	.5	1.4 gal c/2	32602
7 7/7	KT	.2	1.3 gal c/2	32610
8 7/8	ERG	.6	1.6 gal c/2	32613
9 7/9	ERG	0.2	1.2 gal c/2	32623
10 7/10	KT	.2	1.2 gal c/2	32628
11 7/11	LW	.1	1.2 gal c/2	32661
12 11:00am	KE	1.5	1.2 gal, + 1/2 gal	32756
13 7/13	KT	1.5	1.5 gal c/2	32763
14 7/14	KT	1.4	1.4 gal c/2	32766
15 7/15	DW	1.0		32794
16 7/16	KT	.6	2.0 gal c/2	32799
17 7/17	DW	.9	1.9 gal	32807
18		.8		
19 7/18	ERG	0.2	1.0 gal c/2	32822
20 7/20	KT	.1	3 gal c/2	32825
21 7/21	DW	.1	mix 1/2 H ₂ O 3/4 c/2 1.6 gal 3/4	32846
22 8:30am	DW	.1	2.8 gal	32860
23 8:00am	DW	.2	2.6 gal	32890
24 8:00am	DW	.2	2.5 gal	32918
25 9:00am	ERG	.5	1.7 gal c/2	32929
26 9:00am	ERG	.4	1.4 gal c/2	32940
27 9:13/27	KT	.2	1.4 gal c/2	32944
28 8:00	DW	.2	1.1 gal	32995
29 8:30	DW	.2	2.0 gal	33002
30 8:20	SM/EG	.3	.8 gal c/2	33004
9:00	CM 12G	.7	.7 gal c/2	33008

Added 1/2 gal. JT
 Added 1/2 gal. JT