

OHA - Drinking Water Services -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Lane
 Month/Year: August 2021

System Name:	OPRD JM Honeyman Memorial State Park		ID#: 41	91044		WTP: TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	—	.13	.09	.12	—	.13
2	—	.14	—	.06	.07	.08	.14
3	—	—	.08	—	.11 pm	.10	.11 pm
4	.10	—	—	.11	.11	.11	.11
5	—	—	.11	.11	.08	.07	.11
6	—	—	—	.10	.10	.11	.11
7	.10	—	.10	.08	.07	.08	.10
8	.08	—	—	.10	.08	.08	.10
9	—	—	.08	.08	.13	.16	.16
10	—	—	.16	.11	.14	—	.16
11	—	.2	—	.11	.16	—	.16
12	—	.18	—	.12	.11	—	.18
13	—	.17	—	.09	.20	—	.17
14	.09	—	—	.09 .10	.10 .10	.10	.10
15	—	—	.13	.11	.10	.10	.13
16	—	—	.14	.11	—	.12	.14
17	.12	—	—	.07	.07	.08	.12
18	—	—	.09	.083	.08	.08	.09
19	—	—	.10	.10	.10	.09	.10
20	—	—	.09	.09	.10	.09	.10
21	—	—	.097	.10	.10	.10	.10
22	—	—	—	.12	.10	.11	.12
23	—	—	.12	.12	.13	—	.13
24	.26	—	—	.12	.12	.12 ^{CS}	.26
25	.16	—	—	.12	.14	—	.16
26	.16 ⁷⁰ .11	—	—	.13	.15	—	.15
27	.24	.13	—	.22	—	—	.24
28	.22	—	—	—	.28	—	.28
29	.20	—	—	.13	.12	—	.20
30	.20	—	—	.101	.12	—	.20
31	.12	—	—	.10	—	—	.12

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:

PRINTED NAME: Randy Colsey

SIGNATURE: [Signature]

PHONE #: (541) 997-3851

DATE: 9/1/21

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year: August 2021

Disinfection Giardia
Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
AL 10950	.56	480	268.8	18.9	7.94	39	yes	98
AL 20945	.54		259.2	18.9	8.14	41	yes	
KB 30915	.61		292.8	19.4	8.01	42	yes	
AL 41020	.64		307.2	18.9	8.02	42	yes	
KB 51140	.71		340.8	18.9	7.98	35	yes	
KB 61250	.76		364.8	18.9	7.78	35	yes	
KB 70935	.76		364.8	19.4	8.03	42	yes	
AL 81130	.78		374.4	19.4	7.86	35	yes	
AL 9245	.79		379.2	19.4	8.44	42	yes	
KB 10102	.74		355.2	19.4	7.88	35	yes	
KB 110930	.66		316.8	19.4	8.13	42	yes	
KB 12103	.56		268.8	20.0	8.08	31	yes	
KB 130910	.53		254.4	18.9	7.91	34	yes	
KB 141000	.57		244.8	19.4	8.02	41	yes	
AL 151345	.52		249.6	20.6	8.06	31	yes	
KB 161633	.55		264	20.0	8.09	31	yes	
KB 170945	.53		254.4	19.4	8.21	41	yes	
AL 181350	.71		340.8	20.0	7.96	35	yes	
KB 191430	.78		374.4	20.0	7.89	26	yes	
KB 200930	.77		369.6	19.4	7.92	35	yes	
AL 211130	.77		369.6	20.0	8.28	32	yes	
AL 221130	.77		369.6	19.4	7.87	35	yes	
AL 231130	.75		360	19.4	8.15	42	yes	
KB 24059	.64		307.2	18.9	8.08	42	yes	
KB 25010	.56		268.8	18.9	8.10	41	yes	
JH 260925	.53		254.4	18.3	7.99	34	yes	
JH 271005	.49		235.2	18.3	7.82	41	yes	
AL 281620	.46		220.8	18.9	8.11	41	yes	
JH 290930	.41		196.8	17.8	8.07	39	yes	
AL 301010	.52		249.6	18.3	7.91	34	yes	
AL 311010	.57		273.6	18.3	8.06	41	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID #4191048A

SYSTEM NAME: Heceta Head State Park

SOURCE NAME: Well

August

ADDRESS: 93111 Highway 101 N

Florence, OR 97439 MONTH/YEAR

PHONE: 541-547-3416

2021

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
8:00 1	DW	.2	2 gal chl	33014
8:30am 2	JT	.3	EXT Pump H. 2 gal chl	33028
1:30pm 3	JT	.3	P. House 2.5 gal. chl	33047
? 4	Burke	✓	water sample	
10am 5	JT	.3	CXT 2.3 chl/gal	33068
9am 6	ERG	.5	P. House 1.5 gal. chl	33071
10:30 7	KE	0.8	EXT Pump house 2.2 gal	33090
11:00 8	KE	1.3	2.1	33106
11:00am 9	ERG	1.3	2.0 gal. chl	33112
10:00am 10	ERG	0.8	1.3 gal. chl	33114
9:50am 11	SM	.7	.9 gal. chl	33120
10:20 A 12	SM	1.0	.6 gal. chl	33124
9:20 13	KE	.7	1.4 Pump house 2.0	33139
9:20am 14	ERG	0.4	0.9 gal. chl	33140
10:00 15	KE	.6	EXT 2.6 gal	33153
9:40AM 16	ERG	.2	1.2 gal. chl	33158
9:15 AM 17	ERG	.3	0.9 gal. chl	33165
9:06 AM 18	SM	.2	0.5 gal chl	33171
9:10am 19	SM	9 McColbr deducted	0.4 gal chl	33176
10:00 20	WV	.5	2.4 gal	33190
9:10AM 21	ERG	0.1	1.0 gal chl	33197
9:49A 22	SM	.3	.5 gal chl	33206
10:30 23	KE	1.3	2.3 gal	33228
10:00 24	ERG	.6	1.6 gal chl	33239
9:37 25	SM	.7	.9 gal chl	33246
11:00 26	KE	.5	2.2 gal	33250
9:30am 27	ERG	.3	1.1 gal chl	33257
9:55 28	SM	.4	.7 gal chl	33266
9:45 29	KE	.9	2.0 gal	33281
9:30am 30	ERG	.4	1.3 gal chl	33291
9:30am 31	ERG	.4	1.2 gal chl	33299

Total: _____
Write off when not producing water.

Total -- # days = monthly average

18oz 1/2 gal water