

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration

Month/Year: Sept 2021

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 91044 WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.12	—	—	.15 ⁵	.16	—	.16
2	—	.13	—	.12	—	—	.12
3	.12	.12	—	.11	—	—	.12
4	.13	—	—	.12	.12	—	.13
5	.13	—	—	.12	.13	.13	.13
6	—	—	—	.17	—	—	.17
7	—	.26	—	.19	.15	—	.26
8	—	.20	—	—	.13	.25	.25
9	—	—	.18	.13	—	—	.18
10	.14	—	—	.14	—	—	.16
11	.24	—	—	.13	.16	—	.24
12	.12	—	—	.12	—	—	.12
13	—	.13	—	—	.08	.08	.13
14	—	—	—	.06	—	—	.06
15	—	.08	—	—	.08	.08	.08
16	—	—	—	.08	—	.08	.08
17	.08	—	—	.10	.08	—	.10
18	—	—	.08	—	—	.08 ^{EP}	.08
19	—	—	—	.10	.09	.09	.10
20	—	—	—	.11	—	—	.11
21	—	.11	—	—	.11	—	.11
22	—	.20	—	.08	—	—	.20
23	—	.10	—	—	.18	—	.18
24	—	—	.22	.11	—	—	.22
25	.12	—	—	.10	.14	—	.14
26	—	.12	—	.10	—	—	.12
27	—	.10	—	—	.08	—	.10
28	—	—	.08	.08	.08	.08	.08
29	.10	—	—	.08	.08	—	.10
30	—	.08	—	—	.1	—	.10
31	—	—	—	—	—	—	—

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: Kati Baker		DATE: 10-01-2021
	SIGNATURE: [Signature]		CERT #:
	PHONE #: (541) 997 3857		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year: Sept 2021

Disinfection Giardia Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
RW 11200	.74	480	355.2	18.3	8.18	42	yes	98
JH 20925	.68		326.4	17.2	8.06	41	yes	
RW 3845	.72		345.6	17.2	8.27	42	yes	
AL 40915	.67		321.6	17.8	8.05	42	yes	
JH 50920	.69		331.2	18.9	8.01	42	yes	
AL 61635	.73		350.4	15.9	7.94	35	yes	
KB 71116	.67		321.6	17.8	8.20	42	yes	
KB 81042	.62		297.6	17.8	8.10	42	yes	
KB 91010	.59		283.2	18.3	8.04	41	yes	
KB 101052	.56		268.8	17.8	8.08	41	yes	
KB 111110	.54		259.2	18.3	8.01	41	yes	
JH 120940	.57		273.6	18.3	8.26	41	yes	
AL 131660	.58		278.4	18.3	8.06	41	yes	
KB 141105	.68		326.4	18.3	8.13	42	yes	
KB 151050	.73		350.4	17.8	8.14	42	yes	
VB 161449	.73		350.4	17.8	7.98	35	yes	
KB 171113	.75		360	17.2	7.98	35	yes	
KB 181045	.80		384	7.8	7.85	35	yes	
KP 191022	.78		374.4	17.2	7.88	35	yes	
AL 200945	.82		393.6	16.7	7.88	36	yes	
KB 211050	.76		364.8	16.7	7.97	35	yes	
KB 221130	.72		345.6	17.2	8.03	42	yes	
AL 230950	.68		326.4	17.2	8.22	42	yes	
AL 240945	.63		302.4	17.8	8.21	42	yes	
KB 251140	.61		292.8	17.8	8.24	42	yes	
KP 261050	.64		307.2	17.8	8.21	42	yes	
KP 271013	.66		316.8	17.2	7.98	35	yes	
KB 280923	.74		355.2	17.2	8.27	42	yes	
KB 291120	.88		422.4	16.7	8.11	43	yes	
RW 30915	.90		432	17.2	8.78	52	yes	
X								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A

SYSTEM NAME: Heceta Head State Park

SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N

Florence, OR 97439 MONTH/YEAR

PHONE: 541-547-3416

Sept 2021
33299

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
1	Burke			
9:59 2	SM	.3	.9 cl ₂ gal	33322
9:45 3	SM	.5	.6 cl ₂ gal	33329
9:40am 4	ERB	.4	1.0 1/2 gal	33338
10:00 5	SM	.4	.7 cl ₂ gal	33345
9:30am 6	ERB	.4	.9 c/2 gal	333
8:20 7	De	.3	1.9 cl ₂ /gal	33367
8:20 8	DC	.3	1.8 cl ₂ /gal	33372
8:00 9	DC	.2	1.8 cl ₂ /gal	33378
8:00 10	De	.2	1.7 cl ₂ /gal	33383
8:00 11	De	.4	2.3 cl ₂ /gal mix 18oz .5 gal	33391
? 12				
10am 13	JT	1	pumphouse, 0 at cxt	33409
1:00 14	De	0.7 cxt		33472
15				
16				
8:00 17	De	0.2 cxt		33422
1:00 18	De	0.2	2.1 gal	33435
3pm 19	JT	.2 p.H.	2.1 gal	33436
9am 20	JT	.5 cxt	2.0 gal cl ₂	33458
10am 21	JT	.3 cxt	2.0 gal cl ₂	33469
8 22	De	.2	2 gal	33472
23				
9:30 24	De	0.2	1.9 gal	33486
25				
11am 26	JT	.3 cxt	1.9 cl ₂	33502
11am 27	JT	.3 P.H.	1.8 cl ₂	33517
11:30 28	De	1.1 cxt	1.8 cl ₂	33524
29	De	1.1	1.8	33570
30	De	1.2	1.8	33585
31				

Total: _____
Write off when not producing water.

Total -- # days=monthly average