

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration

Month/Year: Oct 2021

System Name:	OPRD JM Honeyman Memorial State Park		ID#: 41	91044		WTP: TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	-	-	-	.08	-	-	.08 .08
2	-	.1	-	-	.09	-	.1
3	-	-	.09	-	.10	-	.1
4	-	-	-	.09	-	-	.09
5	-	.10	-	-	.04	-	.10
6	-	.08	-	-	.08	.04	.08
7	-	-	-	.03	-	-	.03
8	.03 .03	-	-	.06	-	-	.06
9	-	.04	-	-	.08	-	.08
10	-	.08	-	-	.07	-	.08
11	-	-	.07	-	-	.03	.07
12	-	-	-	.05	-	-	.05
13	.05	.04	-	-	-	.05	.05
14	-	-	-	.03	-	-	.03
15	-	.02	-	-	.02	-	.02
16	-	-	.03	.02	-	-	.03
17	-	.02	-	.04	-	-	.04
18	-	.04	-	-	-	.05	.05
19	-	-	-	.05	-	-	.05
20	-	.05	-	-	.07	-	.07
21	-	-	.08	-	.07	-	.08
22	-	-	.06	.06	-	-	.06
23	.06	-	-	.05	-	-	.06
24	-	.08	-	-	-	-	.08
25	-	.04	-	-	.03	-	.04
26	-	-	.02	-	.04	-	.04
27	-	.04	.04	-	-	.03	.04
28	-	-	-	.04	.04	-	.04
29	-	-	.04	-	.03	-	.04
30	-	.03	.03	.03	-	-	.03
31	.03	-	.03	.03	.22	-	.22 .03 M.J.

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / No		
Notes:	PRINTED NAME: KATI BAKER	
	SIGNATURE: <i>[Signature]</i>	DATE: 11-4-2021
	PHONE #: (541) 997-3651	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effic. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year: Oct 2021

Disinfection Giardia Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
ZB 1 1230	.84	480	403.2	17.2	8.00	36	yes	98
ZB 2 1130	.87	}	417.6	16.1	8.3	43	yes	}
KP 3 1125	.98		470.4	16.7	7.15	30	yes	
KP 4 1202	.90		432	17.2	7.16	30	yes	
KB 5 1001	.89		427.2	16.1	7.12	30	yes	
KB 6 1055	.83		398.4	15.6	7.10	30	yes	
KB 7 0945	.71		340.8	16.1	7.10	29	yes	
KB 8 0933	.71		340.8	15.6	7.11	29	yes	
ZB 9 1243	.67		321.6	16.1	7.09	29	yes	
KP 10 1140	.58		278.4	16.1	7.19	29	yes	
KP 11 1044	.59		283.2	16.1	7.19	29	yes	
KB 12 0945	.66		316.8	15.6	7.11	29	yes	
AL 13 0935	.71		340.8	16.1	7.04	24	yes	
KB 14 1111	.71		340.8	15.6	7.08	29	yes	
KB 15 0935	.75		360	15.0	7.01	29	yes	
ZB 16 1120	.75		360	15.6	7.08	29	yes	
ZB 17 1128	.68		326.4	15.6	7.07	29	yes	
AL 18 0935	.88		422.4	15.6	7.01	25	yes	
LB 19 1014	.75		360	15.6	7.09	29	yes	
KB 20 1129	.75		360	15.6	7.03	29	yes	
KB 21 0935	.70		336	15.6	7.04	29	yes	
KB 22 1010	.65		312	15.6	7.06	29	yes	
KB 23 0949	.62		297.6	15.0	7.06	29	yes	
KP 24 1027	.58		278.4	15.6	7.14	29	yes	
KP 25 1044	.57		273.6	14.4	7.13	43	yes	
ZB 26 915	.52		249.6	14.4	7.13	43	yes	
AL 27 1415	.75		360.0	15.0	6.99	24	yes	
KB 28 1150	.72		345.6	15.0	7.04	29	yes	
KB 29 0930	.74		355.2	15.0	7.05	29	yes	
KB 30 1510	.76		364.8	14.4	6.99	37	yes	
MS 31 1230	.75		360	14.4	7.01	29	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A
SYSTEM NAME: Heceta Head State Park
SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N
Florence, OR 97439 MONTH/YEAR
PHONE: 541-547-3416 October 2021

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
820 1	Be	0.2 cxt	0.6 pump 1.0 at tank	33545
930 2	Be	0.6 cxt	36 ^{ext} to local water mixed 1/2 gal	335 33563
10am 3	JT	1 cxt	2 gal Cl ₂	33578
? 4				
9am 5	JT	—	2 gal Cl ₂ , flushed cxt	33582
9 6	Be	.5 cxt	1.9 gal cl ₂	33602
1000 7	Be	.4 cxt	1.9 gal cl ₂	33617
120 8	Be	.5 cxt	1.9 gal cl ₂	33623
1130 9	ID	.5 cxt	.5 → 1.0 tank 20 gals before	336318
10am 10	JT	.3 cxt		33641
9:30 11	BM	.5 cxt	1.5 cl ₂	33654
9:30 12	JT	.3 cxt		33661
930 13	BE	.2 cxt	mix 18m ch 1/2 gal H ₂ O 2.4 gal	33667
8:30 14	BM	1.0 cxt	2.3 gal cl ₂	33684
830 15	Be	.4 cxt	2.1 gal cl ₂	33693
9:45 16	BM	1.0	2 gal cl ₂	33704
10am 17	JT	.75 cxt		33709
10am 18	JT	.3 cxt		33715
11 19	Deb	.5 cxt		33715
830 20	Be	.3 cxt	2 gal cl ₂	33721
800 21	Be	.3 cxt	2 gal cl ₂	33728
930 22	Be	.9 cxt	2 gal	33732
800 23	Deb			33733
9:45 24	Deb	1.5 PH		33724
25				
26				
945 27	Be	0.4 cxt	2g	33739
28	Be	.6 cxt		
900 29	Be	.8 cxt		
1120 30	Be	.4 cxt	1.9g	33749
130 31	Deb	.6 pump		33749

Total: _____
Write off when not producing water.

Total -- # days=monthly average

_____ = _____