

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lane  
 Month/Year: NOV 2021

Conventional or Direct Filtration

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 91044 WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	—	—	MJ .22	—	—	.08	.22
2	—	—	—	.12	—	—	.12
3	.12	—	—	—	.08	—	.12
4	—	—	.15	—	.07	—	.15
5	—	—	.12	—	.07	.08	.12
6	—	—	.10	.07	—	—	.10
7	.08	—	—	.07	—	—	.08
8	—	.12	—	.04	—	—	.12
9	—	.04	—	.04	—	—	.04
10	—	.04	.04	—	.04	.04	.04
11	—	—	.04	—	.04	—	.04
12	—	—	.04	.05	—	—	.04
13	.05	—	—	.05	.04	—	.05
14	—	.04	—	—	.04	—	.04
15	—	—	.07	—	—	.05	.07
16	—	—	—	.05	—	—	.05
17	—	.09	—	—	—	—	.09
18	—	—	.09	—	—	—	.09
19	—	—	—	.07	—	—	.07
20	—	.12	—	—	—	—	.12
21	—	.09	—	.07	.07	—	.09
22	—	.10	—	.06	—	—	.10
23	—	.06	—	.05	.05	—	.06
24	—	.05	—	—	.04	—	.05
25	—	.05	—	.04	—	—	.05
26	.04	.04	—	.09	.05	—	.09
27	—	.05	—	.06	.06	—	.06
28	—	.06	—	.05	.05	—	.06
29	—	.05	—	—	.07	—	.07
30	—	.07	—	—	.12	—	.12

Conventional or Direct Filtration 95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No	
Notes:		PRINTED NAME: Kati Baker SIGNATURE: <i>[Signature]</i> DATE: 12-1-21 PHONE #: (541) 997 3057 CERT #:	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year: Nov 2021

Disinfection Giardia Log Inactive:

0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [°C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
MS 1 1105	.72	480	345.6	14.4	7.08	44	yes	98
KP 2 0956	.66		316.8	14.4	6.96	37	yes	
BW 3 1030	.66		316.8	14.4	7.11	37	yes	
KP 4 0924	.54		259.2	14.4	7.05	43	yes	
LB 5 1041	.49		235.2	13.9	7.12	43	yes	
KB 6 1000	.51		244.8	13.9	7.02	43	yes	
ZB 7 0909	.53		254.4	13.3	7.16	43	yes	
VB 8 0945	.47		225.6	13.3	7.08	43	yes	
KP 9 0928	.48		230.4	13.3	7.13	43	yes	
NM 10 9:35	.52		249.6	13.2	7.00	36	yes	
KB 11 0930	.45		216	13.3	7.03	43	yes	
NM 12 9:45	.38		182.4	14.4	7.05	35	yes	
ZB 13 1050	.43		206.4	13.9	6.96	36	yes	
ZB 14 1100	.36		172.8	13.9	7.09	42	yes	
LB 15 1018	.36		172.8	11.1	7.11	35	yes	
NM 16 9:52	.41		196.8	13.3	7.04	35	yes	
KB 17 1048	.49		235.2	12.8	7.15	43	yes	
LB 18 0950	.60		288	10.6	7.13	43	yes	
NM 19 9:45	.65		312	13.3	7.03	36	yes	
ZP 20 1050	.64		307.2	13.3	7.08	43	yes	
ZB 21 1050	.69		331.2	12.8	7.11	44	yes	
KB 22 1028	.85		408	12.8	7.08	45	yes	
KP 23 0940	.90		432	12.8	6.96	37	yes	
KB 24 0955	.93		446.4	13.3	6.96	37	yes	
KP 25 1113	.95		456	12.8	7.02	45	yes	
KB 26 1040	.95		456	10.6	7.12	45	yes	
MJ 27 1040	.96		461	12.2	7.07	45	yes	
MS 28 1045	.9		432	13.3	7.01	37	yes	
VB 29 1005	.93		446.4	12.8	6.95	37	yes	
KB 30 1010	.76		364.8	12.8	6.95	37	yes	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
dwp.dmc@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

# Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A  
SYSTEM NAME: Heceta Head State Park  
SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N  
Florence, OR 97439 MONTH/YEAR  
PHONE: 541-547-3416

NOV 2021  
33749

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
9:45	1 BM	.2	Cl <sup>2</sup> 2	33762
	2	.2 ext		33766
830	3 DC	1.6	Cl <sub>2</sub> 1.8 gal	33777
	4			
940	5 Be	0.4		33777
950	6 Be	0.4		33814
10am	7 JT	.5 ext	1.5 gal Cl <sub>2</sub>	33843
10am	8 JT	.5 ext	1.4 gal Cl <sub>2</sub>	33849
840	9 Be	.5 ext	1.4 gal chl mix 18oz chl to 1/2 g	33850
10:50am	10 Bm	.5	2 gals Cl <sub>2</sub>	33859
9:45	11 Bm	.2	2 gals Cl <sub>2</sub>	33870
	12			
1000	13 De	1.8	1.5 g chl mix 18oz chl 1/2 g tho	33885 2.2g in bucket
11am	14 JT	1 ext	2.1 gal Cl <sub>2</sub>	33890
	15			
1000	16 Be	0.1 ext	2.1 g chl	33901
1000	17 De	0.1 ext	2.1 g chl	33903
	18			
850	19 De	0.1 ext	0.8 pump 2 g chl	33913
1	20 Deb	2. Pump		33915
9:30am	21 JT	.5 ext		33925
9:30	22 JT	.3 ext		33934
9:30	23 JT	.3 ext		33942
900	24 Be	.2		33945
930	25 Be	.1		33947
920	26 De	.4		33951
845	27 Be	.1		33956
945	28 Deb	.5 + ext	1.7 pump	33960
9:30	29 JT	.3 ext		33965
9:30	30 JT	.5 ext		33971
	31			

Total: \_\_\_\_\_  
Write off when not producing water.

Total -- # days=monthly average  
\_\_\_\_\_ = \_\_\_\_\_



## WELL LOG: MONTHLY WATER REPORT

MONTH: <u>NOV</u>							YEAR: 2021	
DATE	INT.	TIME	CL2	SITE	MIX	Meter	NOTES	
1	BM	9:15	1	11	/	92332	12.68	CL <sup>2</sup> 25 <sup>+1</sup>
2	BM	9:30	1	20	/	92431	13.65	CL <sup>2</sup> 20 <sup>+2</sup>
3	BM	9:15	1	drop	/	92431	11.96	CL <sup>2</sup> 20 <sup>+2</sup>
4	JT	9am			/	92532	13.01	20
5	Be	9:20	1	2	/	92627	13.84	running 15 <sup>12</sup>
6	Be	11:30	1	2	/	92674	12.06	15 <sup>+1</sup>
7	JT	9am			/	92737	13.24	10 <sup>+3</sup>
8	JT	9am			/	92832	13.69	running 10 <sup>+</sup>
9	JT	9am			/	92847	12.35	10
10	Be	9	0.9	3	/	92951	13.28	5 <sup>+2</sup>
11	BM	9:00	1.0	29	/	92991	12.60	running 5 <sup>+1</sup>
12	Deb	10:30			/	93056	12.44	5 <sup>-</sup>
13	Deb	2 pm	1	18	40/3	93158	12.69	From 11-5 constant low every 1/2 hr reading of
14	JT	9am			/	93256	13.84	44
15	Bl	9:50	1	DL	/	93256	11.98	44
16	JT	9am			/	93356	12.71	35
17	Be	3 pm			/	93454	13.15	35 <sup>+1</sup>
18	Be	8:30am	1	01	/	93454	12.01	35 <sup>+1</sup>
19	Be	8:20	1	02	/	93554	13.08	30 <sup>12</sup>
20	Deb	2			/	93653	13.6	30
21	JT	9am			/	93653	12.27	30
22	JT	9am			/	93754	13.28	25 <sup>+2</sup>
23	Deb	10:05	1	58	/	93805	12.84	25 <sup>+</sup> running
24	Be	9:00			/	93857	12.63	20 <sup>+3</sup>
25	De	8:45	1	3	/	93957	13.58	20 <sup>+05</sup>
26	Be	8:40			/	93980	12.24	running 20
27	De	8:30	1	3	/	94065	12.67	15 <sup>12</sup>
28	JT	9am			/	94167	13.43	15
29	JT	9am			/	94190	running	14
30	Be	10:00	1	2	/	94269	12.08	10 <sup>11</sup>
31					/			