

OHA - Drinking Water Services -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Lane  
 Month/Year: Dec 2021

System Name:	OPRD JM Honeyman Memorial State Park		ID#: 41	91044		WTP: TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	—	.18	—	—	.04	—	.18
2	—	.06	—	.04	.04	—	.06
3	.04	.07	—	—	—	—	.07
4	—	.12	—	—	.09	—	.12
5	—	.11	—	.10	—	—	.11
6	.12	—	—	.14	—	—	.14
7	—	.17	.11	—	.09	.08	.17
8	—	—	.08	.09	—	—	.09
9	.08	—	—	.08	—	—	.08
10	—	.08	—	—	.08	—	.08
11	—	.08	—	—	.083	—	.083
12	—	.083	—	—	.07	—	.08
13	—	.07	<del>.09</del> .08	—	.10	—	.10
14	—	.12	—	.09	.12	—	.12
15	—	.16	—	.10	.10	—	.16
16	.11	—	—	.09	—	—	.11
17	.10	—	—	.09	—	—	.10
18	.09	—	—	.09	—	—	.09
19	<del>1.00</del> .11	—	—	<del>.09</del> .08	.10	—	.11
20	.10	.13	—	.05	.06	—	.13
21	.05	.06	—	—	.07	—	.07
22	—	—	.06	—	—	.08	.08
23	—	—	.07	.08	—	—	.08
24	.08	—	—	—	—	—	.08
25							Data correct
26							mal function
27	—	—	.07	—	.13	—	.13
28	—	—	.12	—	.09	—	.12
29	—	.11	.15	—	.07	—	.15
30	—	.09	—	—	.11	—	.11
31	—	.13	—	—	.15	—	.15

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: <i>Larry Cobsey</i>		DATE: <i>1/3/22</i>
	SIGNATURE: <i>[Signature]</i>		CERT #:
	PHONE #: <i>(541) 997-3851</i>		

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year: Dec 2021

Disinfection Giardia Log Inactive:

0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
KB 11100	.66	480	316.8	12.8	6.95	37	yes	98
KB 20955	.59	}	283.2	12.8	7.02	43	yes	}
KB 30920	.54		259.2	12.2	7.02	43	yes	
NM 40930	.51		244.8	12.8	7.01	36	yes	
MS 50955	.52		249.6	12.2	7.08	43	yes	
AL 61020	.49		235.2	12.2	7.02	36	yes	
AL 71010	.48		230.4	12.2	7.0	36	yes	
BB 80950	.53		254.4	11.7	7.14	43	yes	
ZB 90945	.52		249.6	11.7	7.09	36	yes	
MS 101035	.64		307.2	11.7	7.06	43	yes	
11	.77		396.6	11.1	7.06	37	yes	
12	.73		350.4	11.7	7.04	43	yes	
KB 130945	.71		340.8	10.6	6.98	37	yes	
KB 140946	.68		326.4	10.8	6.98	37	yes	
KB 151034	.63		302.4	10.6	6.99	37	yes	
KB 160935	.64		307.2	10.6	7.00	37	yes	
KB 171000	.61		292.8	10.6	6.96	37	yes	
ZB 18 0915	.61		316.8	11.1	7.06	37	yes	
NM 19 1030	.65		312	11.1	7.01	36	yes	
KB 201000	.67		321.6	14.4	7.04	44	yes	
KB 211022	.78		374.4	12.8	6.99	37	yes	
BB 221040	.78		374.4	10.6	7.05	44	yes	
KB 231030	.91		436.8	10.6	7.00	37	yes	
KB 240959	.88		422.4	10.0	7.00	37	yes	
NM 250947	.87		417.6	10.6	6.95	37	yes	
NM 260943	.83		398.4	10.0	6.92	37	yes	
AL 270955	.86		412.8	9.4	6.88	50	yes	
AL 281000	.87		417.6	9.4	6.95	50	yes	
AL 290945	.82		393.6	9.4	6.91	50	yes	
MS 301040	.77		396.6	8.9	7.09	58	yes	
MS 311040	.75		360	10.6	7.04	44	yes	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350