

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lane
 Month/Year: Jan 2022

Conventional or Direct Filtration

System Name:	OPRD JM Honeyman Memorial State Park		ID#: 41	91044		WTP: TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.2	-	-	.22	.14	-	.22
2	-	.18	-	-	-	-	.18
3	-	-	.22	.08	-	-	.22
4	.08	-	-	.08	.08	-	.08
5	-	.08	-	-	.08	-	.08
6	-	.07	.07	-	-	.07	.07
7	-	-	.08	.06	-	-	.08
8	.05	-	-	.06	-	-	.06
9	-	.17	-	-	.07	-	.17
10	-	.07	-	-	.09	-	.09
11	-	.07	.08	-	.08	-	.08
12	-	.09	-	.09	-	-	.09
13	-	.08	-	.10	.11	-	.11
14	.13	.07	-	.09	.07	-	.13
15	.08	-	-	.075	-	-	.08
16	.08	-	-	.09	.12	-	.12
17	.14	.15	-	.07	.07	-	.15
18	-	.07	-	-	.09	-	.09
19	-	.08	.08	-	.07	-	.08
20	-	-	.07	-	.08	.08	.08
21	-	-	-	.07	-	-	.07
22	.07	.07	-	.24	.16	-	.24
23	-	.16	-	-	.15	-	.16
24	-	.15	.16	-	.08	-	.16
25	-	.11	-	.08	-	-	.11
26	.13	.18	-	.09	-	-	.18
27	.11	-	-	.09	-	-	.11
28	.13	-	-	.08	-	-	.13
29	.10	-	-	.07	-	-	.10
30	.16	-	-	.11	-	-	.11
31	.16	.20	-	.07	.06	-	.20

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		
Notes:	PRINTED NAME: Keri A.M. Baker	DATE: 2/1/2022
	SIGNATURE: <i>[Signature]</i>	CERT #:
	PHONE #: (541) 997 3051	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year: Jan 2022

Disinfection Giardia
Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
MS 1 1050	.83	480	398.4	8.9	7.06	60	yes	98
MS 2 1030	.78	}	374.4	9.4	7.19	58	yes	}
VB 3 1015	.70		336	8.9	7.05	58	yes	
VB 4 1003	.68		326.4	10.6	7.02	44	yes	
VB 5 1050	.68		326.4	11.7	6.95	37	yes	
VB 6 0935	.66		316.8	10.0	6.92	37	yes	
VB 7 1032	.66		316.8	8.9	6.95	49	yes	
MS 8 1026	.65		312	10	6.98	37	yes	
NM 9 1015	.62		297.6	9.4	6.87	49	yes	
VB 10 1010	.63		302.4	10.0	6.90	37	yes	
KP 11 1033	.56		268.8	10.6	6.95	36	yes	
KP 12 0946	.55		264	14.4	6.93	36	yes	
VB 13 1010	.55		264	11.1	6.91	36	yes	
VB 14 0950	.53		254.4	11.7	6.95	36	yes	
NM 15 1130	.51		244.8	8.9	6.87	39	yes	
NM 16 1050	.57		273.6	10.6	6.89	35	yes	
VB 17 1005	.59		283.2	10.6	7.00	36	yes	
VB 18 1032	.63		302.4	10.0	6.90	37	yes	
VB 19 1104	.69		331.2	10.6	6.81	37	yes	
KU 20 0930	.70		336	9.4	6.86	49	yes	
KP 21 0937	.67		321.6	8.9	6.96	49	yes	
MS 22 1055	.66		316.8	10	6.99	37	yes	
MS 23 1145	.79		379.2	10.6	6.97	37	yes	
VB 24 1020	.79		379.2	9.4	6.93	49	yes	
VB 25 0940	.71		340.8	9.4	6.94	49	yes	
VB 26 0923	.69		331.2	10.6	6.98	37	yes	
VB 27 0922	.62		297.6	9.4	7.00	49	yes	
VB 28 0944	.63		302.4	8.3	6.98	49	yes	
NM 29 1100	.62		297.6	8.3	6.90	49	yes	
NM 30 1021	.66		316.8	10.0	6.99	36	yes	
KP 31 0952	.71		340.8	10.0	7.04	44	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

WELL LOG: MONTHLY WATER REPORT

MONTH: January

YEAR: ~~2021~~ 2022

DATE	INT.	TIME	CL2	SITE	MIX	Meter	NOTES
1	BM	9:30	1.0	14		96369	61 25 ⁺³ 12.61
2	JT	10am				96486	12.93, 25 slight dip in graph, toilet running
3	JT	—	1.0	Shop		96486	Power out: Tank @ 11 feet, 2pm
4	Deb	10				96486	
5	Deb	11	1.0	DU		96486	
6	Deb	9				96486	
7	Deb	10	1.			96486	ON 7:40 p.m. 6.75
8	Deb	9	1.			96713	25 ¹
9	Deb	9	1			96778	dayuse on @ Noon power out again on @ 1:30
10	Deb	9	1	DU		96842	15 ⁻¹ running 13.21
11	Deb	9	1	DU		96880	10 ²⁺ 12.49
12	Be	9	1	02		96980	10 13.52
13	Be	8	1	38		96980	10 11.90
14	Deb	10				97082	5 ¹⁺ 12.76
15	Be	10:00	1	2	40/3	97182	0 ¹⁺ -43 13.55
16	Deb	11	1	2		97232	Running 40 ¹ 12.75
17	JT	9am				97294	35 ⁺³ 12.56
18	JT	9am	1	22		97394	35 ^{+1.5} 13.39
19	JT	9am				97400	running 11.92
20	JT	9am				97497	30 ⁺³ 12.73
21	Deb	10	1	sp		97598	30 ⁺ 13.56
22	Deb	11:05				97618	running 12.15
23	Deb	10 ⁰³	1	shop		97709	25 ² 12.56
24	Deb	1245				97813	25 ⁻ 13.21
25	Deb	11:12	1	DU		97849	Running 25 ⁻¹ 12.55
26	Be	11:15	1	3		97916	20 ⁺ 12.44
27	Be	8:30	1	02		98017	15 ⁰ 13.53
28	Be	8:15	1	2		98066	15 ¹¹ running 12.86
29	Deb	244				98120	15 11.84
30	Deb	11:03	1	DU		98229	10 ¹⁺ 13.87
31	Deb	10:11				98229	10 ¹⁺ 12.52

Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A
SYSTEM NAME: Heceta Head State Park
SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N
Florence, OR 97439 MONTH/YEAR
PHONE: 541-547-3416

JAN 2022

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
1	BM	1.0	Cl 2	34286
2				
3	parobb			
4	" "			
5	" "			
6				
7	Be	1.0	mix 1g H ₂ O 36oz ch 3.1g	34404
8	Deb	1		34405
9	JT	3 cxt		34418
10	JT	1 cxt	3 gal - Cl ₂	34425
11	Be	1.0 cxt	3 gal ch	34431
12	Be	0.9 cxt	3 gal ch	34434
13	Be	0.8 cxt	3 gal ch	34436
14	Be	1	3 gal ch	34438
15				
16	JT	1 cxt		34440
17				
18	Be	1 cxt	2.9g ch	34450
19	Be	1 cxt	2.9g ch	34453
20	Be	1 cxt	2.8g ch	34455
21		0.2	2.8	34460
22	Be	0.2	2.8	34470
23	/			34475
24				
25				
26	Be	0.6	2.5g	34495
27	Be	0.2	2.5g	34505
28	Be	0.3	2.2g	34508
29	Deb	1.5	cxt	
30	Deb	1.5	cxt	
31	JT	3 cxt		34531

Total: _____
Write off when not producing water.

Total -- # days=monthly average

--- =