

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration

Month/Year: Apr 11 2022

System Name:	OPRD JM Honeyman Memorial State Park		ID#: 41	91044		WTP: TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	—	0.04	0.04	—	0.03	0.03	0.04
2	—	0.01	0.03	—	0.04	0.08	0.03 0.04 VB
3	—	—	0.08	—	—	0.08	0.08
4	—	—	0.08	0.04	—	—	0.08
5	0.04	—	—	0.04	—	0.04	0.04
6	—	—	0.04	—	0.04	—	0.04
7	—	—	0.04	—	0.04	—	0.04
8	—	0.04	—	0.04	—	—	0.04
9	0.04	—	—	0.055	—	0.06	0.06
10	—	—	0.08	—	—	0.07	0.08
11	—	—	0.08	—	0.055	—	0.08
12	—	—	0.05	—	0.06	—	0.06
13	—	0.06	0.06	—	0.07	0.06	0.07
14	—	—	0.06	0.06	—	0.05	0.06
15	0.06	—	—	0.065	—	—	0.065
16	0.07	—	—	0.075	0.03	0.04	0.075
17	—	—	0.035	—	0.12	0.11	0.12
18	—	—	0.11	0.05	—	0.04	0.11
19	0.06	—	0.06	0.09	—	0.11	0.11
20	0.12	—	—	0.06	—	—	0.12
21	0.06	—	—	0.09	0.1	—	0.1
22	0.1	—	—	0.07	0.085	—	0.1
23	0.06	—	—	0.14	0.13	—	0.14
24	—	0.18	—	0.14	0.12	—	0.18
25	—	0.2	—	0.08	0.08	—	0.2
26	—	0.08	—	—	0.08	—	0.08
27	—	—	0.09	0.08	—	0.045	0.09
28	—	—	0.06	0.06	—	—	0.06
29	0.1	—	0.06	0.06	0.04	—	0.06
30	—	0.04	—	—	0.08	0.09	0.09
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Randy Copsey

SIGNATURE: *[Signature]* DATE: 4/11/2022

PHONE #: 541-997-3851 CERT #:

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year: April 2022

Disinfection Giardia Log Inactive:

0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
HE 1 1059	0.62	480	297.6	12.2	6.75	37	yes	98
HE 2 1142	0.75	}	360	12.8	6.76	36	yes	
HE 3 1140	0.77		369.6	12.2	6.76	37	yes	
KB 4 0935	0.76		364.8	11.7	6.74	37	yes	
HE 5 1439	0.69		331.2	12.2	6.72	37	yes	
LB 6 1430	.61		292.8	14.4	6.77	37	yes	
AK 7 1030	.67		321.6	12.8	6.69	37	yes	
MS 8 1005	.26		124.8	12.8	6.76	35	yes	
LB 9 1435	.54		259.2	12.8	6.79	36	yes	
LB 10 1515	.57		273.6	13.9	6.82	36	yes	
ZB 11 0445	.54		259.2	11.1	6.81	36	yes	
MS 12 1235	.53		254.4	11.7	6.83	36	yes	
NM 13 9:34	.59		283.2	11.1	6.71	36	yes	
KB 14 0923	.58		278.4	11.1	6.87	36	yes	
KB 15 0950	.56		268.8	11.1	6.82	36	yes	
MS 16 1220	.53		254.4	11.1	6.82	36	yes	
MS 17 1430	.60		288	13.3	6.77	36	yes	
KB 18 1010	.60		288	11.7	6.77	36	yes	
KB 19 0940	.57		273.6	11.1	6.81	36	yes	
KB 20 1025	.45		216	11.1	6.81	36	yes	
KB 21 1040	.42		201.6	11.7	6.84	36	yes	
LB 22 0940	.47		225.6	12.2	6.85	36	yes	
MS 23 1206	.48		230.4	11.7	6.83	36	yes	
24	.65		312	12.8	6.88	37	yes	
KB 25 1045	.61		292.8	13.9	6.90	37	yes	
KB 26 0950	.59		283.2	12.8	6.82	36	yes	
HE 27 1159	.61		292.8	13.3	6.84	37	yes	
HE 28 1150	.57		249.6	13.9	6.91	HE 27 36	yes	
NM 29 9:41	.66		316.8	12.8	6.90	36	yes	
MS 30 1258	.60		288	13.3	6.32	30	yes	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us, 971-673-0694, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Month/Year: April 2022

## Turbidity - Raw and Filter

Date	Filter	Raw	On	Off
1		0.47		X
2		0.51		X
3		0.46		X
4		.92	✓	
5		0.54		X
6		0.57		X
7		.56		✓
8		.55	✓	
9		.58	✓	
10		.72		✓
11		.53		X
12		.53		X
13		.66	✓	
14		.55	✓	
15		.66	✓	
16		.68	✓	
17		.69		
18		.78	✓	
19		.64	✓	
20		.60	✓	
21		.55	✓	
22		.61		✓
23		.80	✓	
24		.70	✓	
25		.74		✓
26		1.08		✓
27		0.83	✓	
28		1.30	✓	
29		1.21		✓
30		1.05	✓	
31				





# Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A  
SYSTEM NAME: Heceta Head State Park  
SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N  
Florence, OR 97439 MONTH/YEAR  
PHONE: 541-547-3416

April  
2022

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
				34975
1 9	Deb	.1		
2	Deb	.1		
3 9am	JT	.6 ext		34997
4 9am	JT	.6 ext	1.5 gal. Cl <sub>2</sub>	35008
5 9:15	Be	.4	mix 38oz cl <sub>2</sub> x 1/2 hr 29g bucket	35013
6	JT	0.6		
7 9:15	Be	0.8	2.5g ch	35031
8 9:20	Be	0.8	2.5g ch	35034
9	Deb	1		
10	JT	1.0		
11	BM	1.2	2.2 gal cl <sub>2</sub>	35057
12	Be	1.0	2.1 g ch	35058
13	Be	1.1	2.1g ch	35060
14	Be	1.0		
15	Be	1.0	2.0g ch	35064
16	Be	1.0	2.0	35066
17	JT	1 ext		35073
18	BM	1.0	2.0 cl <sub>2</sub>	35073
19	Be	1.0	2.0 ch	35077
20	Deb	1		
21	Be	1.0	2.0	35080
22	BM	1.0	2.0	35087
23	Deb	1		
24	JT	1 ext		35102
25	JT	1 ext		35111
26	Deb	.5 CRT		35111
27	BM	.5 CRT	2.0	35112
28	Be	.7 ext	2.75, mix 18oz cl <sub>2</sub> 1/2 hr	35118
29	Deb	.7 CRT		35120
30	Deb	.7 "		35125
31				

Total: \_\_\_\_\_  
Write off when not producing water.

Total -- # days=monthly average

--- =

## WELL LOG: MONTHLY WATER REPORT

MONTH:

April

YEAR:

2022

DATE	INT.	TIME	CL2	SITE	MIX	Meter	NOTES
1	Be	1200				102083	11.99 20
2	Be	900	1	DV		102183	13.50 15 <sup>+</sup>
3	Deb					102183	11.83 3.5 Run 15 <sup>-2</sup>
4	Deb	10	1	D2		102279	13.29 4hr Run 15 <sup>-</sup>
5	Be	745	1	2		102279	12.23 15 <sup>-</sup>
6	JT	10am	1	45		102376	13.40 10 <sup>+1</sup>
7	JT	10am				102376	12-13 10 <sup>+1</sup>
8	Deb	934	1			102474	13.44 4hr Run 52 <sup>+</sup>
9	Be	1000	1	77		102474	11.98 5 <sup>+</sup>
10	JT	9am				102572	13.30 5 <sup>-</sup>
11	JT	9am	1	73		102572	12.04 5 <sup>-</sup>
12	JT	11am				102668	13.33 (filled tank) 40 <sup>+2</sup>
13	JT	9am				102667	12.33 40 <sup>+2</sup>
14	Be	710	1	03		102763	13.64 40
15	Be	945	1	2		102763	12.30 40
16	Be	950	1	2		102859	13.53 35 <sup>+</sup>
17	JT	11am				102859	11.99 35 <sup>+</sup>
18	JT	9am	1	22		102957	13.41 30 <sup>+3</sup>
19	JT	9am				102957	12.20 Power Out Briefly 30 <sup>+3</sup>
20	JT	9am	1	30		103051	13.64 30 <sup>+</sup>
21	JT	9am				103051	12.44 30 <sup>+</sup>
22	Be	920	1	77		103144	13.71 25 <sup>+2</sup>
23	Be	950	1	2		103144	11.95
24	Deb	242				103248	12.57 25 <sup>-</sup>
25	Deb	1245	1	2		103298	12.02 only ran 1.5 hrs 25 <sup>-</sup>
26	Deb					103273	
27	Be	1208	1	3		103368	12.04 20 <sup>+</sup>
28	Deb					103368	
29	Be	100	0.9	2		103468	11.98 15 <sup>+</sup>
30	Be	930	1	5		103567	13.23 15 <sup>-</sup>
31							