

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration


Month/Year: June 2022

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 91044 WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	.18	—	—	.12	.16	—	.18
2	.15	.24	<del>.20</del> .20	.28	.19	—	.28
3	—	.15	—	.23	.14	—	.23
4	—	.16	—	—	.25	—	.25
5	.17	—	—	.17	.15	—	.17
6	—	.18	—	—	<del>.08</del> .06	—	.18
7	—	.05	—	—	—	—	.05
8	—	—	—	—	.16	—	.16
9	—	—	—	.12	.18	—	.18
10	—	—	.13	.10	.10	.18	.18
11	—	—	.17	.11	.10	.5	.5
12	—	—	.12	.09	.11	.14	.14
13	—	—	.15	.25	.33	.39	.39
14	—	—	.22	.22	.23	.29	.29
15	—	—	.17	.16	.22	—	.22
16	—	—	—	.21	.15	.26	.26
17	—	—	—	.24	.14	.17	.24
18	.22	—	.22	.24	.2	.24	.24
19	—	—	.19	.26	.08	.16	.26
20	—	—	.06	0.06	0.05	0.06	0.06
21	—	—	0.06	0.07	.06	.05	.07
22	—	—	.04	.04	.11	.11	.11
23	—	—	<del>.08</del> .10	.11	.05	.06	.11
24	—	—	.04	.06	.06	.07	.07
25	.09	—	.07	.08	.09	.10	.10
26	.12	.13	—	.08	.09	.09	.13
27	.09	.09	—	.08	.08	.08	.09
28	—	—	.06	.08	.08	.07	.08
29	—	—	.06	.07	.06	—	.07
30	—	.04	.05	—	.07	.07	.07

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="checkbox"/> Yes / No		

Notes: inline turbidimeter lamp failure on 06/07/2022  
 Turbidimeter back online 06/17/2022

PRINTED NAME: Kati A. Baker  
 SIGNATURE:   
 DATE: 7/1/22  
 PHONE #: (541) 997 3851  
 CERT #:

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))



OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year: June 2012

Disinfection Giardia Log Inactive:

0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T) × 480	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
VB 11135	.50	480	240	14.4	6.21	30	yes	90
VB 21200	.51	}	244.8	15.0	6.20	20	yes	}
VB 31305	.51		244.8	15.0	6.15	20	yes	
VB 41800	.60		288	15.6	6.22	20	yes	
VB 51405	.59		283.2	15.0	6.12	20	yes	
AL 6430	.56		268.8	15.0	6.07	20	yes	
AL 71225	.64		307.2	15.0	6.13	20	yes	
VB 81545	.71		340.8	15.6	6.21	20	yes	
VB 91440	.75		360	16.1	6.19	20	yes	
VB 101330	.73		350.4	15.6	6.17	20	yes	
VB 111230	.76		364.8	15.6	6.21	20	yes	
AL 120910	.76		364.8	15.6	6.05	20	yes	
AL 130950	.69		331.2	15.6	6.10	20	yes	
AL 141020	.70		336	15.6	6.11	20	yes	
AL 150910	.68		326.4	15.6	6.14	20	yes	
VB 161210	.63		302.4	15.6	6.22	20	yes	
VB 171415	.66		316.8	16.1	6.24	20	yes	
VB 181330	.74		355.2	16.7	6.16	20	yes	
VB 191220	.69		331.2	16.7	6.16	20	yes	
AL 200940	.60		288	16.7	6.14	20	yes	
HE 211510	0.67		321.6	17.8	6.25	20	yes	
VB 221150	.74	355.2	16.7	6.19	20	yes		
VB 231220	.75	360	16.7	6.07	20	yes		
AL 240930	.71	340.8	16.7	6.09	20	yes		
AL 25410	.66	316.8	17.2	6.14	20	yes		
VB 261030	.71	340.8	17.8	6.15	20	yes		
AW 27930	.69	331.2	16.6	6.18	20	yes		
AL 281015	.55	268.8	17.8	6.10	20	yes		
VB 291250	.52	249.6	17.8	6.21	20	yes		
VB 301345	.45	216	17.2	6.19	20	yes		
31								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us, 971-673-0694, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350









Month/Year: June 2022

## Turbidity - Raw and Filter

Date	Filter	Raw	On	Off
1		.96	✓	
2		.86	✓	
3		.85	✓	
4		1.79		✓
5		.79	✓	
6		.84		✓
7		.81		✓
8		.76		✓
9		.69	✓	
10		.84	✓	
11		.56	✓	
12		.67	✓	
13		.81	✓	
14		.63	✓	
15		.69	✓	
16		1.00	✓	
17		.52	✓	
18		.62	✓	
19		.47		✓
20		.45	✓	
21		0.68	✓	
22		.62	✓	
23		.54	✓	
24		.49	✓	
25		.51	✓	
26		.49	✓	
27		.48		✓
28		.40	✓	
29		.45	✓	
30		.77	✓	
<del>31</del>				



WELL LOG: MONTHLY WATER REPORT

on top of 5

MONTH: June							YEAR: 2022	
DATE	INT.	TIME	CL2	SITE	MIX	Meter	NOTES	
1	BM	8:45	1	72	/	12.81	CL <sup>+</sup> Filled c/2 to 40	
2	BC	1100	1	71	/	105398	45 <sup>+</sup> running 13.55	
3	DW	8:30	1.1	D2	/	105418	45 <sup>+</sup> 12.89	
4	BC	9:15			/	105503	40 <sup>+</sup> running 13.73	
5	ERA	9:20	1.0	03	/	105516	40 <sup>+</sup> 12.64	
6	DW	8:30	1.1	8	/	105561	40 <sup>+</sup> 13.53	
7	BC	3:50pm	1.0	02	/	105679	35 <sup>+</sup> running 13.25	
8	BC	9:15	1	8	/	105714	35 <sup>+</sup> 13.07	
9	DW	8:30	.5	D1	/	105781	35 <sup>+</sup> 13.26	
10	DW	8:15	1	2	/	105830	35 <sup>+</sup> 13.01	
11	DW	8:50	.7	D2	/	105914	30 <sup>+</sup> running 13.70	
12	DW	8:40	1.0	2	/	105919	30 <sup>+</sup> 11.80	
13	DW	8:50	.8	2	/	106038	25 <sup>+</sup> alarm flashing 13.29	
14	BC		1	3	/	106121	25 <sup>+</sup> alarm flashing running 13.73	
15	BC	9:30	1	3	/	106147	25 12.69	
16	BC	9:30	1	71	/	106241	20 <sup>+</sup> 13.69	
17	BC	9:30	1	71	/	106241	20 <sup>+</sup> 11.81	
18	DW				/	106346		
19	DW	10:30am			/	106438	15 <sup>+</sup> 12.99	
20	DW	10:30am	1	W01	/	106441	15 <sup>+</sup> running 11.81	
21	DE	2:50	1	02	/	106544	10 <sup>+</sup> 12.40	
22	BC	10:30	0.8	02	/	106664	10 <sup>+</sup> running 12.22	
23	not sure how we missed this						22nd BE	<del>12.82</del>
24	BE	9:15	1.0	02	/	106748	5 <sup>+</sup> 12.82	
25	BC	12:30	1.0	02	/	106849	5 <sup>+</sup> 13.14	
26	JT	1pm			40/3	106967	2 <sup>+</sup> 3 1/2 hr run 13.98	
27	Deb	1pm	1	46	/	106967	40 <sup>+</sup> seal 12.12	
28	BC	10	76	1	/	107071	40 13.35	
29					/			
30	BC	9:50am	1.2	01	/	107177	35 <sup>+</sup> 12.64	
31					/			

# Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A

SYSTEM NAME: Heceta Head State Park

SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N

Florence, OR 97439

MONTH/YEAR

PHONE: 541-547-3416

JRM  
2014

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
1				
2 9am	DW	.9		
3 8am	Be	.9	2g dz	35292
4 8am	DW	.9	2g	35293
5 ?				
6 10am	JT	1 ext		35299
7 10am	JT	1 ext		35306
8 10am	JT	1 ext		35311
9 10am	JT	1 ext		35315
10 8:30	Be	8.07	mix 1/2 the 18oz ctz 2.75g bucket	35332
11 8:00	DW	.6	2.5g	35336
12 7:00	DW	.8	2.5g	35337
13 ?				
14 4:30 am	JT	1 ext		35343
15 4:30 am	BM	1 ext	2.5g	35346
16 1:30	BM	1 ext	2.5g	35310
17				
18 7:00	JT	1 ext		35350
19 9am	JT	1 ext		35355
20 2pm	JT	1 ext		35357
21 Noon	JT	1 ext		35368
22 8am	Be	0.7	2.2g	35369
23 10am	JT	1 ext		35374
24 10:45	DW	8 ext	2	35378
25 8am	Be	1 ext	2	35390
26 9am	JT	1 ext		35407
27 11:06	ZIW	1 ext	2	35411
28 10am	JT	1 ext	mix 18oz ctz 1/2 the bucket 2.8g	35415
29 10am	JT	1 ext		35419
30 10am	JT	1 ext		35425
31				

Total: \_\_\_\_\_  
Write off when not producing water.

Total -- # days=monthly average

\_\_\_\_\_ = \_\_\_\_\_