

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration

Month/Year: Sept 2012

System Name:	OPRD JM Honeyman Memorial State Park		ID#: 41	91044			WTP: TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	<del>.17</del>	.16	-	.17	.17	-	.17	
2	-	.17	-	.15	.17	-	.17	
3	.17	-	-	.17	.05	.04	.17	
4	.04	-	-	.04	.04	.04	.04	
5	.05	-	-	.08	.12	-	.12	
6	-	.12	-	.04	.18	-	.18	
7	-	-	.20	-	.10	.19	.20	
8	-	-	-	.09	-	-	.09	
9	-	.14	-	-	.18	-	.18	
10	-	.08	-	.09	.16	-	.16	
11	-	.14 <sup>20</sup>	.1	-	<del>.13</del> .16	-	.16	
12	-	.14	-	-	.4	-	.40	
13	-	.04	.39	.05	-	-	.39	
14	-	.04	.04	-	.04	.04	.04	
15	-	-	-	.05	.05	-	.05	
16	-	-	.04	-	.05	-	.05	
17	-	-	.04	.05	-	<del>.05</del> .06	.06	
18	.05	-	-	.05	.05	.05	.05	
19	-	-	-	.07	-	-	.07	
20	-	.12	-	-	.06	-	.12	
21	-	-	.06	-	-	.11	.11	
22	-	-	-	.07	.11	-	.11	
23	-	-	.14	-	-	-	.14	
24	-	0.08	-	<del>.07</del> .06	.06	-	.08	
25	-	-	.06	-	.11	.06	.11	
26	-	-	-	.02	.02	-	.02	
27	-	-	.02	-	-	.02	.02	
28	-	-	-	.03	.03	-	.03	
29	-	-	.04	.02	.02	-	.04	
30	-	-	.03	-	-	.02	.02	
X								

<p>Conventional or Direct Filtration</p> <p>95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No</p> <p>All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No</p> <p>All turbidity readings &lt; IFE<sup>2</sup> triggers <input checked="" type="radio"/> Yes / No</p>		<p>Monthly Summary (Answer Yes or No)</p> <p>CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No</p> <p>All Cl<sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No</p>	
<p>Notes: Alum pump was not firmly plugged in 9/12 to 9/13 causing spike in turbidity.</p>		<p>PRINTED NAME: <u>Ryan Warren</u></p> <p>SIGNATURE: <u>[Signature]</u></p> <p>PHONE #: <u>(541) 997-3851</u></p> <p>DATE: <u>10-4-22</u></p> <p>CERT #:</p>	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum <sup>2</sup> IFE = Individ. Filter Effl (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 91044 Month/Year: *Sept 2022* Disinfection *Giardia* Log Inactive: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
<i>KW</i> 1:550	.90	480	432	18.9	6.24	21	yes	98
<i>ML</i> 2:0440	.74	(Large bracket spanning rows 2-21)	355.2	18.3	6.15	20	yes	(Large bracket spanning rows 2-21)
<i>ML</i> 3:1435	.70		336	20.0	6.15	15	yes	
<i>ML</i> 4:0920	.77		369.6	19.4	6.15	20	yes	
<i>ML</i> 5:1005	.79		379.2	19.4	6.16	20	yes	
<i>ML</i> 6:1805	.74		355.2	19.4	6.39	20	yes	
<i>ML</i> 7:345	.77		369.6	19.4	6.34	20	yes	
<i>KB</i> 8:0945	.68		326.4	18.9	6.24	20	yes	
<i>ML</i> 9:1140	.60		288	18.3	6.18	20	yes	
<i>LB</i> 10:1620	.39		187.2	19.4	6.26	20	yes	
<i>KB</i> 11:1655	.52		249.6	19.4	6.25	20	yes	
<i>KB</i> 12:1005	.48		230.4	18.3	6.21	20	yes	
<i>KB</i> 13:0925	.47		225.6	19.4	6.24	20	yes	
<i>KB</i> 14:1325	.44		211.2	17.8	6.25	20	yes	
<i>KB</i> 15:1105	.47		225.6	18.9	6.28	20	yes	
<i>KB</i> 16:1320	.54		259.2	18.3	6.32	20	yes	
<i>LB</i> 17:1640	.61		292.8	18.3	6.26	20	yes	
<i>LB</i> 18:1630	.74		355.2	19.4	6.25	20	yes	
<i>KB</i> 19:1077	.71		340.8	18.3	6.23	20	yes	
<i>KB</i> 20:0918	.64		307.2	17.8	6.23	20	yes	
<i>KB</i> 21:1127	.59		283.2	18.3	6.22	20	yes	
<i>KB</i> 22:1020	.52	249.6	17.2	6.19	20	yes		
<i>MS</i> 23:1045	.56	268.8	18.3	6.3	20	yes		
<i>ZB</i> 24:1525	.45	216	18.1	6.5	20	yes		
<i>LB</i> 25:1715	.48	230.4	18.9	6.19	20	yes		
<i>KB</i> 26:1056	.50	240	18.3	6.23	20	yes		
<i>KB</i> 27:1020	.58	278.4	18.3	6.20	20	yes		
<i>KB</i> 28:1015	.58	278.4	16.7	6.23	20	yes		
<i>KB</i> 29:1044	.58	278.4	17.8	6.20	20	yes		
<i>KB</i> 30:152	.62	297.6	17.8	6.12	20	yes		

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp\_dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350





Month/Year: Sept 2022

# Turbidity - Raw and Filter

Date	Filter	Raw	On	Off	
1		.63		✓	
2		.56		✓	
3		.80	✓		
4		.75	✓		
5		.75	✓		
6		<del>.84</del> .84			✓
7		.72	✓		
8		.75	✓		
9		.59			✓
10		.81	✓		
11		.80	✓		
12		.65			✓
13		.68	✓		
14		.56			✓
15		.79	✓		
16		.53			✓
17		.61			✓
18		.61			✓
19		<del>.70</del> .70	✓		
20		.64			✓
21		.63			✓
22		.63			✓
23		.61			✓
24		.78		X	
25		.67			X
26		.63	✓		<del>✓</del> KB
27		.57	✓		<del>✓</del> KB
28		.79			✓
29		.61	✓		
30		.55			✓
X					

**WELL LOG: MONTHLY WATER REPORT**

MONTH: *Sept*

YEAR: *2022*

DATE	INT.	TIME	CL2	SITE	MIX	Meter	NOTES
1	Be	900	1.1	33	/	111657	25 <sup>th</sup> - plant off clc pump issue wind plant on 10.81
2	Be	830			/	111826	20 <sup>th</sup> 13.67
3	Be	11	1.0	Shop	/	111848	20 <sup>th</sup> running 10000 gal to sp 12.17
4	Deb	1:26			/	111936	12.44
5	JT	10am			/	112038	20 13.5
6	Be	845	1	55	/	112043	20 running 11.86
7	BM	9:45	1	76	/	112151	20 12.82
8	BM	9:00	1	29	/	112244	15 <sup>th</sup> 13.70
9	Be	830	1	0V	/	112244	15 <sup>th</sup> 12.05
10	Be	11am	1	02	/	112347	10 <sup>th</sup> 12.75
11	JT	10am			/	112444	10 <sup>th</sup> 13.42
12	JH	08:00	.8	47	/	112479	.85 running 12.56
13	Be	1000	1	3	/	112552	5 <sup>th</sup> 12.34
14	Be	9	1	77	/	112649	5 <sup>th</sup> 17.63
15	Be	930	0.7 0.7	8 49	/	112655	5 <sup>th</sup> running starts empty 11.88
16	Be	915	0.7	72	/	112759	5 12.95
17	JH	0830	.8	72	/	112856	5 <sup>-1</sup> Just turned off 14.00
18	JT	8:30 am	.8	H/B	40/3	112856	43 gal 12.19 12.96 <sup>am</sup>
19	JT	10am			/	112964	40 <sup>th</sup> 13.03
20	JH	09:20	.6	CRR	/	113046	35 <sup>th</sup> +3 1/2 Plant on 13.62
21	JT	9am			/	113067	35 +3 12.55
22	JT	9am	.6	Shop	/	113167	35 <sup>th</sup> 13.49
23	JH	07:45	.2	DI	/	113167	35 <sup>th</sup> +14 resistor cap turned stroke up 11.93
24	Deb	5	.5 1.5	Pump house Rea	/	113273	35 Tightened to 47 top yellow cap - does not appear to be leaking may vibrate loose 12.19
25	Deb	630	.5	Shop	/	113366	30 <sup>2</sup>
26	JH	08:54	1.0	38	/	113366	30 <sup>2</sup> 12.03
27	JH	07:50	.8	CRR	/	113468	30 <sup>5</sup> 13.26
28	Be	11	.8	02	/	113515	30 running 12.69
29	Be	945	.8	3	/	113575	25 <sup>th</sup> ? 12.94
30	Deb	5			/	113678	25 <sup>th</sup> 13.60
31					/		

# Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A

SYSTEM NAME: Heceta Head State Park

SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N

Florence, OR 97439 MONTH/YEAR

PHONE: 541-547-3416

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
1 9am	JS	0.8	3.1	35748
2 8am	JS	0.6	3	35751
3 8am	JB	0.6	3	35758
4 8:30am	M.A	0.6	3	35768
5 8:30A	JH	.9		35787
6	de	.8	3 2.9	35788
7	BC	1.0	2.9	35789
8	de	1.0	2.9	35792
9 8am	JS	.9	2.8	35797
10 9:30	de	1.0	2.8	35798
11 8:15am	ERB	0.6	2.7	35802
12 07:50	JH	0.3	<del>2.6</del> 2.6	35808
13 07:55	JH	.2	2.6	35811
14 8:15am	ERB	0.3	2.6	35813
15 8am	JS	0.2	2.6	35816
16 8am	JS	0.6	2.5	35824
17 8am	JS	0.6	2.5	35836
18 8am	JS	0.7	2.3	35850
19 08:05	JH	0.5	2.3	35856
20 <del>8am</del>	?			
21 9am	JT	.5	2.2	35866
22 8am	JS	0.5	2.1	35868
23 07:30	JH	.2	2.1	35874
24 8am	JS	0.4	2.1 added 3/2oz (1 qt H <sub>2</sub> O)	35883
25 8am	JS	0.6	3.1	35895
26 08:32	JH	.5	3.2	35898
27				
28				
29 8am	JS	0.6	3.1	<del>35897</del> 35907
30 8am	JS	0.6	3.1	35915
31				

Total: \_\_\_\_\_  
Write off when not producing water.

Total -- # days=monthly average

\_\_\_\_\_ = \_\_\_\_\_