

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration

Month/Year: Nov 2022

System Name:	OPRD JM Honeyman Memorial State Park		ID#: 41	91044			WTP: TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	—	—	—	—	—	—	—	
2	—	—	—	—	.03	—	.03	
3	—	.04	.06	—	.08	08 .12	.12	
4	—	—	.17	0.15	—	—	.17	
5	—	0.08	—	—	0.05	—	.08	
6	—	—	0.1	—	—	.08	.10	
7	—	—	.12	0.05	—	—	0.12	
8	0.1	—	—	.08	.07	—	.10	
9	—	.12	.12	—	.03	.03	.12	
10	—	—	.03	.04	—	—	.04	
11	.06	.08	—	.02	.01	—	.08	
12	—	—	.01	—	0.01	0.01	0.01	
13	—	—	0.01	.03	—	—	.03	
14	—	.04	—	—	—	.3	.3	
15	—	—	0.3 0.4	.05	—	—	0.4	
16	MS .1	—	—	—	.08	—	.10	
17	—	.12	.21	—	.09	—	.21	
18	—	.08	.22	—	.04	—	.22	
19	—	—	0.13	—	0.1	—	0.13	
20	—	—	0.2	—	.13	—	.2	
21	—	.15	.18	—	—	—	.18	
22	—	—	—	—	.03	.04	.04	
23	.04	.06	—	.04	.02	—	.06	
24	—	.02	.03	—	.03	.03	.03	
25	—	—	.03	.04	—	0.03	0.04	
26	—	—	—	.02	.01	—	.02	
27	—	.01	—	—	.02	—	.02	
28	—	—	0.03	—	—	0.08	0.08	
29	—	—	0.03 0.10	.06	—	—	.06	
30	—	.09	—	.06	—	—	0.09	
31	—	—	—	—	—	—	—	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes: Data logger malfunction 11/2, no 4 h- readings from 11/1 noon - 11/2 noon.		PRINTED NAME: Kati Baker	DATE: 12/1/22
		SIGNATURE: <i>[Signature]</i>	CERT #:
		PHONE #: (541) 997 3851	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year: Nov 2022

Disinfection Giardia
Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
KB 10935	1.04	480	499.2	15.0	6.13	21	yes	98
Mh 2 1030	0.90	}	432	14.4	6.23	26	yes	}
KB 31150	.83		398.4	13.9	6.22	31	yes	
KB 4103	.78		374.4	13.9	6.16	31	yes	
5	0.68		326.4	14.4	6.22	30	yes	
6	0.64		307.2	13.9	6.16	31	yes	
KB 70955	.63		302.4	13.9	6.37	31	yes	
HE 8 0947	0.65		312	12.8	6.13	31	yes	
KB 90946	.67		321.6	12.8	6.13	31	yes	
KB 10036	.66		316.8	12.8	6.11	31	yes	
LB 111100	.68		326.4	13.3	6.12	31	yes	
LB 121050	.73		350.4	12.8	6.43	31	yes	
HE 131001	0.72		345.6	12.8	6.18	31	yes	
KB 141130	.73		350.4	12.2	6.57	37	yes	
KB 151002	.69		331.2	12.2	6.14	31	yes	
My 16 1142	.60		288	13.3	6.09	30	yes	
KB 170948	.61		292.8	12.2	6.14	31	yes	
My 18 1002	.54		259.2	14.4	6.12	30	yes	
My 19 1010	.58		278.4	11.7	6.29	30	yes	
My 20 1020	.65		312	12.2	6.13	31	yes	
KB 211115	.64		307.2	11.7	6.16	31	yes	
KB 220943	.59		283.2	12.2	6.21	30	yes	
KB 230948	.61		292.8	12.2	6.12	31	yes	
LB 241100	.58		278.4	12.2	6.15	30	yes	
LB 251300	.64		307.2	12.2	6.44	31	yes	
HE 261143	0.66		316.8	11.1	6.10	31	yes	
My 27 1010	0.75		360	11.1	6.18	31	yes	
KB 28 1110	0.82		393.6	11.7	6.25	31	yes	
HE 29 1020	0.68		326.4	11.1	6.27	31	yes	
ZB 30 0945	0.78		374.4	11.1	6.31	31	yes	
X	0.							

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp_dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Month/Year: November 2012

Turbidity - Raw and Filter

Date	Filter	Raw	On	Off
1		.87	✓	
2		.75		✓
3		.70		✓
4		.73	✓	
5		0.83	✓	
6		0.87		✓
7		.68	✓	
8		0.76		✓
9		0.71		✓
10		0.70	✓	
11		0.77		✓
12		0.79		✓
13		0.77	✓	
14		0.71		✓
15		0.84	✓	
16		0.81		✓
17		0.68		✓
18		0.74		✓
19		1.26		
20		1.68, 1.12		✓
21				
22		1.17	✓	
23		.71		✓
24		.56		✓
25		.73		✓
26		0.66	✓	
27		0.67		✓
28		0.85		✓
29		0.71	✓	
30		.83		✓
31				

*intake line closed

Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A
SYSTEM NAME: Heceta Head State Park
SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N
Florence, OR 97439 MONTH/YEAR
PHONE: 541-547-3416 2022 Nov

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
08:05 1	JH	.8 CXT	2g	36062
836 2	Be	1.0 cxt	2g	36063
9am 3	JT	.7 cxt	2g	36068
8 4	Be	.8	2g	36069
915 5	Be	.7	2g	36070
830 6	Deb	1.5	2	36070
9:30 7	JT	.5	2	36070
9am 8	JT	.8		36074
815 9	Be	0.2		36075
9am 10	JT	.7		36084
8 11	Be	0.2	1.9g	36086
12	Be	0.2	1.9g	36095
8 15 13	Deb	2.0	cxt	36098
10am 14	JT	.9	cxt	36104
10am 15	JT	.5	cxt	36112
10am 16	JT	.5	cxt	36121
10am 17	JT	1	cxt	36130
18	Be	0.4 cxt	mix 18oz ch 1/2g the 2.25g	36131
8:45 19	JH	.4 cxt	2.2	36139
8 20	Deb	.4		36140
9 21	JT	.5	cxt	36155
9 22	JT	.5	cxt	36161
10:45 23	JH	.8 ←	cxt / At 2.0	36177
09:25 24	JH	.5 CXT	1.9g	36183
08:51 25	JH	.3 CXT	1.9	36187
07:45 26	JH	.3 CXT	1.9	36192
430 27	Deb	1.0 Pump		36192
10am 28	JT	.5 cxt		36217
10am 29	JT	.5 cxt		36221
30	Be	1.5 cxt		36222
31				

Total: _____
Write off when not producing water.

Total -- # days=monthly average

_____ = _____

Heceta needs c/2 + packets @ pump house

WELL LOG: MONTHLY WATER REPORT

MONTH: November

YEAR: 2022

DATE	INT.	TIME	CL2	SITE	MIX	Meter	NOTES
1	Be	115	0.7	3	/	115415	13.38 35 ^{HI}
2	Be	1030	1.0	13	/	115415	12.25 35 ^{HI}
3	Be	830	1.0	3	/	115509	13.74 35
4	De	1015	1.1	D2	/	115509	12.43 35
5	Be	930	1.0	2	/	115602	13.89 30 ^{FR}
6	JT	9am			/	115602	12.41 30 ⁺²
7	JT	9am	1	shop	/	115695	13.66 30
8	Be	11	1.1	9	/	115695	12.51 30
9	JT	9am			/	115788	13.81 25 ^{#3}
10	Deb	850			/	115788	12.65 25 ³
11	DE	930	1.0	27	/	115881	13.83 25 ^{HI}
12	Be	930	1.0	49	/	115881	12.46 25 ^{HI}
13	JT	9am			/	115977	13.60 25
14	JT	9am			/	115977	12.26 25
15	Deb	1037			/	116071	13.58 25 ⁻¹
16	Deb	1023	1.0	2	/	116071	12.27 25 ⁻¹
17	Be	900	1.0	52	/	116169	13.62 20 ^{HI}
18	Be	830	1.0	2	/	116169	12.41 20 ^{HI}
19	Be		1.0	D2	/	116265	13.53 15 ^{HI}
20	JT	9am			/	116265	12.23 15 ⁺³
21	Deb	842	1	2	/	116362	13.53 15 ²
22	Be	930	1	26	/	116362	12.03 15 ^{FR}
23	Be	911	1	2	/	11645	13.95 15
24	JH	09:38	.6	D2	/	116458	11.98 15 ⁺⁵
25	JH	09:24	.8	2	/	116558	12.96 10 ^{+2.75}
26	JH	09:40	.7	shop	/	116608	12.87 10 ⁺² Plant on
27	Deb	830	.7	Res	/	116660	12.96 10 ⁻¹
28	JT	9am			/	116726	13.26 running 10
29	Deb	12	.7	28	/	116757	12.59 10 ⁻¹
30	Deb	830			/	116803	12.85 running 5 ²⁺ cl ² EXT. 7 while running
31					/		