

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration

Month/Year: Feb/2024

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 91044

WTP : TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	-	-	0.09	0.1	-	-	0.1
2	-	-	0.1	-	-	0.01	0.1
3	0.01	-	-	-	-	-	0.01
4	-	-	-	0.2	0.01	0.01	0.2
5	0.5 <sup>nm</sup> 0.01	0.01	0.01	0.02	0.01	0.01	0.02
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.03	0.01	-	-	0.02	0.03	0.03
8	0.03	0.03	0.03	0.01	0.01	-	0.03
9	-	-	-	0.01	-	-	0.01
10	-	-	0.01	0.01	-	-	0.01
11	-	-	0.01	0.04	0.04	-	0.04
12	-	-	0.05	0.01	-	-	0.05
13	-	-	0.02	-	-	-	0.02
14	0.01	-	-	0.01	-	-	0.01
15	-	-	0.01	0.01	-	-	0.01
16	-	-	0.01	0.01	-	-	0.01
17	-	-	0.01	0.01	-	-	0.01
18	-	-	0.01	0.01	-	-	0.01
19	-	-	0.01	-	-	0.01	0.01
20	-	-	-	0.01	0.01	-	0.01
21	-	-	0.01	0.01	0.01	-	0.01
22	-	-	0.01	0.01	-	-	0.01
23	0.01	-	-	-	-	-	0.01
24	0.01	-	-	-	-	-	0.01
25	0.01	-	-	-	-	0.01	0.01
26	0.01	-	-	0.01	0.01	-	0.01
27	-	-	0.02	0.01	-	-	0.02
28	-	0.01	0.01	0.01	-	0.01	0.01
29	-	-	0.01	-	-	-	0.01
30	-	-	-	-	-	-	-
31	-	-	-	-	-	-	-

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		
Notes: Plant malfunction 2/3 @ Noon - 2/4 @ Noon	PRINTED NAME: Nathan Micha	DATE: 3-1-24
	SIGNATURE: Nathan Micha	CERT #:
	PHONE #: (541) 999-5615	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year:

Disinfection Giardia  
Log Inactive:

0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
HE 1 10:51	0.86	480	412.8	10.0	7.34	45	yes	98
NM 2 9:53	0.80		304	10.0	7.74	53	yes	
LB 3 10:50	0.85		408	9.4	6.54	49	yes	
PD 4 11:38	0.73		350.4	9.4	7.23	58	yes	
NM 5 11:10	0.66		316.8	9.4	7.28	57	yes	
NM 6 11:08	0.62		297.6	9.4	7.55	68	yes	
NM 7 10:01	0.70		336	8.9	7.76	68	yes	
NM 8 11:01	0.63		302.4	8.9	7.42	57	yes	
NM 9 9:27	0.72		345.6	8.9	7.88	68	yes	
DC 10 11:45	0.91		436.8	8.9	7.94	70	YES	
DC 11 11:30	0.76		364.8	8.9	7.64	68	YES	
NM 12 10:10	0.93		446.4	9.4	6.89	64	yes	
LB 13 10:50	0.90		432	9.4	7.78	72	yes	
NM 14 9:31	0.95		456	8.9	7.83	70	yes	
NM 15 10:32	1.03		494.4	8.9	7.85	72	yes	
NM 16 9:32	0.90		432	8.9	7.86	70	yes	
DC 17 12:14	0.65		312	8.9	7.79	68	YES	
DC 18 9:47	0.93		446.4	8.9	7.67	70	YES	
LB 19 11:20	0.98		470.4	9.4	7.72	72	yes	
HE 20 10:2	1.04		499.2	9.4	7.55	74	yes	
NM 21 10:35	1.05		504	9.4	7.75	72	yes	
NM 22 9:34	1.19		571.2	8.9	7.60	72	yes	
NM 23 9:24	1.07		513.6	8.9	7.89	72	yes	
DC 24 11:00	0.91		436.8	9.4	7.54	70	YES	
DC 25 10:44	1.01		484.8	9.4	7.51	72	YES	
NM 26 12:01	1.16		528	9.4	7.75	72	yes	
NM 27 9:50	1.00		480	8.9	7.69	72	yes	
LB 28 13:20	0.67		321.6	10.0	7.15	44	yes	
NM 29 9:50	0.90		432	9.4	7.56	70	yes	
30								
31								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
dwp\_dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

# Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of February, 20 24

DATE	Water Plant Effluent Chloride						Distribution System		
	12 a.m.	4 a.m.	8 a.m.	12 p.m.	4 p.m.	8 p.m.	H Sec	Cleawox	E Woahink
1	—	—	0.6	1.75	—	—	0.86	1.25	0.57
2	—	—	1.6	—	—	1.2	0.80	1.17	0.59
3	1.1	—	—	—	—	—	0.85	1.17	0.58
4	—	—	—	0.56	0.54	0.75	0.73	1.18	0.59
5	0.45	0.5	0.5	0.45	0.63	0.50	0.66	1.32	0.49
6	0.45	0.40	0.62	0.73	0.72	0.68	0.62	1.11	0.39
7	0.63	0.61	—	—	0.52	0.49	0.70	1.07	0.54
8	0.49	0.48	0.49	1.17	1.75	—	0.63	0.51	0.33
9	—	—	—	2.0	0	—	0.72	0.54	0.40
10	—	—	2.0	<del>2.0</del> 2	—	—	0.91	0.50	0.43
11	—	—	2	0.95	0.97	—	0.76	0.45	0.35
12	—	—	0.95	0.82	—	—	0.93	0.44	0.39
13	—	—	0.8	—	—	—	0.90	0.37	0.37
14	0.75	—	—	0.95	—	—	0.95	0.56	0.33
15	0.75	—	0.88	0.90	—	—	1.03	0.62	0.52
16	—	—	0.89	0.70	—	—	0.90	0.38	0.50
17	—	—	0.82	0.85	—	—	0.65	0.30	0.40
18	—	—	0.88	0.90	—	—	0.93	0.30	0.55
19	—	—	0.75	—	—	0.90	0.98	0.32	0.69
20	—	—	—	0.78	0.76	—	1.04	0.36	0.84
21	—	—	0.67	0.75	0.80	—	1.05	0.30	0.68
22	—	—	0.90	0.85	—	—	1.19	0.34	0.72
23	0.70	—	—	—	—	—	1.07	0.34	0.72
24	0.70	—	—	—	—	—	0.91	0.29	0.72
25	0.71	—	—	—	—	0.65	1.01	0.24	0.85
26	0.55	—	—	1.00	0.90	—	1.10	0.23	0.86
27	—	—	0.82	0.8	—	—	1.20	0.23	0.78
28	—	0.79	0.67	0.8	—	0.75	0.67	0.16	0.82
29	—	—	0.65	—	—	—	0.90	0.20	0.82
30	-----								
31	-----								



# Raw Turbidity

Month/Year February

2024

Date	Raw Turbidity Reading	Plant On	Plant Off
1	0.57	✓	
2	0.55		✓
3	0.83		✓
4	.55		✓
5	0.46	X	
6	0.56	X	
7	0.65		X
8	0.62	X	
9	0.85		X
10	0.51		X
11	0.74		X
12	0.51	X	
13	0.45		X
14	0.76		X
15	0.47	X	
16	0.45		X
17	0.75		✓
18	0.58	X	
19	0.49		✓
20	0.66		X
21	0.46	X	
22	0.47	X	
23	0.65		X
24	0.43	X	
25	0.50		X
26	0.69		X
27	0.72	X	
28	0.53	✓	
29	0.48	X	
30			
31			

**WELL LOG: MONTHLY WATER REPORT**

MONTH: Feb

143236

YEAR: 2021

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	Deb	1104	1	1	/	143298	10 <sup>+</sup>	13	48	1.5 ft	5	\$
2	Deb	1057			/	143298	10 <sup>+</sup>	12.48			5	scrubbed showers
3	Deb				/		10 <sup>-</sup>	13.25	44	1.5	5	
4	JT	9am			/	143358	10	12.33	40	1.5	5	
5	JT	9am	1	shop	/	143420	5 <sup>+</sup>	17.08			5	
6	Deb	1250			/	143420	5 <sup>3-</sup>	12.05	45	1.5	5	
7	JT	9am			/	143481	5 <sup>+</sup>	12.84			5	
8	Be	1015	1	3	/	143481	5 <sup>+</sup>	12.05	47 1/2	1.5	5	
9	Be	1000	1	5	/	143544	5 <sup>+</sup>	12.90			5	
10	Deb	1102			19.3	143567	5 <sup>+</sup>	12.35	46 1/2		4	14 sites for night
11	How	11:00			/	143610 <sup>3</sup>	19.3	12.5		?		
12	How	12:45			/	143671	18.5	13.2	45	61		
13	Deb	1234			/	143671	15 <sup>2+</sup>	12.27			5	
14	Be	1100	1	3	/	143732	15'	13.05			5	
15	Be	1000			/	143732	5'	12.24	47		5	
16					/	143793	15'	12.91			5	
17	Be	1130			/	143808	15	12.34				N/A
18	AL	4pm			/	143857	14.5	12.5				
19	HL	12:45			/	143918	13.5	13.1				
20	Be	845	1	02	/	143918	10 <sup>02</sup>	12.30	41		5	
21	Be	230			/	143980	10 <sup>+</sup>	12.80			4 1/2	
22	Deb	1129	1	D1	/	143980	10 <sup>+</sup>	12.09			4	
23	Be	1220			/	144042	10	12.63			5	
24	Deb	948			/	144104	10 <sup>-1</sup>	13.49				
25	HC	11:30			/	144104	9	12.22				
26	HL	400			/	144166	7	12.76				
27	Deb	918	1	D2	/	144166	5'	12.17			5	
28	Be	1130			/	144228	5'	12.74				
29	Be	915	1	17	/	144228	5'	12.01				
30					/							
31					/							

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

# Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A

SYSTEM NAME: Heceta Head State Park

SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N

Florence, OR 97439

MONTH/YEAR

PHONE: 541-547-3416

2024 Feb

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
1				
2				
3				
4	HZ	.5	at P. House	38920
5	JT	1	at CXT	38925
6			mix 18oz clz 1/2 lbs 2lbj	
7	Deb	.2		38915
8	Deb	.2		39032
9	Deb	.2	Backbrange valve closed	39065
10	Deb	.2		39092
11	HAWARD		NO positive results at RR's	39122
12	HAWARD			39146
13	bc	0.5 cad	mix new clz 2oz 1/2 lbs 6	39178
14	Deb	.2		39186
15				
16	bc	.8	2.25g	39227
17				392
18	HZ		2.25	39257
19				
20	Deb	1.0		39264
21	Deb	1.0		39271
22				
23	Deb	.2	Pumphouse 2 + Bassell	39282
24				
25	HZ	1.0	at RR's	39329
26	HZ	.2	at RR's Did not run water while cleaning	39334
27				
28				
29			cleaned line	
30	Deb	.2	CXT	39366
31				

Total: \_\_\_\_\_  
Write off when not producing water.

Total -- # days=monthly average

--- =